

# Report for the Periodic Monitoring of Emissions to Atmosphere

## Veolia ES Onyx Ltd

Permit No: BW 32811A  
Installation: Redbourn Treatment Plant  
Monitoring Dates: 5<sup>th</sup> June 2018  
Site Address: Redbourn Road, St Albans, Hertfordshire, AL3 6RP

Report Number: 11888v1  
Date of Report: 27 June 2018  
Report Author: Charlie Williams  
MCERTS No: MM17 1422

Version: 1      Visit: 1 in 2018

MCERTS Level: 1

Approved By: Andrew Davis  
MCERTS No: MM 02 089

Function: Principal Consultant  
MCERTS Level: 2 (TE1, TE2, TE3, TE4)

Signed: 


T: 01274 738668  
E: [Danieltaylor@envirocare.org](mailto:Danieltaylor@envirocare.org)  
Envirocare Technical Consultancy Ltd  
Bradford Chamber Business Park, New Lane, Bradford, BD4 8BX

### YOUR INDUSTRY EXPERTS



# Contents

Executive Summary.....	3
Monitoring Objectives.....	3
Monitoring Results .....	4
Operating Information .....	7
Monitoring Deviations .....	8
Supporting Information.....	9
Appendix 1: General Information.....	9
Appendix 2: A1 Scrubber Results and Calculations .....	10
Appendix 3: A2 Dust Silo Results and Calculations.....	21
Appendix 4: F3 Sample Gantry (fugitive) Results and Calculations.....	23
Appendix 5: F4 Waste Discharge Area (fugitive) Results and Calculations.....	25
Appendix 6: F5 Inner Bunding (fugitive) Results and Calculations.....	27
Appendix 7: Laboratory Analysis Results .....	29



# Executive Summary

## Monitoring Objectives

Veolia ES (UK) Ltd operates the Redbourn Treatment Plant near St Albans, where hazardous and non-hazardous waste liquids and sludge, from a broad variety of external processes, are brought by tanker to be unloaded and treated. As part of the environmental permit BW32811A issued to the site, Envirocare Technical Consultancy were contracted to test emissions to atmosphere from the lime silo dust filtration unit designated as emission point A2.

Testing was also conducted from the A1 Scrubber emission point, as part of an improvement program. Monitoring for potential pollutants in ambient air also took place at several key source points around the site.

The results of the testing form the basis of this report.

## Emission Point Identification

Substances to be Monitored	A1	A2	F3	F4	F5
	Scrubber	Dust Silo	Sample Gantry	Waste Discharge Area	Inner Bunding
Total Particulate Matter	✓	✓	✓	✓	✓
Ammonia	✓	-	✓	✓	✓
Hydrogen Chloride	✓	-	✓	✓	✓
Hydrogen Sulphide	✓	-	✓	✓	✓
Total VOCs	✓	-	✓	✓	✓
<b>Special requirements</b>	None				

Opinions and interpretations expressed within this report are outside the scope of Envirocare Technical Consultancy's MCERTS and UKAS accreditation.

## Monitoring Results

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
<b>A1 – Scrubber</b>	Total Particulate Matter	None	<b>0.327</b>	mg/Nm <sup>3</sup>	0.42 mg/Nm <sup>3</sup>	273K, 101.3kPa	05/06/18	11:52 – 12:52	BS EN 13284	MCERTS	Normal
	Ammonia	None	<b>0.26</b>	mg/Nm <sup>3</sup>	0.05 mg/Nm <sup>3</sup>	273K, 101.3kPa	05/06/18	15:31 – 16:31	BS EN 14791	MCERTS	Normal
	Hydrogen Chloride	None	<b>0.022</b>	mg/Nm <sup>3</sup>	0.007 mg/Nm <sup>3</sup>	273K, 101.3kPa	05/06/18	11:52 -12:52	BS EN 1911	MCERTS	Normal
	Hydrogen Sulphide	None	<b>0.14</b>	mg/Nm <sup>3</sup>	0.035 mg/Nm <sup>3</sup>	273K, 101.3kPa	05/06/18	15:31 – 16:31	US EPA M11	MCERTS	Normal
	Total VOCs	None	<b>1.21</b>	mg/Nm <sup>3</sup>	0.315 mg/Nm <sup>3</sup>	273K, 101.3kPa	05/06/18	15:31 – 16:31	PD CEN TS 13649	MCERTS	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Uncertainty (95% confidence)	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
<b>A2 – Dust Silo</b>	Total Particulate Matter	None	<b>1.77</b>	mg/Nm <sup>3</sup>	N/A	273K, 101.3kPa	05/06/18	15:25 – 16:25	MDHS 14/4	None	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
<b>F3 - Sample Gantry (Fugitive)</b>	Total Particulate Matter	None	<b>2.04</b>	mg/Nm <sup>3</sup>	273K, 101.3kPa	05/06/18	15:20 - 16:20	MDHS 14/4	None	Normal
	Ammonia	None	<b>&lt;0.01</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	9:07 - 15:20	Passive Sampling	None	Normal
	Hydrogen Chloride	None	<b>&lt;0.006</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	9:07 - 15:20	Passive Sampling	None	Normal
	Hydrogen Sulphide	None	<b>&lt;0.024</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	9:07 - 15:20	Passive Sampling	None	Normal
	Total VOCs	None	<b>0.27</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	9:07 - 15:20	Passive Sampling	None	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
<b>F4 - Waste Discharge Area (Fugitive)</b>	Total Particulate Matter	None	<b>2.33</b>	mg/Nm <sup>3</sup>	273K, 101.3kPa	05/06/18	15:18 - 16:18	MDHS 14/4	None	Normal
	Ammonia	None	<b>0.02</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	9:11 - 15:18	Passive Sampling	None	Normal
	Hydrogen Chloride	None	<b>0.008</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	9:11 - 15:18	Passive Sampling	None	Normal
	Hydrogen Sulphide	None	<b>&lt;0.024</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	9:11 - 15:18	Passive Sampling	None	Normal
	Total VOCs	None	<b>0.45</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	9:11 - 15:18	Passive Sampling	None	Normal

Emission Point Reference	Substance to be Monitored	Emission Limit Value	Periodic Monitoring Result	Units	Reference Conditions	Date of Sampling	Start and End Times	Monitoring Method Reference	Accreditation for use of Method	Operating Status
<b>F5 - Inner Bunding (Fugitive)</b>	Total Particulate Matter	None	<b>0.86</b>	mg/Nm <sup>3</sup>	273K, 101.3kPa	05/06/18	15:16 - 16:16	MDHS 14/4	None	Normal
	Ammonia	None	<b>&lt;0.01</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	8:56 - 15:15	Passive Sampling	None	Normal
	Hydrogen Chloride	None	<b>0.013</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	8:56 - 15:15	Passive Sampling	None	Normal
	Hydrogen Sulphide	None	<b>&lt;0.024</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	8:56 - 15:15	Passive Sampling	None	Normal
	Total VOCs	None	<b>0.22</b>	mg/m <sup>3</sup>	273K, 101.3kPa	05/06/18	8:56 - 15:15	Passive Sampling	None	Normal

## Operating Information

Emission Point Reference	Date	Process Type	Process Duration	Fuel	Feedstock	Abatement	Load	Comparison of Operator CEMS and Periodic Monitoring Results			
								Substance	CEMS Results	Periodic Monitoring Results	Units
A1 – Scrubber	26/09/17	Continuous	Dependent on deliveries	N/A	Hazardous & non-hazardous materials.	Chemical Absorption Scrubber	Unknown	N/A	N/A	N/A	N/A
A2 – Dust Silo	26/09/17	Continuous	Intermittent	N/A	Lime	Filter	Unknown	N/A	N/A	N/A	N/A
F3 – Sample Gantry (Fugitive)	26/09/17	Batch	Varies on tanker size and number of deliveries	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F4 – Waste Discharge Area (Fugitive)	26/09/17	Batch	Varies on tanker size and number of deliveries	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
F5 – Inner Bunding (Fugitive)	26/09/17	Continuous	Continuous	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

## Monitoring Deviations

Emission Point Reference	Substance Deviations	Monitoring Deviations	Other Relevant Issues
A1 - Scrubber	None	Sampling of particulate, HCl and ammonia took place through one port however the number of points was doubled. Breakthrough of hydrogen chloride from the first impinger to the second.	None
A2 - Lime Silo	None	None	None
F3 - Sample Gantry	None	None	None
F4 - Waste Discharge Area	None	None	None
F5 - Inner Bunding	None	None	None



# Supporting Information

## Appendix 1: General Information

### Monitoring Organisation Staff Detail

Personnel	Function in monitoring campaign	MCERTS Level	MCERTS Number
Mr C Davies	Team Leader	MCERTS Level 2 (TE1, TE2, TE3,TE4)	MM 03 252
Mr T Arden	Technician	MCERTS Trainee	MM 18 1478

### Monitoring Methods

Pollutant Species	Standard	Technique	Envirocare Internal Procedure
Total Particulate Matter	BS EN 13284	Gravimetric	ETC-M-01
Total Particulate Matter	MDHS 14/4	Gravimetric	ETC-HS-01
Hydrogen Chloride	BS EN 1911	IC	ETC-M-13
Total VOCs	BS EN 13649	GC-MS	ETC-M-18
Hydrogen Sulphide	US EPA M11	Dist-VAS	ETC-M-30
Ammonia	BS EN 14791	Colorimetry	ETC-M-33
Stack Temperature + Velocity	BS EN ISO 16911-1	Pitot Tube + Thermocouple	ETC-M-46

### Equipment Checklist

Equipment ID	Model Number	Purpose
P70	Sidekick	Portable sampling pump
P76	Sidekick	Portable sampling pump
ENV8	Sidekick	Portable sampling pump
ENV 6	Sidekick	Portable sampling pump
ENV 9	Sidekick	Portable sampling pump
ENV 10	Sidekick	Portable sampling pump
IP3	Westec Superprobe	Integrated Probe
CB5	Anderson Console	Isokinetic Sampler

## Appendix 2: A1 Scrubber Results and Calculations

Photograph of the sampling location and positions



## Flow Criteria Measurements

Duct Diameter (cm)	Cross Sectional Area (m <sup>2</sup> )	Barometric Pressure (mbar)	Ambient Temperature (°C)	Stack Gas Mr (g/mol)	Pitot Coefficient
84.0	0.554	1024	16	29.00	0.835

Sample Line	Traverse Point	Traverse Position	Differential Pressure Reading (cmH <sub>2</sub> O)				Stack Velocity (m/s)	Stack Temp (°C)	Angle of Swirl
			1	2	3	Average			
LHS	1.00	4.2	0.20	0.20	0.20	0.200	4.69	15	0
	2.00	12.6	0.20	0.20	0.20	0.200	4.69	15	0
	3.00	21	0.20	0.20	0.20	0.200	4.69	15	0
	4.00	29.4	0.20	0.20	0.20	0.200	4.69	15	0
	5.00	37.8	0.20	0.20	0.20	0.200	4.69	15	0
	6.00	46.2	0.20	0.18	0.18	0.187	4.54	15	0
	7.00	54.6	0.18	0.18	0.16	0.173	4.37	15	0
	8.00	63	0.16	0.18	0.16	0.167	4.29	15	0
	9.00	71.4	0.16	0.18	0.16	0.167	4.29	15	0
	10.00	79.8	0.16	0.16	0.16	0.160	4.20	15	0

Parameter	Mean Duct Velocity	Velocity Ratio (Max:Min)	Mean Stack Temperature	Mean Stack Temperature	Stack Gas Volume Flow	Corrected Stack Gas Volume Flow
Value	4.51	1:1	16	288	9006.6	8630.2
Units	m/s	-	°C	K	m <sup>3</sup> /hr	Nm <sup>3</sup> /hr

## Water Vapour Measurements

The water content was measured as a part of both the particulate and ammonia sampling processes, and was found to be between 1.41% and 1.95%.

Particulates and Hydrogen Chloride

**Sampling Run No: 1**

<b>Stack details: A1</b>	<b>Duct diameter:</b> 84.0 (cm)	<b>Date:</b> 05/06/2018
	<b>Cross-sectional area:</b> 0.554 (m <sup>2</sup> )	<b>Operators:</b> CD/TA

Meter Box No: CB5 Gas Meter Coefficient: 0.944 Pitot Coefficient: 0.835 Molecular weight of Stack Gas: 29.0 g/mole	Barometric Pressure (mbar)		Ambient Temperature (°C)		Leak Check (l/min)		Time	
	Before	After	Before	After	Before	After	Start	End
	1024	1024	16.0	18.0	0.10	0.10	11:52	12:52

<b>Nozzle diameter=</b>	<b>10.97</b>	<b>mm</b>
<b>Average Stack Temperature</b>	<b>14.8</b>	<b>°c</b>
<b>Average Stack Velocity=</b>	<b>4.65</b>	<b>metres/second</b>
<b>Isokineticity =</b>	<b>102.5</b>	<b>%</b>
<b>Total Sampling Time=</b>	<b>60.0</b>	<b>minutes</b>
<b>Gasmeter Difference=</b>	<b>1730.0</b>	<b>litres</b>
<b>Corrected Gasmeter Volume</b>	<b>1632.8</b>	<b>(Gasmeter Coefficient)</b>
<b>Mean Sampling Rate =</b>	<b>27.2</b>	<b>litres/minute</b>

<b><u>Emission Calculations</u></b>		
Corrected Total Dry Gas Volume =	1531.27	Litres (273K; 101.3kPa)
Mass of water collected Run1=	17.6	g
Volume of Mass of Water =	21.9	NLitres
Water Content =	1.4	%
<b>Corrected Total Particulate Matter Emission =</b>	<b>0.327</b>	<b>mg/Nm<sup>3</sup> (273K; 101.3kPa and dry gas)</b>
<b>Corrected Hydrogen Chloride Emission =</b>	<b>0.022</b>	<b>mg/Nm<sup>3</sup> (273K; 101.3kPa and dry gas)</b>

# Ammonia

## Sampling Run No: 1

<b>Stack details: A1</b>	<b>Duct diameter:</b> 84.0 (cm)	<b>Date:</b> 05/06/2018
	<b>Cross-sectional area:</b> 0.554 (m <sup>2</sup> )	<b>Operators:</b> CD / TA

Meter Box No:	CB5	g/gmole cm H2O	Barometric Pressure (mbar)		Ambient Temperature (°C)		Leak Check (l/min)		Time	
Gas Meter Coefficient:	0.952		Before	After	Before	After	Before	After	Start	End
Pitot Coefficient	0.835		1024	1024	16.0	17.0	0.10	0.10	15:31	16:31
Molecular weight of Stack Gas	29.00									
Static Pressure in Stack	0.10									

<b>Average Stack Velocity=</b>	<b>4.7</b>	<b>metres/second</b>
<b>Total Sampling Time=</b>	<b>60.0</b>	<b>minutes</b>
<b>Gasmeter Difference=</b>	<b>1039.0</b>	<b>litres</b>
<b>Corrected Gasmeter Volume</b>	<b>989.1</b>	<b>(Gasmeter Coefficient)</b>
<b>Mean Sampling Rate =</b>	<b>16.5</b>	<b>litres/minute</b>

### Emission Calculations

Corrected Total Dry Gas Volume =	935.61	Litres (273K; 101.3kPa)
Ammonia Emission =	0.26	mg/Nm <sup>3</sup> (273K; 101.3kPa; Dry)
Mass of water collected Run1=	14.8	g
Volume of Mass of Water =	18.4	NLitres
Water Content =	1.9	%
<b>Corrected Ammonia Emission =</b>	<b>0.26</b>	<b>mg/Nm<sup>3</sup> (273K; 101.3kPa and dry gas)</b>

## Hydrogen Sulphide

Sampling Details		
Collection Media	Zinc Acetate	-
Sampling Rate	740	mL/min
Test Duration	60.0	min
Sample Volume	44.40	L
Corrected Sample Volume	42.11	NL

Analysis Details		
1st Collector Reference	11888-Y	-
1st Collector Concentration	3.96	µg
2nd Collector Reference	11888-Z	-
2nd Collector Concentration	187	µg
Blank Concentration	0.05	mg/Nm <sup>3</sup>
Has breakthrough occurred?	Yes	-

Date	Operators
05/06/18	TA - CD

Parameter	Before	After	Unit
Barometric Pressure	1024	1024	mbar
Operating Temperature	18	18	°C
Leak Check	Pass	Pass	-
Time	15:31	16:31	-

Emissions Calculations		
Emission Limit Value	-	mg/Nm <sup>3</sup>
<b>Corrected Emission</b>	<b>0.14</b>	<b>mg/Nm<sup>3</sup></b>
Corrected to 0% Oxygen	N/A	mg/Nm <sup>3</sup>
<b>Mass Emission Rate</b>	<b>0.00</b>	<b>kg/hr</b>

## Total Volatile Organic Compounds

Sampling Details		
Collection Media	226-09	-
Sampling Rate	248	mL/min
Test Duration	60.0	min
Sample Volume	14.85	L
Corrected Sample Volume	14.08	NL

Analysis Details		
1st Collector Reference	5817315217	-
1st Collector Concentration	17	µg
2nd Collector Reference	6125811484	-
2nd Collector Concentration	<1	µg
Blank Concentration	0.07	mg/Nm <sup>3</sup>
Has breakthrough occurred?	No	-

Date	Operators
05/06/18	TA - CD

Parameter	Before	After	Unit
Barometric Pressure	1024	1024	mbar
Operating Temperature	18	18	°C
Leak Check	Pass	Pass	-
Time	15:31	16:31	-

Emissions Calculations		
Emission Limit Value	-	mg/Nm <sup>3</sup>
<b>Corrected Emission</b>	<b>1.21</b>	<b>mg/Nm<sup>3</sup></b>
Corrected to 11% Oxygen	N/A	mg/Nm <sup>3</sup>
<b>Mass Emission Rate</b>	<b>0.01</b>	<b>kg/hr</b>

## Analysis Results

### Particulates

#### FILTER WEIGHINGS

Filter type	110mm QMA	
Filter reference	AF	AB
	Run 1 mg	Blank mg
Filter weight change	< 0.1	< 0.1
Probe wash weight change	0.50	0.50
<b>Total deposit</b>	<b>0.50</b>	<b>0.50</b>

#### MOISTURE WEIGHINGS

	No.1 (g)	No.2(g)	No.3(g)	no.4(g)
Impinger end	589.5	604	682.2	893.8
Impinger start	602.2	594.5	678.6	876.6
Moisture in each impinger	-12.7	9.5	3.6	17.2
<b>Total Moisture</b>	<b>17.6</b>	<b>g</b>		

Particulate Emission Limit Value	N/A	mg/m <sup>3</sup>	Date of Analysis	20/06/2018
Overall Blank Particulate Value	0.50	mg/m <sup>3</sup>	Analysis Laboratory	CLS
Is overall blank less than 10% of emission limit value?	N/A		Analytical Method	Gravimetric
			Accreditation	ISO 17025



## Hydrogen Chloride

### HYDROGEN CHLORIDE ANALYSIS

Sample Reference	11888-B	11888-C	11888-A
	Run 1	Run 1	BLANK
	1st Impinger	2nd Impinger	
	µg	µg	
Hydrogen Chloride	19.8	13.5	<6
Impinger Efficiency Run 1 (%)	59	FAIL	

## Ammonia

### ANALYSIS RESULTS

Sample Reference	11888-K	11888-L	11888-J
	Run 1	Run 1	BLANK
	1st Impinger	2nd Impinger	
	µg	µg	µg
Ammonia	240	< 16	< 16
Impinger Efficiency Run 1 (%)	-	> 94	

### MOISTURE WEIGHINGS RUN 1

	No.1 (g)	No.2(g)	No.3(g)	No.4(g)
Impinger end	555.5	766.8	604.4	901.4
Impinger start	554	762.5	602.9	893.9
Moisture in each impinger	1.5	4.3	1.5	7.5
<b>Moisture Run 1</b>	<b>14.8</b>			

Emission Limit Value            N/A      mg/m<sup>3</sup>  
 Overall Blank Value                0.02     mg/m<sup>3</sup>

## Uncertainty Calculations

### Particulates

#### TOTAL PARTICULATE MEASUREMENTS TO BS EN 13284 MEASUREMENT UNCERTAINTY CALCULATION

##### Run 1

Emission Limit value =	-	mg/Nm <sup>3</sup>	Mean Emission Concentration =	0.327	mg/Nm <sup>3</sup>
Mean Sampling Rate =	27.20	litres/minute	Monitoring Time =	60.0	mins
Leak Rate =	0.10	litres/minute	Envirocare Console used =	<b>CB5</b>	
Barometric Pressure =	1024	mbar	Temperature uncertainty =	0.24	°C
Duct Temperature =	14.8	°C	Gasmeter uncertainty =	0.37	%
Sampled Gas Volume =	1531.27	litres	Barometer used =	<b>BA11</b>	
			Barometer uncertainty =	1	mbar

Source of Uncertainty	ASD *	BS EN 13284		Envirocare Certified Value	Units	% Actual value	Source Uncert u	Combined Uncert u <sup>2</sup>
		Uncertainty Criteria	Max Uncert Value					
Weighing Procedure	Std	5% of limit value		0.215	mg		0.2150	0.04623
Leak Rate	Rect	<2% of sampling rate	0.54	0.10	l/min	0.37	0.0007	0.00000
Time	Std	1sec in 1hour = 0.028%	2	1.00	secs	0.03	0.0001	0.00000
Gasmeter Volume	Std	<2%	30.63	5.67	litres	0.37	0.0012	0.00000
Std Ref Conditions Corrections								
Temperature	Std	1% of value	2.9	0.24	°C	1.62	0.0053	0.00003
Pressure	Std	1% of value	10.24	1	mbar	0.10	0.0003	0.00000
<b>Total</b>								0.04626
<b>Combined Standard Uncertainty [(Sum u<sup>2</sup>)<sup>0.5</sup>]</b>								0.215
<b>Measurement Uncertainty (mg/Nm<sup>3</sup>) (95% Confidence Value)</b>								<b>0.42</b>

### Hydrogen Chloride

#### Hydrogen Chloride Sampling to BS EN 1911 MEASUREMENT UNCERTAINTY CALCULATION

##### Run 1

Emission Limit value =	N/A	mg/Nm <sup>3</sup>	Mean Emission Concentration =	0.02	mg/Nm <sup>3</sup>
Mean Sampling Rate =	27.20	litres/minute	Monitoring Time =	60.0	mins
Leak Rate =	0.10	litres/minute	Envirocare Console used =	<b>CB5</b>	
Barometric Pressure =	1024	mbar	Temperature uncertainty =	0.24	°C
Duct Temperature =	14.8	°C	Gasmeter uncertainty =	0.37	%
Sampled Gas Volume =	1531.27	litres	Barometer used =	<b>BA11</b>	
			Barometer uncertainty =	1	mbar

Source of Uncertainty	ASD *	BS EN 1911		Envirocare Certified Value	Units	% Actual value	Source Uncert u	Combined Uncert u <sup>2</sup>
		Uncertainty Criteria	Max Uncert Value					
Leak Rate	Rect	<2% of sampling rate	0.54	0.10	l/min	0.37	0.0000	0.00000
Time	Std	1sec in 1hour = 0.028%	2	1.00	secs	0.03	0.0000	0.00000
Gasmeter Volume	Std	<2%	30.63	5.67	litres	0.37	0.0001	0.00000
Std Ref Conditions Corrections								
Temperature	Std	1% of value	2.9	0.24	°C	1.62	0.0004	0.00000
Pressure	Std	1% of value	10.24	1	mbar	0.10	0.0000	0.00000
<b>Total</b>								0.000

Analysis result mg	Analysis Uncertainty %	Analysis Uncertainty u mg	u <sup>2</sup>	Total Sampling Uncertainty	Combined Standard Uncertainty [(Sum u <sup>2</sup> ) <sup>0.5</sup> ]	Measurement Uncertainty (95% Confidence) (mg/Nm <sup>3</sup> )	Expanded Total Uncertainty as a percentage of ELV (95% Confidence)
HCl	0.0	10	0.00333	0.00	0.00	0.007	N/A

# Ammonia

## Ammonia Sampling to BS EN 14791 MEASUREMENT UNCERTAINTY CALCULATION

### A1 Run 1

Emission Limit value =	N/A	mg/Nm <sup>3</sup>	Mean Emission Concentration =	0.26	mg/Nm <sup>3</sup>
Mean Sampling Rate =	16.49	litres/minute	Monitoring Time =	60.0	mins
Leak Rate =	0.10	litres/minute	Envirocare Console used =	<b>CB5</b>	
Barometric Pressure =	1024	mbar	Temperature uncertainty =	0.24	°C
Duct Temperature =	15.0	°C	Gasmeter uncertainty =	0.37	%
Sampled Gas Volume =	935.61	litres	Barometer used =	<b>BA11</b>	
			Barometer uncertainty =	1	mbar

Source of Uncertainty	ASD *	BS EN 14791		Envirocare Certified Value	Units	% Actual value	Source Uncert u	Combined Uncert u <sup>2</sup>
		Uncertainty Criteria	Max Uncert Value					
Leak Rate	Rect	<2% of sampling rate	0.33	0.10	l/min	0.61	0.0009	0.00000
Time	Std	1sec in 1hour = 0.028%	2	1.00	secs	0.03	0.0001	0.00000
Gasmeter Volume	Std	<2%	18.71	3.46	litres	0.37	0.0009	0.00000

#### Std Ref Conditions Corrections

Temperature	Std	1% of value	2.9	0.24	°C	1.60	0.0041	0.00002
Pressure	Std	1% of value	10.24	1	mbar	0.10	0.0003	0.00000
<b>Total</b>								<b>0.00</b>

	Analysis result mg	Analysis Uncertainty %	Analysis Uncertainty u mg	u <sup>2</sup>	Total Sampling Uncertainty	Combined Standard Uncertainty [(Sum u <sup>2</sup> ) <sup>0.5</sup> ]	Measurement Uncertainty (95% Confidence) (mg/Nm <sup>3</sup> )	Expanded Total Uncertainty as a percentage of ELV (95% Confidence)
NH3	0.26	10	0.0256	0.00	0.0000	0.03	<b>0.051</b>	N/A

# Hydrogen Sulphide

Parameter	Value	Unit
Emission Limit Value (ELV)	-	mg/m <sup>3</sup>
Mean Sampling Rate	0.7	L/min
Barometric Pressure	1024	mbar

Parameter	Value	Unit
Emission Concentration	0.14	mg/m <sup>3</sup>
Monitoring Duration	60	min
Average Stack Temperature	15	°C

Source of Uncertainty	Uncertainty Criteria	Actual Source Value	Units	% Actual Value	Source Uncertainty u	Combined Uncertainty u <sup>2</sup>
Analysis	25% of result (95% confidence)	0.02	mg	12.50	0.017307543	0.00030
Leak Rate	<2% of sampling rate	0.01	L/min	135	0.002769207	0.00001
Time	1minute	0.5	min	0.01	192306E-05	0.00000
Sampling Flow Rate	2% of value	0.01	L/min	135	0.001871086	0.00000
Std Ref Conditions						
Temperature	1% of value	0.5	°C	0.17	0.000240383	0.00000
Pressure	1% of value	5	mbar	0.49	0.000676076	0.00000
<b>Total</b>						<b>0.000</b>
<b>Combined Standard Uncertainty [(sum u<sup>2</sup>)<sup>0.5</sup>]</b>						<b>0.018</b>
<b>Expanded Total Uncertainty as a % of emission conc. (95% confidence)</b>						<b>24.973</b>
<b>Expanded Total Uncertainty (mg/m<sup>3</sup>) (95% confidence)</b>						<b>0.035</b>
<b>Expanded Total Uncertainty as a % of emission limit value (95% confidence)</b>						<b>-</b>

## Total Volatile Organic Compounds

Parameter	Value	Unit
Emission Limit Value (ELV)	-	mg/m <sup>3</sup>
Mean Sampling Rate	0.248	L/min
Barometric Pressure	1024	mbar

Parameter	Value	Unit
Emission Concentration	121	mg/m <sup>3</sup>
Monitoring Duration	60	min
Average Stack Temperature	15	°C

Source of Uncertainty	Uncertainty Criteria	Actual Source Value	Units	% Actual Value	Source Uncertainty u	Combined Uncertainty u <sup>2</sup>
Analysis	25% of result (95% confidence)	0.15	mg	12.50	0.150894118	0.02277
Leak Rate	<2% of sampling rate	0.01	L/min	4.04	0.024143059	0.00058
Time	1 minute	0.5	min	0.01	0.00016766	0.00000
Sampling Flow Rate	2% of value	0.01	L/min	4.04	0.048773856	0.00238
Std Ref Conditions						
Temperature	1% of value	0.5	°C	0.17	0.002095752	0.00000
Pressure	1% of value	5	mbar	0.49	0.005894301	0.00003
<b>Total</b>						0.026
<b>Combined Standard Uncertainty [(sum u<sup>2</sup>)<sup>0.5</sup>]</b>						0.161
<b>Expanded Total Uncertainty as a % of emission conc. (95% confidence)</b>						26.065
<b>Expanded Total Uncertainty (mg/m<sup>3</sup>) (95% confidence)</b>						0.315
<b>Expanded Total Uncertainty as a % of emission limit value (95% confidence)</b>						-

## Appendix 3: A2 Dust Silo Results and Calculations

Photograph of the sampling location and positions



Flow Criteria Measurements  
Not applicable.

Water Vapour Measurements  
Not applicable.

**PARTICULATE MATTER EMISSIONS TO ATMOSPHERE DATA (MDHS 14 METHOD)**

Date: 05/06/18

Site: **Veolia Redbourn**  
 Atmospheric Press: 1024 mbar

Ambient Temperature 17 °C

PARTICULATE MONITORING (MDHS-14)												Filter Masses			Concn. Partic. Matter	Corr. Part. Matt. Conc.
Duct Reference	Pump No.	Filter No.	Flow Start (l/min)	Checks Finish (l/min)	Average Flow (l/min)	Time ON (hr:m:s)	Time OFF (hr:m:s)	Elapsed Time (hr:m:s)	Elapsed Time (min)	Air Volume Sampled (m <sup>3</sup> )	Initial (mg)	Final (mg)	Difference (mg)	(mg/m <sup>3</sup> )	(mg/Nm <sup>3</sup> )	
<b>A2</b>	Dust Silo	Env8	<b>2-677</b>	2.05	2.07	2.06	15:25:00	16:25:00	01:00:00	60.00	0.12	-	-	0.23	1.86	<b>1.77</b>

Analysis Results

For the analysis of the passive absorption tubes see Appendix 7.

Uncertainty Calculations

Not applicable.

## Appendix 4: F3 Sample Gantry (fugitive) Results and Calculations

Photograph of the sampling location and positions



Flow Criteria Measurements

Not applicable.

Water Vapour Measurements

Not applicable.

**PARTICULATE MATTER EMISSIONS TO ATMOSPHERE DATA (MDHS 14 METHOD)**

Date: 05/06/18

Site: **Veolia Redbourn**  
 Atmospheric Press: 1024 mbar

Ambient Temperature 17 °C

PARTICULATE MONITORING (MDHS-14)												Filter Masses			Concn. Partic. Matter	Corr. Part. Matt. Conc.
Duct Reference	Pump No.	Filter No.	Flow Start (l/min)	Checks Finish (l/min)	Average Flow (l/min)	Time ON (hr:m:s)	Time OFF (hr:m:s)	Elapsed Time (hr:m:s)	Elapsed Time (min)	Air Volume Sampled (m <sup>3</sup> )	Initial (mg)	Final (mg)	Difference (mg)	(mg/m <sup>3</sup> )	(mg/Nm <sup>3</sup> )	
<b>F3</b>	Sample Gantry	Env6	<b>2-678</b>	2.01	2.03	2.02	15:20:00	16:20:00	01:00:00	60.00	0.12	-	-	0.26	2.15	<b>2.04</b>

Analysis Results

For the analysis of the passive absorption tubes see Appendix 7.

Uncertainty Calculations

Not Applicable.



## Appendix 5: F4 Waste Discharge Area (fugitive) Results and Calculations

Photograph of the sampling location and positions



Flow Criteria Measurements  
Not applicable.

Water Vapour Measurements  
Not applicable.

**PARTICULATE MATTER EMISSIONS TO ATMOSPHERE DATA (MDHS 14 METHOD)**

Date: 05/06/18

Site: **Veolia Redbourn**  
 Atmospheric Press: 1024 mbar

Ambient Temperature 17 °C

PARTICULATE MONITORING (MDHS-14)												Filter Masses			Concn. Partic. Matter (mg/m <sup>3</sup> )	Corr. Part.Matt. Conc. (mg/Nm <sup>3</sup> )
Duct Reference	Pump No.	Filter No.	Flow Start (l/min)	Checks Finish (l/min)	Average Flow (l/min)	Time ON (hr:m:s)	Time OFF (hr:m:s)	Elapsed Time (hr:m:s)	Elapsed Time (min)	Air Volume Sampled (m <sup>3</sup> )	Initial (mg)	Final (mg)	Difference (mg)			
<b>F4</b>	Waste Discharge	P70	<b>2-679</b>	2.03	2.05	2.04	15:18:00	16:18:00	01:00:00	60.00	0.12	-	-	0.30	2.45	<b>2.33</b>

Analysis Results

For the analysis of the passive absorption tubes see Appendix 7.

Uncertainty Calculations

Not applicable.

## Appendix 6: F5 Inner Bunding (fugitive) Results and Calculations

Photograph of the sampling location and positions



Flow Criteria Measurements  
Not applicable.

Water Vapour Measurements  
Not applicable.

**PARTICULATE MATTER EMISSIONS TO ATMOSPHERE DATA (MDHS 14 METHOD)**

Date: 05/06/18

Site: **Veolia Redbourn**  
 Atmospheric Press: 1024 mbar

Ambient Temperature 17 °C

PARTICULATE MONITORING (MDHS-14)												Filter Masses			Concn. Partic. Matter (mg/m <sup>3</sup> )	Corr. Part.Matt. Conc. (mg/Nm <sup>3</sup> )
Duct Reference	Pump No.	Filter No.	Flow Start (l/min)	Checks Finish (l/min)	Average Flow (l/min)	Time ON (hr:m:s)	Time OFF (hr:m:s)	Elapsed Time (hr:m:s)	Elapsed Time (min)	Air Volume Sampled (m <sup>3</sup> )	Initial (mg)	Final (mg)	Difference (mg)			
<b>F5</b>	Inner Bunding	P76	<b>2-676</b>	2.05	2.00	2.03	15:16:00	16:16:00	01:00:00	60.00	0.12	-	-	0.11	0.91	<b>0.86</b>

Analysis Results

For the analysis of the passive absorption tubes see Appendix 7.

Uncertainty Calculations

Not applicable.

## Appendix 7: Laboratory Analysis Results



CONCEPT LIFE SCIENCES  
DELIVERING SCIENCE

Concept Life Sciences is a trading name of  
Concept Life Sciences Analytical & Development  
Services Limited registered in England and  
Wales (No 2514788)

# Concept Life Sciences

## Certificate of Analysis

Hadfield House  
Hadfield Street  
Cornbrook  
Manchester  
M16 9FE  
Tel : 0161 874 2400  
Fax : 0161 874 2404

**Report Number:** 743334-1

**Date of Report:** 20-Jun-2018

**Customer:** Envirocare Technical Consultancy Ltd  
Office 17  
Bradford Chamber Business Park  
New Lane  
Bradford  
BD4 8BX

**Customer Contact:** Mr Andrew Davis

**Customer Job Reference:** 11888

**Customer Purchase Order:** 11060

**Date Job Received at Concept:** 11-Jun-2018

**Date Analysis Started:** 12-Jun-2018

**Date Analysis Completed:** 20-Jun-2018

The results reported relate to samples received in the laboratory and may not be representative of a whole batch.

Opinions and interpretations expressed herein are outside the scope of UKAS accreditation

This report should not be reproduced except in full without the written approval of the laboratory

Tests covered by this certificate were conducted in accordance with Concept Life Sciences SOPs

All results have been reviewed in accordance with Section 25 of the Concept Life Sciences, Analytical Services Quality Manual



1549

Report checked  
and authorised by :  
Lauren Clarke  
Customer Service Advisor

Issued by :  
Lauren Clarke  
Customer Service Advisor

<b>Concept Reference:</b> 743334							
<b>Customer Reference:</b> 11888							
<b>Radiello 168 tube</b> Analysed as Radiello 168 tube							
<b>Ammonia expressed as NH3</b>							
<b>Concept Reference</b>				743334 022	743334 023	743334 024	
<b>Customer Sample Reference</b>				A667B	A668B	A669B	
<b>Test Sample</b>				AR	AR	AR	
<b>Sampling Time (min)</b>				300	300	300	
<b>Date Sampled</b>				05-JUN-2018	05-JUN-2018	05-JUN-2018	
<b>Determinand</b>	<b>Method</b>	<b>LOD</b>	<b>Units</b>	<b>Symbol</b>			
Ammonia expressed as NH3	Colorimetry	1	µg	N	<1	1	<1
	Calc	Calc	mg/m3	N	<0.01	0.02	<0.01
	Calc	Calc	ppm	N	<0.020	0.023	<0.020

<b>Concept Reference:</b> 743334							
<b>Customer Reference:</b> 11888							
<b>Filter Quartz 110mm</b> Analysed as Filter Quartz 110mm							
<b>Miscellaneous</b>							
<b>Concept Reference</b>				743334 013	743334 015		
<b>Customer Sample Reference</b>				AB	AF		
<b>Test Sample</b>				AR	AR		
<b>Date Sampled</b>				05-JUN-2018	05-JUN-2018		
<b>Determinand</b>	<b>Method</b>	<b>LOD</b>	<b>Units</b>	<b>Symbol</b>			
Particulates (Total)	Grav (5 Dec)	0.10	mg	U	<0.10	<0.10	
Weight Gain	Grav		mg	U	-0.57	-4.6	

<b>Concept Reference:</b> 743334									
<b>Customer Reference:</b> 11888									
<b>Filter IOM</b> Analysed as Filter IOM									
<b>Miscellaneous</b>									
<b>Concept Reference</b>			743334 017	743334 018	743334 019	743334 020	743334 021		
<b>Customer Sample Reference</b>			2-680	2-677	2-678	2-679	2-676		
<b>Test Sample</b>			AR	AR	AR	AR	AR		
<b>Date Sampled</b>			05-JUN-2018	05-JUN-2018	05-JUN-2018	05-JUN-2018	05-JUN-2018		
<b>Determinand</b>	<b>Method</b>	<b>LOD</b>	<b>Units</b>	<b>Symbol</b>					
Particulates (Total)	Grav (5 Dec)	0.05	mg	U	0.23	0.23	0.26	0.30	0.11
Weight Gain	Grav		mg	U	0.23	0.23	0.26	0.30	0.11

<b>Concept Reference:</b> 743334							
<b>Customer Reference:</b> 11888							
<b>Radiello 130 Tube</b> Analysed as Radiello 130 Tube							
<b>TVOC</b>							
<b>Concept Reference</b>				743334 031	743334 032	743334 033	
<b>Customer Sample Reference</b>				A037P	A038P	A039P	
<b>Test Sample</b>				AR	AR	AR	
<b>Sampling Time (min)</b>				300	300	300	
<b>Date Sampled</b>				05-JUN-2018	05-JUN-2018	05-JUN-2018	
<b>Determinand</b>	<b>Method</b>	<b>LOD</b>	<b>Units</b>	<b>Symbol</b>			
Volatile Organic Compounds (Total)	GC/MS	2	µg	N	6	10	5
	Calc	Calc	mg/m3	N	0.27	0.45	0.22
	Calc	Calc	ppm	N	0.073	0.12	0.057

Concept Reference: 743334						
Customer Reference: 11888						
Wash(Acetone)                      Analysed as Wash(Acetone)						
Particulates						
Concept Reference			743334 014	743334 016		
Customer Sample Reference			AB	AF		
Test Sample			AR	AR		
Date Sampled			05-JUN-2018	05-JUN-2018		
Determinand	Method	LOD	Units	Symbol		
Particulates (Total)	Grav	0.3	mg	U	0.5	0.5

Concept Reference: 743334						
Customer Reference: 11888						
Radiello 170 Tube                      Analysed as Radiello 170 Tube						
Hydrogen sulphide						
Concept Reference			743334 028	743334 029	743334 030	
Customer Sample Reference			E823V	E824V	E825V	
Test Sample			AR	AR	AR	
Sampling Time (min)			300	300	300	
Date Sampled			05-JUN-2018	05-JUN-2018	05-JUN-2018	
Determinand	Method	LOD	Units	Symbol		
Hydrogen sulphide	Colorimetry	0.50	µg	N	<0.50	<0.50
	Calc	Calc	mg/m3	N	<0.024	<0.024
	Calc	Calc	ppm	N	<0.017	<0.017

Concept Reference: 743334						
Customer Reference: 11888						
Radiello 169 tube                      Analysed as Radiello 169 tube						
Hydrochloric acid						
Concept Reference			743334 025	743334 026	743334 027	
Customer Sample Reference			A4151	A4161	A4171	
Test Sample			AR	AR	AR	
Sampling Time (min)			300	300	300	
Date Sampled			05-JUN-2018	05-JUN-2018	05-JUN-2018	
Determinand	Method	LOD	Units	Symbol		
Hydrochloric acid	IC	0.2	µg	N	<sup>(13)</sup> <0.2	<sup>(13)</sup> 0.2
	Calc	Calc	mg/m3	N	<0.006	0.008
	Calc	Calc	ppm	N	<0.0043	0.0051

Concept Reference: 743334						
Customer Reference: 11888						
Impinger (0.05M Sulphuric Acid)                      Analysed as Impinger (0.1N Sulphuric Acid)						
Ammonia expressed as NH3						
Concept Reference			743334 010	743334 011	743334 012	
Customer Sample Reference			11888-J	11888-K	11888-L	
Test Sample			AR	AR	AR	
Date Sampled			05-JUN-2018	05-JUN-2018	05-JUN-2018	
Determinand	Method	LOD	Units	Symbol		
Ammonia expressed as NH3	Colorimetry	0.1	mg/l	U	<0.1	1.2
Volume	Vol	1	ml	U	160	200



<b>Concept Reference:</b> 743334 <b>Customer Reference:</b> 11888  <b>Impinger(DI water)</b> Analysed as Impinger(DI water) <b>Hydrogen Chloride</b>							
<b>Concept Reference</b>		743334 007	743334 008	743334 009			
<b>Customer Sample Reference</b>		11888-A	11888-B	11888-C			
<b>Test Sample</b>		AR	AR	AR			
<b>Date Sampled</b>		05-JUN-2018	05-JUN-2018	05-JUN-2018			
<b>Determinand</b>	<b>Method</b>	<b>LOD</b>	<b>Units</b>	<b>Symbol</b>			
Hydrogen Chloride	IC	0.05	mg/l	U	<0.05	<sup>(13)</sup> 0.09	<sup>(13)</sup> 0.09
Volume	Vol	1	ml	U	120	220	150

<b>Concept Reference:</b> 743334 <b>Customer Reference:</b> 11888  <b>Tube (Charcoal 226-09)</b> Analysed as Tube (Charcoal 226-09) <b>TVOC</b>							
<b>Concept Reference</b>		743334 001	743334 002	743334 003			
<b>Customer Sample Reference</b>		722140340	5817315217	6125811484			
<b>Test Sample</b>		AR	AR	AR			
<b>Date Sampled</b>		05-JUN-2018	05-JUN-2018	05-JUN-2018			
<b>Determinand</b>	<b>Method</b>	<b>LOD</b>	<b>Units</b>	<b>Symbol</b>			
Volatile Organic Compounds (Total)	GC/MS	1	µg	N	<1	17	<1

<b>Concept Reference:</b> 743334 <b>Customer Reference:</b> 11888  <b>Impinger (zinc acetate)</b> Analysed as Impinger (zinc acetate) <b>Hydrogen sulphide</b>							
<b>Concept Reference</b>		743334 004	743334 005	743334 006			
<b>Customer Sample Reference</b>		11888-X	11888-Y	11888-Z			
<b>Test Sample</b>		AR	AR	AR			
<b>Date Sampled</b>		05-JUN-2018	05-JUN-2018	05-JUN-2018			
<b>Determinand</b>	<b>Method</b>	<b>LOD</b>	<b>Units</b>	<b>Symbol</b>			
Hydrogen sulphide	Dist-VAS	0.05	mg/l	N	0.13	0.12	0.11
Volume	Vol	1	ml	N	16	33	17

### Index to symbols used in 743334-1

Value	Description
AR	As Received
13	Results have been blank corrected.
U	Analysis is UKAS accredited
N	Analysis is not UKAS accredited
C	Calculation