



CERTIFICATE of ANALYSIS

Wyke Farms Ltd waste water - V Notch Water

Report No.

149390

White house farm
Wyke champflower
Bruton
Somerset
BA10 0PU

Wessex reference: 27000785/WA-746383

Sampler's comments:

Sample taken: 05/10/2022 07:00

Analysts' comments:

Sample received: 05/10/2022 13:10

Sample notes / Cust ID: Wyke Farms LTD V-Notch water

Sampler: Sampled by customer

Sample matrix: Waste water

Analysis	Result	Unit	Method No.
Ammoniacal nitrogen	0.486	mg/L N	2550
Orthophosphate	1.46	mg/L P	2550
pH	8.0		2701
Biochemical oxygen demand, atu	<6	mg/L O2	2702
COD	<50	mg/L O2	2703
Suspended solids	5	mg/L	2704
Aluminium	1.1	mg/L	2972
Calcium	107.9	mg/L	2972
Iron	0.4	mg/L	2972
Potassium	356.5	mg/L	2972
Magnesium	12.9	mg/L	2972
Manganese	<0.05	mg/L	2972
Sodium	1889.6	mg/L	2972
Calcium hardness	270	mg CaCO3/L	2972
Magnesium hardness	53.1	mg CaCO3/L	2972
Total hardness	323	mg CaCO3/L	2972

The above analysis, unless otherwise indicated, has been carried out in UKAS accredited laboratory No. 0905

- Ñ indicates that the result is not UKAS accredited
Ø indicates "not detected in volume tested"
~ indicates that the result is estimated

Signed:

M. Edgell, Senior Scientist

11 October 2022



0905

Details of analytical procedures, performance data, uncertainty of measurement and sample analysis date are available on request.
Where information has been provided by the customer this has been recorded as received but if inaccurate could affect the validity of the results.
The results are provided for the sample as received by the laboratory. Sampling not in accordance with the documented procedures may affect the validity of the results.

Not to be reproduced except in full without written approval of the laboratory