

## Northacre Renewable Energy Limited

# Northacre Facility

## R1 Technical Note

## 1 Introduction

Northacre Renewable Energy Limited (NRE) is developing a scheme for the Northacre Facility (the 'Facility') to incinerate incoming residual waste fuel. The Facility will be located at Stephenson Road, Westbury, Wiltshire.

The Facility will process approximately 243,000 tonnes per annum (at the design capacity of 30.9 tph with an NCV of 10.5MJ/kg with an assumed availability of 7,860 hours).

NRE is applying for planning permission and an Environmental Permit (EP) for the Facility. This technical note has been developed to demonstrate that the design of the Facility achieves the R1 criteria and can be classified as a recovery operation in accordance with the requirements of the Waste Framework Directive (WFD).

## 2 Background

### 2.1 Waste Framework Directive

In accordance with the WFD, incineration facilities which process non-hazardous residual waste can be regarded as "Recovery" operations if the energy efficiency of the plant is greater than 0.65 (for plants permitted after January 2009). This is referred to as achieving "R1 status". In the UK, R1 status can only be formally granted by the relevant Competent Authority (for the Facility this will be the Environment Agency) when the facility has been in operation for more than 12 months. Plants which do not meet the energy efficiency criterion are classed as "Disposal" operations and therefore are considered as being equivalent to landfill in terms of the waste hierarchy.

The European Commission has published guidance titled '*Guidelines on the Interpretation of the R1 Energy Efficiency Formulae for Incineration Facilities Dedicated to the Processing of Municipal Solid Waste According to Annex II of Directive 2008/98/EC on Waste*'. Within the European Commission guidance the formula to calculate the efficiency of a facility is explained as follows:

$$\text{Energy Efficiency} = \frac{(E_p - (E_f + E_i))}{(0.97 \times (E_w + E_f))}$$

where:

- $E_p$  means annual energy produced as heat or electricity. It is calculated with energy in the form of electricity being multiplied by 2.6 and heat produced for commercial use multiplied by 1.1 (units of GJ/yr)
- $E_f$  means annual energy input to the system from fuels contributing to the production of steam (units of GJ/yr)

- $E_w$  means annual energy contained in the treated waste calculated using the lower calorific value of the waste (units of GJ/yr)
- $E_i$  means annual energy imported excluding  $E_w$  and  $E_f$  (units of GJ/yr)
- 0.97 is a factor accounting for energy losses due to bottom ash and radiation.

## 2.2 R1 Approval

As the Competent Authority for granting R1 status in England, the Environment Agency (EA) has developed a three stage approval system:

1. Design stage approval;
2. Commissioning approval; and
3. Operational approval, referred to as 'Full R1 approval'.

To achieve any level of 'R1 approval', the Operator is required to submit an R1 application to the EA which demonstrates that the Facility has achieved the minimum R1 value of 0.65. The R1 application is subsequently audited by the EA to determine whether the Facility has achieved the R1 status and written confirmation of achieving the relevant approval is granted by the EA. The EA has developed an R1 application spreadsheet to assist Operators with the development for applications for R1 approval.

'Design Stage approval' is granted prior to commissioning of a Facility, and can demonstrate that the proposed design will achieve the R1 criteria if the plant is designed, commissioned and operated as the criteria assumed within the R1 application.

'Commissioning Stage approval' uses data collected during the commissioning process to demonstrate that the 'as built' Facility achieved the R1 criteria during the commissioning period.

A Facility can only be classified as having 'full' R1 approval when operational data for a period of 1 year, or more, shows that the Facility has achieved the relevant efficiency requirements of the R1 criteria. Having obtained Full R1 approval from the operational data, records are required to be submitted to the EA, on an annual basis, to demonstrate that the Facility has continued to operate at the same level of efficiency. If the operational data shows that the Facility is not achieving R1 status at the end of the year, the Operator can ask for more time to take action to fix the problem. However, R1 status will be withdrawn by the EA if the Facility cannot meet the minimum requirements the following year.

## 3 R1 Application

An 'R1 Application' for Design Stage approval has been developed and is intended to be submitted to the EA in support of the EP application for the Facility. The R1 application is based on the relevant design parameters for the Facility as will be presented within the planning and EP applications; waste processing capacity; and electricity consumption. The design parameters and completed R1 application form are presented in Appendix A.

As shown in the R1 application, the R1 efficiency of the Facility has been calculated as **0.90**.

## 4 Conclusions

The Facility has been assessed in accordance with the EA's R1 application process. As demonstrated within this Technical Note, the R1 efficiency of the Facility has been calculated as 0.90. Therefore, this technical note demonstrates that the design of the Facility will achieve the R1 status and would be classified as a recovery operation under the terms of the WFD.

Furthermore, NRE will be submitting the application presented with this Technical Note to the EA for Design Stage R1 approval in support of the EP application for the Facility.

Yours sincerely

FICHTNER Consulting Engineers Limited




**James Sturman**  
Lead Environmental Consultant



**Nigel Garrod**  
Principal Consultant

# A R1 Application

	A	B	C	D	E	F	G	H	I
1	<b>PROFORMA FOR DETERMINING ENERGY EFFICIENCY USING R1</b>								
2	<b>Site name, address and grid reference</b>	Northacre Energy Recovery Facility	<b>EPR Permit reference (if known)</b>						
3	<b>Operator name</b>	Northacre Renewable Energy	<b>Application fee (£)</b>	2000					
4	<b>Details of who to contact if we have any queries regarding this form</b>	James Sturman jamessturman@fichtner.co.uk 07889 364179							
5	<b>What data has been used in the application? →</b>		Design data						
6	Indicative R1 factor (subject to confirmation)	0.90	Quantity in reporting year	Units	U <sub>c</sub>	Properties (Average over reporting year)	Units	Note which parameters that have been estimated	Reference to Supporting information
7	Climate change correction factor (optional)								
8	R1 after CCF adjustment								
9	1. Gross electricity meter (Electricity produced at turbine)		225304.96	MWh					See Application Support
10	2. Electricity exported - Net input/output meter		201901.36	MWh					See Application Support
11	3. Electricity imported - Net input/output meter		190.08	MWh					See Application Support
12	4. Other fuel inputs								
13		4.1 Light fuel oil	309,850	litres		0.85	kg/l		
14						42860	kJ/kg		See Application Supporting Information
15		4.2 Natural gas		Nm <sup>3</sup>		34200	kJ/Nm <sup>3</sup>		
16									
17		4.3 LPG		Nm <sup>3</sup>			kg/Nm <sup>3</sup>		
18							kJ/kg		
19		4.4 Other fuels similar to light fuel oil		litres			kg/l		
20							kJ/kg		
21	5. Primary combustion air (as supplied to furnace)		759950431	m <sup>3</sup>		1.287283698	kg/Nm <sup>3</sup>		
22						120	°C		See Application Supporting Information
23						95.95	kJ/kg		
24	6. Secondary combustion air (as supplied to furnace)		236836631	m <sup>3</sup>		1.287283698	kg/Nm <sup>3</sup>		
25						120	°C		See Application Supporting Information
26						95.95	kJ/kg		
27	7. Recycled flue gas (as supplied to furnace)			m <sup>3</sup>			kg/Nm <sup>3</sup>		
28							°C		
29							0	kJ/kg	
30	8. Heat exported outside R1 boundary								
31		8.1 steam exported		tonnes			°C		
32							kPa		
33							kJ/kg		
34		condensate returned		tonnes			°C		
35							kPa		
36							kJ/kg		
37		8.2 hot water exported		tonnes			°C		
38							kPa		
39							kJ/kg		
40		hot water returned		tonnes			°C		
41							kPa		
42							kJ/kg		
43									
44	9. Internal steam use								
45		9.1 for soot blowing (no backflow)		tonnes			°C		
46							kPa		
47							kJ/kg		
48		9.2 for steam driven devices		tonnes			°C		
49							kPa		
50							kJ/kg		
51		backflow as steam		tonnes			°C		
52							kPa		
53							kJ/kg		
54		9.3 for trace heating		tonnes			°C		
55							kPa		
56							kJ/kg		
57		backflow as condensate		tonnes			°C		
58							kPa		
59							kJ/kg		
60		9.4 for re-heating flue gas		tonnes			°C		
61							kPa		
62							kJ/kg		
63		backflow as condensate		tonnes			°C		
64							kPa		
65							kJ/kg		
66		9.5 for concentration processes		tonnes			°C		
67							kPa		
68							kJ/kg		
69		backflow as condensate		tonnes			°C		
70							kPa		
71							kJ/kg		
72		9.6 for building, equipment, tank heating		tonnes			°C		
73							kPa		
74							kJ/kg		
75		backflow as condensate		tonnes			°C		
76							kPa		
77							kJ/kg		
78		9.7 for deaeration and demineralisation		tonnes			°C		
79							kPa		
80							kJ/kg		



Northacre Renewable Energy  
**Northacre Facility**  
R1 Application Supporting Information

## 1 Design Data

The following data on the Northacre Facility (the Facility) has been assumed for the purposes of the R1 application.

Description	Value	Units
Lines	1	line
Operational hours	7880	hours/year
Non-operational Hours	880	hours/year
Waste consumption (nominal design capacity)	30,863	kg/hour
Waste LHV	10,500	kJ/kg
Gross power generation	28.6	MW <sub>e</sub>
Parasitic load	2.97	MW <sub>e</sub>
Auxiliary fuel consumed annual	263,373	Kg/y
Auxiliary fuel LHV	42,860	kJ/kg
Auxiliary fuel density	0.850	kg/l
Start up electricity	47.52	MWh
Number of start ups per year	4	
Start up time	16	hrs
Annual time for start ups	64	hrs/y
Primary air flow	96,440	Nm <sup>3</sup> /hr
Primary air temperature	120	°C
Primary air density	1.29	kg/m <sup>3</sup>
Primary air enthalpy	95.95	kJ/kg
Secondary air flow	30,055	Nm <sup>3</sup> /hr
Secondary air temperature	120	°C
Secondary air density	1.29	kg/m <sup>3</sup>

Description	Value	Units
Secondary air enthalpy	95.95	kJ/kg
Main steam produced by boiler at 100% MCR	113.90	tonnes/hour
Main steam temperature	430	°C
Main steam enthalpy	3,228	kJ/kg
Boiler feedwater flowrate	115.06	tonnes/hour
Boiler feedwater enthalpy	602	kJ/kg
Boiler design efficiency	93.58	%

## 2 Assumptions

The following assumptions on the design and performance of the Facility have been used for the purposes of this R1 application. These assumptions are based on the available design assumptions. Where applicable, conservative assumptions on operational parameters based on our experience of similar facilities have been made.

- The availability of the Facility will be 7,880 hours/year.
- The auxiliary fuel will be low sulphur fuel oil. No other auxiliary fuels will be combusted in the Facility.
- The parasitic load will be 2.97 MW.
- There will be 4 start ups / shutdowns per year.
- Despite aspirations from the applicant, there is assumed to be no heat export from the Facility since no formal heat supply agreements are currently in place with heat users. Therefore, the Facility is assumed to be operating in fully condensing mode. This approach represents a conservative position with regards to energy efficiency, which will improve when heat export is realised.
- There will be no internal heat use within the Facility.

## 3 Calculations

### 3.1 Gross Electricity

The gross electrical generation of the Facility has been calculated as follows:

$$\begin{aligned}
 \text{Total gross electrical generation} &= \text{Gross power generation (MW}_e\text{)} \times \text{Annual operating hours} \\
 &= 28.6 \text{ (MW}_e\text{)} \times 7,880 \text{ (hours)} \\
 &= 225,368 \text{ MWh}
 \end{aligned}$$

### 3.2 Electricity Exported

The electricity exported from the ERF was calculated as follows:

$$\text{Electricity exported} = (\text{Gross power generation} - \text{Parasitic power}) \text{ (MW}_e\text{)} \times \text{Operating time (hours)}$$



$$= (28.592 \text{ (MW}_e) - 2.97 \text{ (MW}_e)) \times 7,880 \text{ (hours)}$$

$$= 201,901 \text{ MWh}$$

### 3.3 Electricity Imported

The only electricity imported to the site should be during start-ups before the plant is able to export power. The electricity imported into the ERF has been calculated as follows:

$$\begin{aligned} \text{Total electricity import} &= \text{Hours spent during start up} \times \text{Parasitic load during start-up} \\ &= 64 \text{ hours of start-ups} \times 2.97 \text{ MW} \\ &= 190.08 \text{ MWh} \end{aligned}$$

### 3.4 Fuel Oil

Fuel oil is consumed by all burners during start-ups and discontinuously by the top burner during nominal operation to prevent the temperature falling below 850°C. For the purpose of this calculation, the discontinuous operation is ignored. The fuel oil consumed on the ERF has been calculated as follows.

Fuel oil consumed during start-ups and shutdowns = 263,373 kg/y

$$\begin{aligned} \text{Total fuel oil consumed} &= \text{Total fuel oil consumed} \div \text{Fuel oil density} \\ &= (263,373 \text{ kg/y}) \div 0.85 \text{ kg/L} \\ &= 309,850 \text{ litres/y} \end{aligned}$$

### 3.5 Primary Combustion Air (Heated)

The annual heated primary combustion air flow was calculated as follows:

$$\begin{aligned} \text{Primary combustion air} &= \text{Primary combustion air (Nm}^3\text{/hour)} \times \text{Operating time (hours)} \\ &= 96,440 \text{ (Nm}^3\text{/hour)} \times 7,880 \text{ (hours)} \\ &= 759,950,431 \text{ Nm}^3 \end{aligned}$$

### 3.6 Secondary Combustion Air (Heated)

The annual heated secondary combustion air flow was calculated as follows:

$$\begin{aligned} \text{Secondary combustion air} &= \text{Secondary combustion air (Nm}^3\text{/hour)} \times \text{Operating time (hours)} \\ &= 30,055 \text{ (Nm}^3\text{/hour)} \times 7,880 \text{ (hours)} \\ &= 236,836,631 \text{ Nm}^3 \end{aligned}$$

### 3.7 Heat export outside R1 boundary

No steam is currently exported from the ERF.

### 3.8 Superheated Steam at Boiler Outlet

The annual superheated steam at the boiler outlet for the ERF was calculated as follows:

Superheated steam from boilers = Main steam flow rate (tonnes/hour) x Operating time (hours)  
 = 113.9 (tonnes/hour) x 7,880 (hours)  
 = 897,563 tonnes


### 3.9 Boiler Feedwater

The annual boiler feedwater used by the ERF was calculated as follows:

Boiler feedwater = Boiler feedwater flow rate (kg/hour) x Operating time (hours)  
 = 115.06 (tonnes/hour) x 7,800 (hours)  
 = 906,641 tonnes

## 4 Sankey Diagram

An indicative Sankey Diagram for the Northacre ERF (exporting power only) is presented below.



Based on the nominal design capacity - No Heat Export

Figure 4 – ERF Indicative Sankey Diagram