



**LEGEND**

- SURFACE WATER CHAMBERS AND DRAINS
- COMBINED WATER CHAMBERS AND SEWERS
- GULLY COLLECTING SURFACE WATER
- GULLY COLLECTING COMBINED WATER
- PERMIT APPLICATION BOUNDARY
- - - ABANDONED PIPEWORK
- - - RISING MAIN

D14219 – IED Permitting Investigations – All STCs

Trowbridge BC drainage

Scale: 1:500

Originator: GA  
 Checker: JBC

Date: 06/10/2022

Revision: 3



All liquors returning to Inlet channel downstream the certified flow measurement

Abandoned 750mm diameter surface water Storm Drain

Overflow from disused sludge lagoons

Abandoned surface water Storm drain sealed (confirmed with the CCTV survey) – no flow passes towards the southeast side of the site.

Primary Sludge PS overflow

HST Desludge chamber with emergency overflow to a gravity sewer draining to Trowbridge Terminal PS

Sewers drain to Trowbridge Terminal PS prior to being pumped back to the Trowbridge STW