

End User License Agreement
PLEASE READ THIS AGREEMENT CAREFULLY.

THIS END USER LICENSE AGREEMENT ("AGREEMENT") IS BETWEEN HFL RISK SERVICES LIMITED (THE "COMPANY") AND THE PERSON WHO OPENS THIS PACKAGE OR USES THE SOFTWARE WHICH ACCOMPANIES THIS AGREEMENT (THE "USER"). THIS AGREEMENT GIVES A USER THE RIGHT TO ACCESS AND USE THE COMPANY'S PRODUCTS AND SERVICES ("PRODUCTS") PURCHASED FROM THE COMPANY, ITS RESELLERS OR AGENTS PURSUANT TO A PURCHASE AGREEMENT, CONTRACT, SALES ORDER, INVOICE OR SIMILAR DOCUMENT ("PURCHASE CONTRACT"). THE COMPANY IS WILLING TO GRANT A USER THE RIGHT TO ACCESS AND USE THE COMPANY'S PRODUCTS ONLY IF THE USER ACCEPTS ALL OF THE TERMS OF THIS AGREEMENT, AND PAYS OR HAS PAID THE COMPANY, ITS RESELLERS OR AGENTS, THE FULL PURCHASE PRICE (TO INCLUDE ALL APPLICABLE TAXES AND FEES) FOR USE OF THE LICENSE TO THE PRODUCTS PURCHASED.

THE USER ACKNOWLEDGES THAT USER HAS READ THIS AGREEMENT, UNDERSTANDS IT, AND AGREES TO BE BOUND BY IT. IF THE USER DOES NOT AGREE TO ALL OF THE TERMS IN THIS AGREEMENT, THE USER SHOULD NOT ACCESS OR OTHERWISE UTILIZE THE PRODUCTS BECAUSE NO LICENSE SHALL HAVE BEEN GRANTED THERETO.

1. LICENSE.

In consideration of the payment of the purchase price for the right to use Company's Products, and the User's adherence to all provisions of this Agreement, the Company grants the User a personal, non-exclusive, non-transferable license to access and use the Company's Products covered hereunder for the sole purpose of accessing and/or completing the associated training purchased under the Purchase Contract.

2. RESTRICTIONS.

User may not use, copy, modify, or transfer the Products to others, in whole or in part, except as expressly provided in this Agreement. The Products contains trade secrets of the Company, and the User may not reverse engineer, disassemble, decompile, or translate the Products, or otherwise attempt to derive its source code or the source code through which the Products is accessed, or authorize any third-party to do any of the foregoing. The license granted hereunder is personal to the User, and any attempt by the User to transfer any of the rights, duties or obligations hereunder shall terminate this Agreement and be void. The User may not rent, lease, loan, resell, or distribute the Products or any part thereof in any way including, but not limited to, making the Products available to others via shared access to a single computer, a computer network, or by sharing access information, which includes the User's Username and Password.

3. OWNERSHIP.

The Company's Products are the property of the Company and its licensor(s), if any, and subject to applicable patent, copyright, trade secrets, trademarks and other proprietary rights. The Products are licensed, not sold, to the User for use only under the terms of this Agreement, and the Company reserves all rights not expressly granted to the User.

4. INTELLECTUAL PROPERTY RIGHTS

The Customer will keep the Company indemnified in full against all liability, loss, damage, injury, claim, action, demand, expense or proceeding in respect of any infringement or alleged infringement of any IPR resulting from any use by the Company of the Customers Property or any compliance by the Company with the Customer's instructions, whether express or implied.

The IPR in all works owned by the Company prior to the date of the Contract ("Existing IPR") will remain vested in the Company. The IPR in all Works provided by the Company pursuant to this Contract will also remain vested in the Company.

Provided that the Customer is not in default of any payment obligation arising under the Contract, the Company grants to the Customer a non-exclusive, royalty free licence to make use of such IPR for the purposes envisaged in the Contract.

Where the Works are not manufactured or performed by the Company the Company gives no assurance or guarantee that the use or sale of the Works will not infringe any third party intellectual property rights.

5. TERMINATION.

This Agreement will terminate immediately if the User breaches any term of this Agreement. Further, in the event of a termination or expiration of any agreement between the Company and a third-party content provider or licensor of all or a part of the Products, the User's right to access and use the Products may also terminate or expire without prior notice to User. A User may terminate this Agreement at any time by notifying the Company in writing. Upon receipt of notice of termination from the User, the license and the User's access to the Products shall cease. Upon termination, any refund to which the User may be entitled shall be determined in accordance with the terms of the applicable Purchase Contract.

6. CONTENT MAINTAINED BY THE COMPANY.

User acknowledges and understands that: (a) the Company may, from time to time, elect to update the Products, but the Company does not warrant or guarantee that any Products or other information accessed through the Company's website(s) will be updated at any time during the term of this Agreement; and (b) the Company does not recommend, warrant or guarantee the use or performance of any third-party product or service described in the Products or elsewhere in the Company's website(s), nor is the Company responsible for malfunction of such products or services due to errors in the Products, the User's negligence or otherwise. User agrees to seek additional information on any third-party product or service from the respective third party. The User covenants that it will use the Products only as a reference and study aid, and acknowledge that the Products are not intended to be used as a substitute for the exercise of professional judgement.

8. WARRANTY DISCLAIMER.

EXCEPT AS EXPRESSLY PROVIDED HEREIN, THE COMPANY'S PRODUCTS ARE PROVIDED "AS IS" AND THE COMPANY MAKES NO REPRESENTATIONS OR WARRANTIES. THE COMPANY EXPRESSLY DISCLAIMS ALL WARRANTIES, EXPRESS OR IMPLIED, OF ANY KIND, FOR THE PRODUCTS AND ANY OTHER MATERIAL PROVIDED TO USER BY THE COMPANY, INCLUDING, WITHOUT LIMITATION, THE IMPLIED WARRANTIES OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE, AND NON-INFRINGEMENT OF THIRD PARTY RIGHTS. THE COMPANY DOES NOT WARRANT THAT THE PRODUCTS ARE ERROR-FREE, THAT THEIR OPERATION WILL BE UNINTERRUPTED, OR THAT PRODUCTS WILL MEET ANY PARTICULAR USER REQUIREMENTS. WITHOUT LIMITING THE GENERALITY OF THE FOREGOING, THE COMPANY MAKES NO WARRANTY, AND PROVIDES NO ASSURANCE, THAT THE PRODUCTS WILL MEET CERTIFICATION REQUIREMENTS OF ANY REGULATORY AUTHORITY OR OTHER ASSOCIATION LICENSING AGENCY, WITHIN OR OUTSIDE OF THE UK.

9. LIMITATION OF LIABILITY.

Except as specifically provided herein, neither the Company, its affiliates, resellers, agents, or licensors, if any, shall be liable for any claim, demand or action arising out of, or relating to, the User's use of the Products or the Company's performance of (or failure to perform) any obligation under this Agreement or for special, incidental or consequential damages, including, without limitation, damages due to lost revenues or profits, business interruption, or other damages caused by User's inability to use the Products, even if the Company, its affiliates, resellers, agents, or licensors have been advised of the possibility of such loss or damages, and whether or not such loss or damages is or are foreseeable.

10. EXPORT LAW.

The Company's Products are subject to U.K. export control laws and may be subject to export or import regulations in other countries. Unless in compliance with applicable law and specifically authorized in writing by the Company prior to any Product access, the User shall not export the Products under any circumstances whatsoever. In any case, the User will indemnify and hold the Company harmless from any and all claims, losses, liabilities, damages, fines, penalties, costs and expenses (including reasonable legal fees) arising from, or relating to, any breach by the User of the User's obligations under this section.

11. GOVERNING LAW, JURISDICTION AND VENUE.

This Agreement shall for all purposes be governed by English law and the parties submit to the exclusive jurisdiction of the English courts.

12. LEGAL FEES.

If any legal action or proceeding is brought for the enforcement of this Agreement or arises from the alleged breach, dispute, default or misrepresentation in connection with any of the provisions of this Agreement, the prevailing party or parties shall be entitled to recover reasonable legal fees and other costs incurred as a result of such legal action or proceeding.

13. WAIVER.

No failure to enforce any term of this Agreement shall constitute a waiver of such term in the future unless such waiver so provides by its terms.

14. ASSIGNMENT.

Neither this Agreement nor any of the User's rights or obligations hereunder may be assigned by the User in whole or in part without the prior written approval of the Company. Any other attempted assignment shall be null and void.

15. SEVERABILITY.

If any part of this Agreement is for any reason found to be invalid, illegal or unenforceable, the validity, legality and enforceability of the remaining provisions of this Agreement shall not be affected and same shall remain in effect.

16. COMPLETE AGREEMENT.

This Agreement is the complete and exclusive statement of the agreement between the Company and the User with respect to its subject matter, and supersedes and voids any proposal or prior agreement, oral or written, and any other communications between the parties in relation to its subject matter. No waiver, alteration or modification of this Agreement shall be valid unless made in writing and signed by a corporate officer of the Company.

HAZARD IDENTIFICATION ANALYSIS

Hazard System: CA

System Title: New Anodise Line (CTF)

Original Assessment Date: 03/02/2022 & 14/02/2022

Revision Date:
Revision: 0

Brief System Description: On the New Anodise Line, Aluminum & Titanium Components are processed. The line consists of 28 stages. Components are loaded onto the flight bar (three transporters) then automatically transferred to the relevant tanks based on a recipe.

References: DP001023-00-000A: New Anodise P&ID Examine from New PFD Line
ME: 13-143-040 LPWH system example
13-143-022C - Blowdowns
13-143-012B - Blowdowns
13-143-022B - Drawing
KOCN Anodisation Line Outline Design Review (13/01/2022)

The following information is provided below the HAZID:

Block Flow of the Line - Showing an idealised process as an overview
Process Sheet - Showing the typical processes that may be selected
Tank Chart - Showing the chemicals in each tank
Tank Summary Table - Showing the equipment and processes relating to each tank
Chemical details / Incompatibilities
Sketch of study tank

All tanks bonded to >110V or 25% of the total tanks contents with acid / alkali segregation (can mix if very large volume). Level alarms on bund sumps which initiate evacuation and relayed to the gishouse. All chemical tanks have an overflow into bund (some tanks have a vent to clean).
LEV is fitted to all chemical tanks, that passes off gases into a packed column water scrubber with release to atmosphere. When the transporter is over an open tank, a basic seal is formed between the transporter and the tank. LEV is fitted to the transporter which vents directly to atmosphere outside the building at height. Dragger system detects HF & Nitric acid vapour releases along the front and back of the line.

HAZID is selected as a suitable risk assessment process as it is the site standard and considered proportionate to the complexity of the relatively simple process. The HAZID is focused on scenarios where significant harm to people or the environment may occur due to process safety risks (COMAH hazards). It is not intended to be an exhaustive list of all risks (e.g. personal safety, quality). Where these were discussed, they were recorded by the project team for discussion elsewhere.

HAZID Process:

The tanks are designed to be very similar, using a modular approach. The process in each tank is specified and the technical requirements are identified (e.g. heating, cooling, filtration, aeration). See 'Tank Summary Table'. On this basis, it was agreed that a 'representative worst case' tank would be assessed in detail and then any significant variations considered. This is possible as the modular parts of each tank are built to the same standard, based on the Tank Summary Table, Tank 9 was chosen as the basis for the assessment. A similar approach was adopted for the New PFD Line HAZID. The representative tank has:

16m3 tank constructed from stainless steel, PP or PVDF as appropriate to the chemicals
Close fitting lid which are PLC controlled
Lip extract on both long sides to a caustic scrubber
Heating coil using Low Pressure Hot Water (80°C)
Cooling coil from chiller unit
Air agitation fed from common main
Filtration pump and filter with extractor on end of return line to provide mixing
Bulk fill by Veeva bringing BCS, pump and hoses to the line Pump from BCS to tank via Blister. Rise through pipes with water when complete
Bulk Drain by Veeva bringing vac tanker and hoses. Hose dropped into tank via blister (tank internal floor designed to fall towards blister side) and connected to water line. Vacuum tanker removes contents.
When tank is drained and rinsed, waste line is flushed its full length.
Automatic Demin water top up from common main
Manual Demin water top up from common main
No penetrations in the chemical tanks below liquid surface (with the potential exception of station 23)
Overflow to bund
Air agitated self-stainer for dosing
Vent line from self-stainer into head space of tank
Dosing pump draws liquid from self-stainer and transfers to tank where it enters via an open ended pipe above the liquid level.
Rustle level detection which turns on DI for automatic stop-up and turns it off again at high level. This device also alarms on HI or LI, and stops additions and heating / cooling.
High level Sensor which alarms on HI and isolates auto demin, demin main supply, LPWH (and steam on tank 23)
Two temperature sensors for control of the process
Additional temperature sensor for HIH temperature which alarms on HIH and isolates LPWH (and steam on tank 23)
Assume Chemical is Hydrofluoric Acid in worst case

Notes: Where a line is 'greyed out', this indicates that there are no significant safety / environmental hazards identified or the hazard is considered elsewhere in the HAZID.

Attendees:
T Stabileford (Mice)
S Coombes (Production)
M Chantrey (Facilities)
A Parsonage (SHE)
L Hollis (SHE)
J Willis (Koch)
S Cartmel (Koch)
P Henry (HAZID Leader -
Portman Risk Ltd)

SYSTEM: New Anodise Line (CTF)																			
Hazard	Event	Cause and Initiating Event	Hazard Scenario	Harm or Consequence	Raw Risk			Prevention, Control & Mitigation Safeguards					Residual Risk			Recordings			
					P	S	E	Prevention Safeguards (Physical, Control, Reliability, Redundancy)	Control Safeguards (Procedural, Control, Reliability, Redundancy)	Physical Protection Safeguards (Physical, Control, Reliability, Redundancy)	People & Procedures (PPE, PPE, Emergency Response)	A	L	S	Actions, Comments, and What Next can be done?	0	3		
Tanks	CA 1	Overpressure	Mechanical failure	Blockage of relief valve on Blower air for air sparge.	Increased flow to tanks which increases the effective volume of the tank contents. Potential for splashing and injury of operator from tank contents (acids)	P	2	6	None identified	1. Design gas detectors may pick up higher levels of vapour 2. High level detection may be triggered by rise in level and alarm status (automatic isolations will not remove the hazard)	1. Pressure relief on blower line 2. Spill guards and physical barriers around tanks on front of line. Distance guarding on rear. 3. Lids on all chemical tanks may limit splashing 4. Gaps in side checks etc will be as small as practical 5. LEV for removal of additional fumes	1. Maintenance have procedures for generating process risk assessments for access beyond guards and limiting air if this is the issue 2. PPE for maintenance and operators when potential for splashing is possible 3. Chemical & Emergency awareness training 4. Trained operators 5. Spill kits available	1	4	M	1. Blower relief valve to be on PPM 2. Consider the benefits of alternative methods of controlling pressure to minimise wasted air (energy) (e.g. pressure sensor and VSD). Relief valve is likely to still be needed as ultimate protection.	0	3	
	CA 2	Overpressure	Human error	Valves closed in Blower air line	Low air pressure reduces agitation in the tanks. Quality issue - no significant safety hazard. Back pressure on blowers - blower damage Note: If air agitators are isolated on other tanks, this will increase the air vented via the relief valve rather than significantly increasing the air pressure of other tanks.	P	0	8	Pipework suitable for maximum air pressure	None identified	1. Pressure relief on blower line 2. Overload on electrical supply to motor	None identified	0	6	L	1. Confirm blowers have over temperature protection. 2. Blower relief valve to be on PPM	0	0	
	CA 3	Overpressure	Mechanical failure	Blockage in Blower air line due to chemical build-up, corrosion, foreign objects etc leading to failure of the pipe within the tank due to overpressure.	Leads to block air into the tank in a similar way to blockage of the relief valve	P	2	6	1. Maximum pressure of blower is below the maximum pressure rating of the pipework	None identified	1. Pressure relief on blower line	None identified	2	3	L	1. Consider if it is practical to arrange the holes in the sparge pipes at 45 degrees facing down to avoid chemical build-up	0	0	
	CA 4	Overpressure	Human error	Maintenance error with fan vent up backwards sucking liquid up the air line from tank.	Expect reduced performance of fan rather vacuum - no significant safety hazard	P												0	0
	CA 5	Overpressure	Mechanical failure	Filter unit return pipe in bottom of tank and has an isolator to mix tank contents - risk of failure due to corrosion impact, etc.	Quality issue - no significant safety hazard	P													0
CA 6	Overpressure	Mechanical failure	Filter unit return line goes bottom of tank and has an isolator to mix tank contents - blocked. OR Hand valve shut after pump.	Filter system pressure increases. Pipe splits or filter is set passives. Corrosion sprayed onto nearby personnel	P	2	6	1. Maximum pump pressure is below the maximum pressure rating of the pipework and fittings.	None identified	1. Pipework containing corrosives is double skinned	None identified	2	4	M	1. For each chemical filtration system, consider screening around safety critical tank parts so operators chemicals to prevent splashing outside the bund and/or flame covers to prevent sprays.	0	0		
CA 8	Over Temperature	Mechanical failure	Chemical Tanks is heated from a hot water coil fitted to the tank. LPWH Unmanned operation Saturday	80°C hot water cannot boil tank No Significant Safety Hazards Identified	P				1. Independent High temperature alarms will close valve to heating coil. 2. Auto drain top up on tanks to replace any drop in level due to evaporation.	1. Tanks are fitted with lids & no extraction so fume emission is reduced					1. Check that low level shuts off hot water supply	0	0		
CA 9	Over Temperature	Mechanical failure	Tank 23 is heated from a steam coil fitted into the tank.	Failure of temperature control system leads to boiling of the tank and increased emission of toxic/corrosive fumes	P	2	8	Not applicable	1. Independent High temperature alarms will close valve to heating coil. 2. Auto drain top up on tanks to replace any drop in level due to evaporation. 3. Design gas detectors may pick up higher levels of vapour	1. Tanks are fitted with lids & no extraction so fume emission is reduced	Not applicable	2	5	M	1. Check that low level shuts off steam supply	0	0		
CA 10	Over Temperature	Corrosion / mechanical failure	Tank 23 is heated from a steam coil fitted into the tank.	Failure of the pipework allows the tank chemical to enter the steam pipework (during temperature control cycle negative pressure may occur, sucking liquid into the pipe). Chemical then damage the steam system. No Significant Safety Hazards Identified	P				1. Heating coils located to avoid contact with the flight bar / components 2. Pipework is of suitable material for solution						1. Tank inspections include condition of heating coils	1. Check that low level shuts off hot water supply	0	0	
CA 11	Over Temperature	Mechanical failure	Electric Dryer overheats	Waste of energy only No Significant Safety Hazards Identified	P												0	0	
CA 12	Overfilling	Human error	Overfilling of tanks due to incorrect manual charging of water	Loss of up to 18,000 litres of Toxic, OTE, Very Toxic or corrosive from Process tanks but being contained within the bund. May be release of toxic vapour. If above run out of bund may leave site and go to Blackdown WWTW and ultimately river	P	2	8	1. Chemical Tanks fitted with overflows direct to bund which are positioned below the level of extraction to bund potential for liquid to enter LEV and not over edges of tank in uncontrolled fashion	1. Independent high level monitoring alarm will close valve to heating coil 2. Auto drain top up on tanks to replace any drop in level due to evaporation 3. Design gas detectors may pick up higher levels of vapour	1. Bunds 2. Manual isolation valves 3. Postlock to isolate outlet to WTW 4. Trained operators 5. Spill procedures and kits	1. Minimum duration of manual intervention 2. Level instruments on PPM 3. Emergency procedures 4. Trained operators 5. Spill procedures and kits	2	4	M	1. Koch - Add ICV what is ICV ??? to post DI supply and close on HI on any tank	0	0		

CA ID	Category	Failure Mode	Consequence	Prevention	Detection	Response	Control	Severity	Impact	Frequency	Residual Risk	Notes
CA 13	Overflowing	Mechanical failure	Overflowing of tanks due to incorrect valve closure resulting in release of toxic vapour (e.g. released fire, radar fail, partial close)	Loss of up to 16,000 litres of Toxic, OTE, Very Toxic or corrosive from Process tanks but being contained within the bund. May be released to the atmosphere if bund run out of bund may leave site and go to Blackburn WWTW and ultimately river	1. Chemical Tanks fitted with overflow arrest to bund which are positioned below the level of the extraction to avoid potential for liquid to enter LEV	1. Independent high level monitoring & alarm on chemical tanks (local / HRA, audible and visual alarm and bund alarm at gate office) 2. High high level will shut down the water to the whole lot 3. Audible alarm led from Level monitoring in the bund and returned to Controlhouse 4. Gas detector gas detection and alarm 5. Trainers on valves (if no high level in pre-determined time, valve valve) 6. When valve opens, software checks valve is shut after a pre-determined time to reduce demand on HPL significant	1. Bund 2. Manual isolation valves available but significant delay to react to contact Error 3. Trained operators 4. Spill procedures and kits	2	4	M	1. Koch - Confirm alarm specified in Control System status are installed 2. Koch - Confirm that Bund Alarm and Dräger alarm shut off water to the line	
CA 14	Overflowing	Mechanical failure	Burst water main above the tanks sprays into chemical tank and overflows to bund	Loss of up to 16,000 litres of Toxic, OTE, Very Toxic or corrosive from Process tanks but being contained within the bund. May be released to the atmosphere if bund run out of bund may leave site and go to Blackburn WWTW and ultimately river	1. Water pipework routed down stairs to limit potential 2. Lids may prevent ingress 3. Trainers screening may prevent water away from tanks 4. No fire sprinklers etc in the building	1. High and independent high level monitoring & alarm on chemical tanks (local / HRA, audible and visual alarm) 2. Audible alarm led from Level monitoring in the bund. Bund alarm sends a signal to security and activates the evacuation alarm 3. Gas detector gas detectors	1. Bund 2. Manual isolation valves available but significant delay to react to contact Error 3. Trained operators 4. Spill procedures and kits	2	4	M	1. Survey liquid lines above the tanks and consider if it is practical to provide an isolation valves which are easily accessed without need to call Error	
CA 15	Overflowing	Mechanical failure	Burst hot water coil runs into tanks and overflows	Loss of up to 16,000 litres of Toxic, OTE, Very Toxic or corrosive from Process tanks but being contained within the bund. May be released to the atmosphere if bund run out of bund may leave site and go to Blackburn WWTW and ultimately river	1. Chemical Tanks fitted with overflow arrest to bund which are positioned below the level of the extraction to avoid potential for liquid to enter LEV	1. High and independent high level monitoring & alarm on chemical tanks (local / HRA, audible and visual alarm) 2. Audible alarm led from Level monitoring in the bund. Bund alarm sends a signal to security and activates the evacuation alarm 3. Gas detector gas detectors	1. Bund 2. Manual isolation valves available but significant delay to react to contact Error 3. Trained operators 4. Spill procedures and kits	2	4	M	1. Confirm if the HPL shuts off the water to the heating coil unit (P&ID)	
CA 16	Loss of Containment	Catastrophic failure	Line Tanks containing up to 16,000 litres of Toxic, OTE, Very Toxic or corrosive from Process tanks but being contained within the bund. May be released to the atmosphere if bund run out of bund may leave site and go to Blackburn WWTW and ultimately river	Line Tanks containing up to 16,000 litres of Toxic, OTE, Very Toxic or corrosive from Process tanks but being contained within the bund. May be released to the atmosphere if bund run out of bund may leave site and go to Blackburn WWTW and ultimately river	1. Materials of construction are compatible and certified minimum webs and certified 2. No penetrations in chemical tanks 3. Significant excess material thickness to compensate for corrosion	1. High level tank alarm trigger to gasdetector and evacuation alarm sounded Low level tank	1. Bund 2. Manual isolation valves available but significant delay to react to contact Error 3. Trained operators 4. Spill procedures and kits	3	3	M	1. Consider tank checks to go to go sheets for checks down outside of tank, dry bund 2. Confirm Level sensors on PPM	
CA 17	Loss of Containment	Major incident	Building collapse due to structural failure or major incident. Aircraft crash major act of terrorism	Catastrophic failure of mechanical integrity of tank structure loss of up to 16,000 litres of Toxic, OTE, Very Toxic or corrosive from Process tanks but being contained within the bund. May be released to the atmosphere if bund run out of bund may leave site and go to Blackburn WWTW and ultimately river	1. Steel tanks are made from 10mm steel (only needed to be 8mm) 2. Building bonded to low earthquake / flood area. Sealed area. Not a dual terrorism target	1. Secure site building security	1. Concrete floors 2. Pylowork to isolate outlet to WTTW 3. Emergency response plan	4	1	L	No further actions identified	
CA 18	Loss of Containment	Design	Catastrophic failure of mechanical integrity of tank structure causing spill of bund	Spillage onto existing concrete floor. Potential operator injury Chemical operator injury Chemical operator injury Chemical operator injury	1. Steel tanks are made from 10mm steel (only needed to be 8mm) 2. Bund alarm would evacuate people and notify gasdetector to respond 3. Gas detector in bund are likely to raise alarm	1. Bund alarm would evacuate people and notify gasdetector to respond 2. Bund would be expected to contain a significant proportion of the material 3. Concrete floors 4. Floors painted with chemical resistant coating	1. Spill procedures and kits 2. Trained operators 3. Plastic tanks designed and manufactured to BS EN 12573 BSEN 13067 4. Steel Tanks manufactured in line with BS EN 12573-2:2007/Eurocode 3 5. Tanks routinely checked for leaks and repaired as needed 6. Tanks have inspection schedule	2	3	L	No further actions identified	
CA 19	Loss of Containment	Design	Localized failure of mechanical integrity of tank structure causing spill (e.g. 0.5 hole)	Spillage onto existing concrete floor. Potential operator injury Chemical operator injury Chemical operator injury	1. Tanks are made from 10mm steel (only needed to be 8mm) 2. Bund alarm would evacuate people and notify gasdetector to respond 3. Gas detector in bund are likely to raise alarm	1. Bund alarm would evacuate people and notify gasdetector to respond 2. Bund would be expected to contain a significant proportion of the material 3. Concrete floors 4. Floors painted with chemical resistant coating	1. Spill procedures and kits 2. Trained operators 3. Plastic tanks designed and manufactured to BS EN 12573 BSEN 13067 4. Steel Tanks manufactured in line with BS EN 12573-2:2007/Eurocode 3 5. Tanks routinely checked for leaks and repaired as needed 6. Tanks have inspection schedule	2	4	L	No further actions identified	
CA 20	Abnormal Chemical Reaction	Design	Mixing of caustic and acid chemistry in a tank	Release toxic gas caused by reaction from incompatible chemicals	1. Safetainers have gas venting to prevent wrong sulfanifer connection 2. Changes may alert operator to the problem 3. HPL alarm may alert operator to a problem	1. Bund alarm will trigger if venting is reduced 2. Bund to contain any overflow	1. Tanks are fitted with lids & extraction so some emissions to be reduced 2. Bund to contain any overflow 3. SOP and trained people including 4-eye check of chemical 4. Incident investigation and subsequent tank inspection 5. Routine chemical analysis by MEST etc would be expected to identify any such gross error within a very short period (24 hrs)	3	5	M	1. Implement a clear procedure for the addition of chemicals to tanks from sulfanifer. This should minimize the risk of the incorrect chemical being added to a tank 2. Implement a clear procedure for the tank addition of chemicals to tanks from IBCs (Vials). This should minimize the risk of the incorrect chemical being added to a tank and should include a clear transfer of responsibility from BAE (e.g. PFTW) and include checks that the correct chemicals are used 3. Review the training / authorization arrangements for personnel involved in these transfers (Safety Critical Tasks) 4. Complete human factors review of the tank filling / sulfanifer changeover procedures to minimize the potential for mixing incompatible chemicals	
CA 21	Abnormal Chemical Reaction	Human error	Wrong type of metal used in incompatible tank causing a chemical reaction	The assessment team do not anticipate a violent or significant adverse chemical reaction - Quality affect only	1. Other materials that may react with the chemicals are not present in the building	1. Tanks are fitted with lids & extraction so some emissions to be reduced 2. Bund to contain any overflow	1. SOP and trained people including 4-eye check of chemical 2. Bund to contain any overflow 3. Incident investigation and subsequent tank inspection 4. Routine chemical analysis by MEST etc would be expected to identify any such gross error within a very short period (24 hrs)	2	4	M	1. MEST to confirm that placing any combination of metal component into any tank, that no significant adverse chemical reaction is expected to occur. If such a hazard is identified, the HAZOP will need to be updated accordingly	
CA 22	Loss of containment	Human error	Concentration of chemical too high	For the majority of chemicals this will only be a risk for the toxic materials, additional fumes may be generated (excess concentration). For corrosive materials, the integrity of the tank may be affected over an extended period of time.	1. Tank materials are compatible with the chemicals at expected concentrations. The presence of higher concentrations is expected to have no significant short term effect (check) 2. Higher concentrations are not used on site and so there would need to be a failure at the supplier (e.g. wrong material in container)	1. Change gas detectors may pick up higher levels of vapour	1. Tanks are fitted with lids & extraction so some emissions to be reduced 2. Bund to contain any overflow 3. SOP and trained people including 4-eye check of chemical 4. Incident investigation and subsequent tank inspection 5. Routine chemical analysis by MEST etc would be expected to identify any such gross error within a very short period (24 hrs)	2	4	M	1. Koch to confirm that tanks can take the expected concentration of acid chemical (i.e. no water added) - Initial Backlog is that >20% HCl Acid at 20°C is detrimental to P&ID used on stages T1 & T2 2. Koch to consider the effect of adding higher concentrations (e.g. due to wrong delivery) and to confirm that this would not be expected to lead to failure of the tanks in the short term (e.g. 24 hrs in which time it would be expected that OC testing would highlight the issue and corrective action would be taken to take to an acceptable level). Damage to the tank is considered acceptable in the scenario but a breach of containment would not be acceptable 3. Consider how to record this knowledge for future use, e.g. include it in the descriptive part of the training package (procedures) 4. Review the tank bulk filling procedure to ensure that water is always added before the chemical is added	
CA 23	Loss of containment	Instrument failure	Inconsistency fails or gives a false reading (e.g. level probe, temperature probe, pH probe)	Potential for overfill of tank, high temperature in tank, etc. These scenarios are already covered in the HAZOP.	1. PLCs will generally fail to operate if there is a problem. PLC has fail safe process.	1. Commissioning checks	1. Koch to confirm what diagnostic are available on the PLC to identify any issues with internal failure of the system (there are PLC start up checks but rarely restricted)				No further actions identified	
CA 24	Misc	Instrument failure	Control system (PLC) fails or becomes corrupt leading to unexpected actions	Potential for overfill of tank, high temperature in tank, wrong piping, tanks, wrong sequencing etc. These scenarios are already covered in the HAZOP.	1. PLCs will generally fail to operate if there is a problem. PLC has fail safe process.	1. Commissioning checks	1. Koch to confirm what diagnostic are available on the PLC to identify any issues with internal failure of the system (there are PLC start up checks but rarely restricted)				No further actions identified	
CA 25	Misc	Human error	Operator forgets to close valves	Parts are lowered into the tank which overfills into bund. Spill in the amount that overflow would be expected to cope with the top of the tank.	1. Tank dimensions limit the potential for overfill components 2. Possibility of a large volume component is considered very low as not present in the building	1. Transporter may recognize overfill of large volume components are added	1. Overflow is checked on being raised as part of the tank inspection process 2. Operators may quantify the presence of large volume components but also just assume the system is correct.	2	4	M	1. Koch to confirm the maximum volume Spill and then check this on the overflow 2. If an issue is identified with potential overflow related to component, consider if there is a way for some type of volume check as part of the sequence 3. Transporter operations to take if HPL detected in the tank that is in use	
CA 26	Misc	Design	Chemical carry over on components between tanks	Transfer of acid alkali into a tank which contains the opposite material. This is a well understood issue on the site. Quarantines are likely to be small due to the nature of the components being dipped. Typically less than 1 litre, suitable for safe to drain. Worst case = Maximum area = 5m ² with max of 1 litre per m ² = 5 litres	1. Quarantines are likely to be small due to the nature of the components being dipped. 2. Dip trays etc are chemical resistant	1. The processes involve rinsing tanks between dissimilar chemicals which is expected to reduce any carryover. 2. Plastic chipping prevent splashing etc 3. Transporter extraction (not scrubbed)	1. L1 extraction provided (80% over other component entire the solution) 2. Plastic chipping prevent splashing etc 3. Transporter extraction (not scrubbed)	2	5	L	No further actions identified	
CA 27	Misc	Other	Building fire elsewhere spreading to the line	Tanks containing chemicals which could boil dry & decompose due to the heat from the fire forming a toxic gas. Unable to cause an explosion as no combustible materials near by already consumed by fire. Hazard will be obvious due to large fire meaning any emergency personnel not expected to be	None identified	1. Building fire alarm that activates roof & wall vents & evacuates the building 2. Heat detectors 3. Heat detectors 4. On-site fire water drain to Pylowork on drains from site to Blackburn WWTW	1. Smoke detection 2. Heat detectors 3. Heat detectors 4. On-site fire water drain to Pylowork on drains from site to Blackburn WWTW	1. Emergency response times of 20mins for LFRS 2. A fire Call of hours patrols 3. Good housekeeping 4. On-site fire water drain to Pylowork on drains from site to Blackburn WWTW	2	4	L	No further actions identified

				prevented. Fire water run off may be contaminated with chemicals. Potential for multiple plastic tanks to fail in short period (7 tanks are plastic with a total vent capacity of 4.4 tanks)	E 4 6						7. FAT testing 8. Fire awareness training of staff 9. Fire fighting strategy will include large volumes of water directly on the line to minimise FPMO	4 4 3			
CA 36	Loss of containment	Human error	Two recuperation tanks overflowing at the same time	The scenario would require two simultaneous failures to occur (e.g. subsidence, PLC fail to danger on two separate tanks). Gases from the module would enter the building. CO2 plastic tank fails and corrodes SS tank next to it	P 4 5 E 4 5	9		1. PLC and instrumentation are designed to fail safe. 2. Independent high level alarms warn of overflow 3. Chemical alarm will initiate evacuation	1. Staggered loading will allow time to respond and for evacuation before material mks 2. Pinlock on site drains to prevent run off to the rivers.		4 3 M		No further actions identified		
CA 35	Misc	Other	OFM 4 hazards	In the first HAZID session, the properties of OFM 4 were unknown. Since the initial HAZID, it has been confirmed that OFM 4 is now known as Dextropne 1002 (made up from the concentrate OFM250). OFM250 is an alkaline liquid which means that it is similar to the other alkaline materials and may produce hazardous decomposition compounds. No significant additional hazard when compared to the other alkaline materials	P										
CA 30	Low Temperature	Mechanical failure	Low temperature leading to crystallisation	Loss of heating leading to tank cooling to ambient temperature - No Significant Safety Hazards identified	P										
CA 31	Loss of utilities	DI Water	Loss of utilities - DI Water	No DI water = low level in tanks or mis-priming of DI lines = Quality agent from potential for increased carryover to an incompatible tank etc. - See high concentration	P										
CA 32	Loss of utilities	Air agitators	Loss of utilities - Air agitators	Loss of agitator may lead to incomplete mixing within the tank. In extreme cases, potential for pockets of higher concentration material - See high concentration	P										
CA 33	Loss of utilities	LPHW / Steam	Loss of utilities - LPHW / Steam	Quality only No Significant Safety Hazards identified	P										
CA 34	Loss of utilities	Instrument / compressed air	Loss of utilities - Instrument / compressed air	Subder in tankholder would stop = quality only. Instrumentation giving false readings = No instrumentation failure Instrument could lead to overflow by DI water from tankholder, leading to potential overflow of tank - See Overfill Tank fill operation may be compromised if lids are opened by pneumatic cylinders - Instrument could lower level in selected tank - Mechanical damage to fill / transporter	P			1. Instrumentation, valves, etc designed to be fail to safe condition	1. Alarm on PLC HMI if air supply pressure is below target value 2. Sensors on tank lids confirm open closed and prevent transporter movement if not correct	1. Band 2. Overflow to bund				1. Koch - Consider processes of electric / air actuators on lids of tanks	
CA 35	Loss of utilities	Electricity	Loss of utilities - Electricity	Assume total blackout. System may have tanks open but LEV scrubber goes off with potential for toxic gases to enter the building. No significant loss in the environment anticipated.	P 4 8 E 1 8		1. Instrumentation, valves, etc designed to be fail to safe condition	1. LPS to protect any maintenance people in a tank / on transporter (move a few times) 2. LPS to protect PLC sequence to aid recovery 3. Scrubber failure (low flow alarm) and building evacuation alarm have LPS and will be triggered immediately	1. Emergency lighting 2. Bund	1. Emergency procedures	4 4 M		1. Koch - Consider processes of electric / air actuators on lids of tanks		
Anodise Process															
CA 36	High Temperature	Mechanical / electrical failure	Excess heat generated and not taken away	The excess heat will increase the temperature of the tank - See High temp scenario	P			1. Anodising current is monitored by PLC system 2. High temp sensor warns of anodising current if tank is high temperature	1. Tanks are fitted with lids & extraction so fume emission is reduced					1. Koch - Confirm high temp sensor runs off anodising current if tank is high temperature	
CA 37	Misc	Mechanical / electrical failure Human error	Anodising process adds less electrolytes and produces Hydrogen and Oxygen (normal and abnormal operation)	Anodising process adds the electrolytes and produces hydrogen and oxygen which reaches a concentration where ignition is possible. Explosion in head space of tank is unlikely as hydrogen rises but may lead to rupture of tank.	P 4 7 E 4 7		New identified	1. Anodising current is monitored by PLC system 2. Anodiser will not function when lids are open / transporter is active in the tank	1. Tanks are fitted with lids & extraction so fume emission is reduced 2. Transporter fitted with extraction for the short duration it is present above the tank 3. Buildings are very large and well ventilated which aid dispersion of any evolved gases	1. Maintenance of anodising system 2. Emergency procedures	4 4 M		1. Koch - Confirm that Hydrogen levels can not reach 25% LEL levels (normal and abnormal operation) if this is possible, revisit HAZID findings		
CA 38	Misc	Human Error	Current transferred to transporter / metal parts of tank	Equipment made live with potential for fatality. No harm to environment anticipated.	P 3 7 E 0 7		1. Anodiser specialist will design and install standard 2. Transporter support the load in two places to prevent 'swaying' of the load.	1. Any leakage current will trip system, e.g. if tank has hole liquid onto nearby metal is enough to trip transfer. 2. Transfer ramps up current to check no current leakage before applying full amps. 3. All metalwork is earthed 4. Anodiser will not function when lids are open / transporter is active in the tank (PLC control)	New identified	1. Emergency stop buttons on the terminals anodising current 2. Operators trained to test and secure beams to the flight bars	3 4 M		1. Koch - Confirm that Emergency stop buttons on the terminals anodising current 2. Koch - Are there any simple ways to prevent contact with the electrodes that do not compromise the quality of the process?		
Extraction System															
CA 39	Loss of Containment	Mechanical failure	Blocked tank lid extract points or scrubber failure (including power failure)	Gases into the building from ambient temp and some heated overhead, nitric, HF. Potential operator injury. No significant harm to environment anticipated.	P 3 7 E 1 7		1. Lid extract gases are large and unlikely to be clogged / blocked by buildup or corrosion	1. Scrubber not running alarm will alarm off if stopped (evacuation of the building) 2. Multiple pressure and flow sensors which also sound fire alarm. 3. Designers gas detectors	1. Roof & wall vents open on evacuation / fire alarm activation	1. Evacuation procedure 2. Local alarm activation 3. 24/7 security alarm repeat 4. Scheduled inspections of scrubber and lid extract 5. On-site emergency team attends within 10 minutes	3 4 M		1. Confirm that the scrubber flow alarm (or similar) has a test schedule to prove that it operates as intended. 2. Confirm scrubber flow alarm has FPMO and activate evacuation in the event of power failure		
CA 40	Loss of Containment	Mechanical failure	Beats on main scrubber (acting full allowing air in and reducing suction to tank)	Gases into the building from ambient temp and some heated overhead, nitric, HF. Potential operator injury. No significant harm to environment anticipated.	P 2 6 E 1 6		New identified	1. Design gas detection may alarm if significant vapours are produced	1. Roof & wall vents open on evacuation / fire alarm activation 2. Failure of seals will allow extraction rates but unlikely to lead to immediate failure before alarm sensors detect the failure	1. Evacuation procedure 2. Local alarm activation 3. 24/7 security alarm repeat 4. On-site emergency team attends within 10 minutes	2 4 M		1. Include external visual inspection of the vehicle of the extraction system as part of other inspections to help identify any potential leak points. (e.g. external damage, dips, discolouration)		
CA 41	Loss of Containment	Design	Mixing of acidic and alkaline vapours	Incompatible materials mixing to give other hazardous substances with the dust work	P 1 9 E 0 9		1. The system is designed for this hazard. As the gases will be in low concentration vapour phase, violent reaction is not expected. 2. The extraction system is remote to personnel locations 3. Vapours will be extracted by the system	1. Design gas detection may alarm if significant vapours are produced	New identified	New identified		1 4 L		No further actions identified	
CA 42	Loss of Containment	Design	Buildup of condensed vapours in scrubber pipework	Incompatible materials mixing to give other hazardous substances or buildup of a single component that may be exposed by maintenance. Small LOCC within the building with limited environmental harm	P 1 9 E 1 9		1. The system is designed for this hazard. As the gases will be in low concentration vapour phase, violent reaction is not expected. 2. The extraction system is remote to personnel locations. 3. Materials of construction selected to be resistant to chemicals. 4. Main ductwork is inside the building which will limit condensation of gases until they are outside.	1. Design gas detection may alarm if significant vapours are produced	New identified	1. FPMO used for all pipework streams. 2. Routine maintenance of Scrubber system as per manufacturers recommendations		1 4 L		1. Provide any low points in the ductwork with drains to safe location. 2. Design ductwork so that it has falls in appropriate directions to manage 'underwater' 3. Provide access panels in areas where buildup may be a concern to allow safe inspection / cleaning (safe hot)	


Dosing System											
CA 43	Loss of Containment	Human error	Manual charging & movement of load addition to process tanks - potential damage to Safestair (Double skinned)	Loss of up to 1000 litres of DTE, T, Tricorolone from a plastic container causing a loss of the contents to the floor. Likely to be contained within the curbs of the building. Potential operator exposure and injury	P 2 8	1. Safestair is double skinned with no drain valves 2. Safestairs located within fire line, away from traffic movements	None identified	1. Galley running along the side of the line will contain the volume of a full Safestair 2. Central location within the building	1. Trained operators / FLT drivers 2. Spill kits 3. Emergency Spillage Procedure 4. Specific PPE for spillage control 5. Safestairs have a specified lifetime before being changed 6. Safestairs are inspected regularly	2 5 M	1. Consider the design of the galley to ensure it contains 100% of a Safestair 2. Provide a ramp to the galley to allow easy recovery of spill material 3. Provide level drains in the galley ramp to indicate that something is present and need attention (not linked to fire alarm)
CA 44	Overpressure	Substance addition event	Chemical based chemicals crystallises in vent of the air agitator causing HF to be released	All pressurised Safestair leading to either failure of the Safestair or the fittings. Person nearby splashed with HF while not wearing PPE. Single fatality, HF expected to be retained near incident	P 3 7	1. Safestairs are double skinned and sealed at the top which is expected to contain the majority of any release. 2. Designer gas detection	1. Air agitator pressure. 3. Size set to as low as possible and 2. Normal vent pressure of Safestair.	1. Galley 2. Normally vents back into the chemical tank	1. SOP 2. Trained operators	3 4 M	1. Consider from the vent on the Safestair (from the air agitator) could be checked/insured to ensure that the vent remains clear. 2. Confirm that when Safestairs are replaced, the associated pipework etc is replaced as being at end of life - 5 years. (Previously agreed that pipework needs to be changed but unclear if this being done) 3. Confirm max pump pressure is less than the pressure rating of the pipework 4. Consider stopping pump after 1 hr to limit total maximum loss 5. Ensure open end of pipe into tank is above the level of the overflow to prevent the burst pressure of a Safestair
CA 45	Overpressure	Faulting or Human error	Pipe from Chemical dosing pump (e.g. small GroundFlo) blocked, resulting in over pressure in pipework from pump to tank	Rupture of pipework releasing up to 1000 litres of chemical - worst case 40% HF - potential fatality	P 3 7	1. Pipework rated to 10 barg which is above maximum pressure possible from pump 2. Pump can only deliver 30 litres per hour	1. Inbuilt flow meter stops pump if no flow	1. Bund and galley 2. Pipes are double walled 3. All joints have spray guards 4. Dragger may detect and alarm	1. Maintenance procedures for generating process risk assessments for access beyond guards 2. PPE for maintenance 3. Chemical & Emergency awareness training 4. Trained operators 5. Spill kits available	3 3 M	1. Consider fitting pipes within a clear protective cover / box to minimise spray in the event of failure. 2. Confirm that when Safestairs are replaced, the associated pipework etc is replaced as being at end of life - 5 years. (Previously agreed that pipework needs to be changed but unclear if this being done) 3. Confirm max pump pressure is less than the pressure rating of the pipework 4. Consider stopping pump after 1 hr to limit total maximum loss 5. Ensure open end of pipe into tank is above the level of the overflow to prevent the burst pressure of a Safestair
CA 46	Loss of Containment	Human error	Safestair vent not connected	Fumes from Safestair are localised at the Safestair location. May harm person working in immediate vicinity. No environmental harm	P 2 8	1. Transfers will tend to draw air into the Safestair rather than force fumes out. 2. Vent is part of the main connection process so unlikely to be left off	1. Designer gas detectors may detect any release 2. General room ventilation may be sufficient to dilute vapours from most chemicals	None identified	1. SOP for connecting Safestairs 2. Trained operators 3. Safestair locations are not near workstations	2 5 M	No further actions identified
Filtration / Circulation System											
CA 47	Overpressure	Mechanical failure	Chemical leak from the filtration system (e.g. pump seal, filter case lid, flanges)	Pipeline rupture leading to the loss of chemical at low level onto the building floor which would be captured in the bund or if it may pool & be contained within the building with little escaping through the building door and entering the first drain	P 2 8	1. The system uses a double design pump which is unlikely to produce adequate pressure to rupture these fittings, but this can not be confirmed - Gas alarm 2. All equipment located below the top of the tank and pump is inside the tank	1. Designer gas detectors may detect any release 2. Bund alarm	1. All equipment located within the bund 2. PIPES on line to Blackbox WWTW 3. Spray guards as for the rest of the line	1. PPE - Full acid suit 2. Chemical & Emergency awareness training 3. Trained operators 4. Spill kits & drain covers available for incidents 5. Emergency response and HF antidote	2 6 M	1. Confirm if pipework is designed for pressure greater than pump can deliver 2. Consider providing additional splash guarding to protect operator 3. Develop a PPM schedule for the acid addition system to include maintenance of seals to prevent leakage 4. Provide the operator with a risk assessment and SOP
CA 48	Low pressure / low flow	Mechanical failure	Lack of mixing filtration (e.g. filter blocked, reactor not working effectively)	Quality problems only - No Significant Safety Hazards identified	P						No further actions identified
CA 49	Misc.	Maintenance	Exposure of chemicals when the filter cartridge needs to be replaced	Operator / Technician splashed with chemicals or residues left on floor where others may be harmed	P 2 9	None identified	1. Designer gas detectors may detect any release 2. Bund alarm	1. Drip trays to capture any material leaking from the filter before it is 'bagged' up	1. SOP for safe changing of filters 2. PPE assuming filter	2 6 M	1. Can filters be flushed through with water before they are removed to minimise hazard? 2. Assess personal exposure during change over and consider if LEV is needed or if PPE is suitable. 3. Implement a suitable process and equipment to manage a filter change safely.
Cooling System											
CA 50	Overflowing	Mechanical failure	Burst cooling water coil runs into tank and overflows	Loss of up to 16,000 litres of Toxic, DTE, Very Toxic or corrosive from Process tanks but being contained within the bund. May be potential for liquid to enter LEV	P 2 7	1. Chemical Tanks fitted with overflow direct to bund which are positioned below the level of the addition to tank 2. Insurements cross check each other 3. Selected cut off device to reset control on all tanks on high level, high high level and shut down the whole line 4. Audible alarm led from Level monitoring in the bund	1. High and independent high level monitoring & alarm on chemical tanks (local audible and visual alarm) 2. Insurements cross check each other 3. Selected cut off device to reset control on all tanks on high level, high high level and shut down the whole line 4. Audible alarm led from Level monitoring in the bund	1. Bund 2. Manual isolation valves 3. More likely to leak than rupture causing a slow overflow	1. Trained operators 2. Cooling coil condition is part of tank inspection 3. Spill procedures and kits	2 4 M	1. Confirm if the PPE shuts off the water to the cooling coil (not on P&ID)
Bunding											
CA 51	Loss of Containment / Environmental impact	Design	Mixing of oxidic and acid chemistry into bund	Release toxic gas caused by reaction from incompatible chemicals	P 2 8	1. Segregated bunds 2. No drain valves etc on chemical tanks	1. Bund sump level alarms trigger evacuation 2. Designers alert operator to a problem	1. Bund	1. Emergency procedures 2. Tank inspections 3. SOPs and trained personnel for all chemical transfers	2 5 M	No further actions identified
CA 52	Loss of containment	Fire	Failure of multiple tanks leading to over-topping of the bund	See 'Fire' in Tanks Sections	P						No further actions identified
Transporters and Flight Bars											
CA 53	Loss of Containment	Mechanical failure	Flightbar or component drops into solution	Chemicals over-tops the tank into bund. Splashing of chemicals. Spillage retained within building	P 2 8	1. Lids on chemical tanks would prevent incident if this was not the target tank 2. Transporter height above tanks is minimised, limiting potential for splashing 3. Parts have low cross section area the way they are mounted, which may reduce amount of displaced material	1. Drip trays under transporter but not always closed 2. Any significantly misaligned parts are likely to be dislodged by jamming equipment before reaching chemical tanks (e.g. lid spout) 3. Slack ball detector may help if component makes contact with other equipment	1. Tank and walkway sensors 2. Significant free board to bund ensure splashed 3. Bund 4. Transporter etc are enclosed to limit splash potential (sequencing)	1. Spill procedures and kits 2. Operators trained to load flightbar and check dip is correctly fitted 3. Regular LOLER inspections of transporter 4. Kits are routinely replaced every 12 months due to chemical environment	2 3 L	No further actions identified
CA 54	Loss of Containment	Mechanical failure / Human Error	Lid only partially open - dip tray on transporter which is then moved into area where operators may work	Procurer to 'tighten' or component drops into solution' above or Component fails outside tank	P						No further actions identified
CA 55	Others	Human error	Contractor maintenance	Various falls & impact damage from contract maintenance duties resulting in harm to people (predominantly the contractors) and the environment	P 3 7	None identified	None identified	None identified	1. Contractor Risk Assessments 2. Approved methodologies (e.g. RAIBS) 3. Method statements 4. Competence assessment (ECC) before contractors are employed by BAE 5. Permit to Work System	3 4 M	No further actions identified
CA 56	Others	Human error	Operator in gantry when transporter at loading station	Potential crush injury / fatality	P 3 8	1. Raising and lowering of flight bars is remote to other work stations	1. Light curtain around loading point stops movement of transporter and loading station 2. RAMP (Risk Reduce Platform) is automated with suitable sensors etc	1. Clearly marked area 2. Audible beacon whilst load raised station moving 3. Dead man handle to transporter operation	1. SOPs 2. Trained operators 3. Light beams and other safety systems on the transporter are routinely tested	3 4 M	No further actions identified
CA 57	Others	Design	Acid dips / residues on the dip tray on transporter which is then moved into area where operators may work	Contamination of a working area by dips from dip tray. Minor injury possible	P 1 10	None identified	None identified	1. Dip trays designed to minimise leaks 2. When transporter is over an area, no operator can be present under a suspended load	1. Operators trained in chemical awareness 2. Gloves worn 3. Mico team has risk assessment and Dynamic RA to avoid this hazard	1 8 M	1. Confirm that chemical resistant gloves are worn when handling the dip tray 2. New PFD arrangements approved to work on OR and these will be replaced to make sure we don't come into contact / underneath including water/seal/air and unbad / load.
CA 58	Abnormal Chemical Reaction	Mechanical / Chemical failure	Transporter lowers component into the wrong tank	See 'Wrong type of metal put into an incompatible tank causing a chemical reaction' in Tank Section	P						No further actions identified
Powder Additions											
CA 59			At the time of the HAZID, no powder additions are made on the New Analysis Line		P						No further actions identified

Bulk Fill - Vessels bring IBCs of chemicals, hoses, pump, trained personnel. Area is handed over to Vessels under a PTW. Cooled/soff. Hose into tanks positioned with the blaster and secured in position.										
CA 80	Abnormal Chemical Reaction	Human error	Wrong chemical added to the tank during bulk fill. Mixing of caustic and acid chemistry in a tank	Release toxic gas caused by reaction from incompatible chemicals. (See compatibility matrix below)	P 2 8 E 2 8	1. Use of IBCs for bulk fill means it is not practical to use different filling etc. 2. Design gas detectors may pick up higher levels of vapour operator is a problem	1. Bund alarms may trigger if overflowing 2. Lip extraction to minimise loss of gases 3. Lids closed during chemical addition to ensure IBC is effective 4. Anodise bulk fill via the blaster	1. Trained operators 2. Clear labelling of IBCs 3. Risk assessment, permits and method statements in place for filling which includes a check of the correct IBC Tank 4. Bulk fill is carried out by a competent contractor 5. A pre-check of correct container 6. PPE worn during transfers and area is cordoned off	2 6 M 2 6 M	1. Complete human factors review of the tank filling procedures to minimise the potential for mixing incompatible chemicals 2. Consider if this procedure is safety critical 3. Ensure that this process is always done under a PTW, which includes a visual check by the PTW issuer that the correct chemicals and tank have been selected
CA 81	Overpressure / Loss of Containment	Mechanical failure	Overpressure in IBC transfer system or Loss of containment from hoses, joints, seals	Loss of up to 1000 litres of DFE, T+, corrosives from an IBC / pump / hose causing a loss of the contents to the floor. Due to the location in the centre of the building, respect the majority to be contained within the building (or existing trenches towards effluent) Potential operator exposure and injury. Fatally possible if sprayed with corrosives or unable to escape and exposed to toxic fumes. Limited environmental effect.	P 3 6 E 1 6	1. Maximum pump pressure is below the maximum pressure rating of the pipeline and fittings 2. No valves on hose after the pump 3. Pressure and flow rates are low so hose will not whip around if loose	1. Design gas detectors may pick up higher levels of vapour 1. Bund / trench	1. Area is barricaded and hoses reeled to avoid damage 2. Hoses are secured to prevent slippage out of the tank 3. PPE worn during transfers 4. Trained contractors with Risk assessment, permits and method statements in place and PPE 5. Emergency procedures 6. Hoses inspected before use for condition 7. Spill kits	3 4 M 1 4 L	
CA 82	Abnormal Chemical Reaction	Human error	Concentrated acids will be added to tank during bulk fill with no water already in tank. This water added leading to violent reaction	Heat of solution leads to steam generation and creation of fumes which could harm people near by. No environmental hazard	P 2 8 E 0 8	None identified	1. Design gas detectors may pick up higher levels of vapour 1. Lip extraction to minimise loss of gases 2. Lids closed during chemical addition to ensure IBC is effective	1. Area is barricaded off 2. PPE worn during transfers 3. Trained contractors with Risk assessment, permits and method statements in place and PPE 4. Emergency procedures	2 6 M 0 5 L	1. Ensure that SOP includes a visual check by test personnel that the water has been added prior to the chemicals (this is likely to require contact with an operator and confirmation via the PAB)
Bulk Empty - Vessels bring vacuum tanker, hoses, trained personnel, etc. Hoses lowered into tank from transporter and connected to their waste line with external connection point to vacuum tanker. All connection points are confirmed as valve closed, blanking/bleed. Lines is washed through with water to ensure no other chemicals present and no leaks from the other connection points. Hoses manually positioned to remove as much liquid as possible. Tanks are washed multiple times to dilute remaining chemicals and sucked to tanker. Tanks has capacity for a full tank plus wastepans. Lines washed through with water before hoses disconnected.										
CA 83	Low pressure	Human error	Operator (Vessels) closes valves in suction line from vacuum tanker used to empty tanks OR Inadequate vacuum from tanker	Evacuation system from road tanker to downstream hose, collapses hose (and wastes it). No Significant Safety Hazards Identified	P E		1. Pressure inside suction line has suitable pressure drop to ensure use is effective at the furthest tank.			No further actions identified
CA 84	Loss of containment	Human error	Operator (Vessels) closes valves in suction line from vacuum tanker used to empty tanks OR Inadequate vacuum from tanker	Chemical from tank will leak / flow from the waste pipe before the vacuum is applied (e.g. valve open). It is likely that the line from the tank prime - therefore no chemical hazard if the opening is small, it is likely to draw air into the line, increasing any out of chemical	P 2 8 E 1 8		1. Design gas detectors may pick up higher levels of vapour 1. Waste pipe and valves at each tank are located within the bund	1. SOP requires all valves to be confirmed closed and present during the transfer. 2. Method statements requires the line to be inspected for leaks before applying vacuum. 3. Trained contractors with Risk assessment, permits and method statements in place and PPE 4. Emergency procedures	2 6 M 1 5 L	1. Review SOP to include the necessary checks and flush sequence 2. Check to supply sealed caps
CA 85	Loss of containment	Mechanical failure	Hoses / coupling fails during transfer. (e.g. hose not connected properly, damaged, hose weak)	Chemical continues to siphon from tank / clean from vac tanker and flow is removed from tank. Tank waste connection valve is inspected, closed. Proof of chemical forms outside building (no spray etc). Farmer's corrosion burns to personnel. Potential for chemicals to enter drains and into river	P 2 8 E 4 8		1. Quality / Trench will help to contain leaks that occur inside the building. 2. Connection point is in the external chemical delivery area	1. Vac tanker operator can see contain leaks that occur inside the building. 2. Connection point is in the external chemical delivery area 3. Hoses inspected prior to use 4. Hoses not in areas where impact is not expected (e.g. vehicle exhaust)	2 6 M 4 6 M	1. Ensure all components in the waste line are compatible with the worst case chemicals and any substances created by interaction of chemicals
CA 86	Cross contamination	Design	Residue left in line after transfer which may be incompatible with next transfer.	Chemical fills pipe upstream of the tank connection point and not washed out. Two tanks emptied at same time. Chemical reaction within pipe leading to LOC	P 2 8 E 1 8		1. New Anodise Line waste pipe is not connected to the New PPE waste pipe 1. Bund will contain leaks that occur inside the building	1. Method statements requires the water is flushed through the line before and after each transfer. 2. PPE worn during transfers 3. Trained contractors with Risk assessment, permits and method statements in place and PPE 4. Emergency procedures	2 6 M 1 5 L	No further actions identified

Total Scenarios:	66
Last Scenario Reference:	CAS81
Total Number of Actions:	70
Last Action Reference:	CAS8.1

Category	Residual Risk Summary	
	Risk to People	Risk to the Environment
High	34	3
Medium (if ALARP)	9	34
Low	21	21
Not Applicable		
Total		

ADDITIONAL INFORMATION



Process Steps

- 8 recipes overall
- only 6 will happen at any given time



Tank Chart

Number	Process	Chemistry	Concentration (g/L)	Volume (m ³)	Tank Material	Temperature (°C)	Heat Up Load (kW)	Steady State Load (kW)	Evaporation (kg/s)	Cooling (kW)	Volume (m ³ /s)	Eductor Agitation TO's/h
1	Load											
2	Alkaline Clean	Turco	40-60	16.64	304 SS	45-60	78.4	33.4	0.0302	-	0.0247	-
3	DI Rinse	Water	<20µs	15.25	304 SS	<35	-	-	-	-	0.0302	-
4	WIP Inspection											
5	DI Rinse	Water	<20µs	15.25	304 SS	<35	-	-	-	-	0.0302	-
6	Aluminum Etch	Alibus Etch	35-45 NaOH & 10 Sodium glucohepatonate	16.64	304 SS	30-40	88.6	13.5	0.00857	-	0.0329	-
7	Aluminum Etch	Alibus Etch	35-45 NaOH & 10 Sodium glucohepatonate	16.64	304 SS	30-40	88.6	13.5	0.00857	-	0.0329	-
8	DI Rinse	Water	<20µs	15.25	304 SS	<35	-	-	-	-	0.0302	-
9	Pickle	Surtec 831	5Nv/v	16.64	316 SS	40-60	78.4	33.4	0.0302	-	0.0329	-
10	Daamut	Nitric	450-550	16.64	PP	10-25	9.3	5.5	0.00857	-	0.0329	-
11	Ti Etch/Pickle	HF&Nitric	300-450 HNO ₃ 20-24 HF	16.64	PVDF	15-26	11.4	5.8	0.00282	-	0.0329	-
12	Ti Etch/Pickle	HF&Nitric	300-450 HNO ₃ 20-24 HF	16.64	PVDF	15-26	11.4	5.8	0.00282	-	0.0329	-
13	DI Rinse	Water	<20µs	15.25	PVDF	<35	-	-	-	-	0.0302	-
14	TPAA	H ₂ SO ₄	4.5Nwt	18.78	PP	24-27	15.43	N/A	0.00345	42.3	0.0555	-
15	TPAA	H ₂ SO ₄	Proprietary	18.78	PP	24-27	15.43	N/A	0.00345	42.3	0.0555	-
16	DI Rinse	Water	<20µs	15.25	316 SS	Ambient	-	-	-	-	0.0302	-
17	DI Rinse	Water	<20µs	15.25	316 SS	Ambient	-	-	-	-	0.0302	-
18	Ti Conversion Ct	Fluoride Phosphata	50 Na ₂ PO ₃ F 20 KF// 9 NaF & 2HF	16.64	PVDF	21-23	25.5	10.0	0.00638	-	0.0329	-
19	Seal	Surtec 650M	8-12% (assumed wt)	16.64	316 SS	30-40	38.7	11.8	0.00857	-	-	3
20	Seal	Surtec 650M	8-12% (assumed wt)	16.64	316 SS	30-40	38.7	11.8	0.00857	-	-	3
21	Warm DI Rinse	Water	<20µs	16.64	316 SS	32-38	94.8	9.0	0.00131	-	-	3
22	Warm DI Rinse	Water	<20µs	16.64	316 SS	32-38	94.8	9.0	0.00131	-	-	3
23	Hot Water Seal	Water or Dichromate	-	16.64	316 SS	88-93	138.5	90.0	0.0005	-	0.0329	3
24	Hot Water Seal	Wait (Water)	-	15.25	316 SS	N/A	-	-	-	0.0302	-	
25	DI Rinse	Water	<20µs	15.25	304 SS	Ambient	-	-	-	-	0.0302	-
26	Drying Oven											
27	Drying Oven											
28	Unload											

The Tank Chart shows us what the chemistry and process requires per station
 Chiller load has been updated, tank 23 no need for force chilling
 On cascaded rinses, conductivity target will be achieved on second stage



Tank Summary Table

Number	Process	Heating	Cooling	Hein to Effluent	Air Agitation	Eductor Agitation	Top Spray	Cascade	Filtration	Conductivity Control	pH Monitor	DI Water Supply	Cathode Plates	Chemical Quick Fill	Chemical Dosing	Safety Interlocks	Air Agitation Substrate	Strip/Washers	Specified User	Overflow
1	Load																			
2	Alkaline Clean	✓			✓				✓					✓	✓	✓	✓	✓		✓
3	DI Rinse		✓		✓				✓											✓
4	WIP Inspection																			
5	DI Rinse		✓		✓				✓											✓
6	Aluminum Etch	✓			✓				✓					✓	✓	✓	✓	✓		✓
7	Aluminum Etch	✓			✓				✓					✓	✓	✓	✓	✓		✓
8	DI Rinse		✓		✓				✓											✓
9	Pickle	✓			✓				✓					✓	✓	✓	✓	✓		✓
10	Daamut	✓			✓				✓					✓	✓	✓	✓	✓		✓
11	Ti Etch/Pickle	✓			✓				✓					✓	✓	✓	✓	✓		✓
12	Ti Etch/Pickle	✓			✓				✓					✓	✓	✓	✓	✓		✓
13	DI Rinse		✓		✓				✓											✓
14	TPAA	✓			✓				✓					✓	✓	✓	✓	✓		✓
15	DI Rinse	✓			✓				✓					✓	✓	✓	✓	✓		✓
16	DI Rinse	✓			✓				✓					✓	✓	✓	✓	✓		✓
17	DI Rinse	✓			✓				✓					✓	✓	✓	✓	✓		✓
18	Ti Conversion Ct	✓			✓				✓					✓	✓	✓	✓	✓		PVDF
19	Seal	✓			✓				✓					✓	✓	✓	✓	✓		✓
20	Seal	✓			✓				✓					✓	✓	✓	✓	✓		✓
21	Warm DI Rinse	✓			✓				✓					✓	✓	✓	✓	✓		✓
22	Warm DI Rinse	✓			✓				✓					✓	✓	✓	✓	✓		✓
23	Hot Water Seal	✓			✓				✓					✓	✓	✓	✓	✓		✓
24	Hot Water Seal	✓			✓				✓					✓	✓	✓	✓	✓		✓
25	DI Rinse		✓		✓				✓											✓
26	Drying Oven	✓							✓											✓
27	Drying Oven	✓							✓											✓
28	Unload																			

Stage 23 is force cooled using Towns Water
 Stage 24 will be configured as a wait station with air agitation provision, no educators

To be switched off when processing Do different heating cooling Retire? Or educator? Changed this issue

CHEMICAL DETAILS / INCOMPATIBILITY

Process	Tank	Chemical	Ferro 4315	Surtec 818/819	Alum Etch	Residue Alum Etch	Surtec 181	DMF	Nitric Acid	Hydro 295 G0	Hydro 295 G0	Hydro 295 G0	Sulphuric Acid	Sulphuric Acid	Fluoric Phosphate	Surtec 650V	Strovert FDS	Strovert FDS	SOS Files				
Alkaline Clean	2	Turco 4315							x	x	x	x	x						Bonderite CAK 4215 NCLT	Eye damage, fertility, irritant	Reacts with acids	Powder, slightly alkaline	
		Turco 061 089							x	x	x	x	x						MDS SurTec 081	skin eyes	Reacts with acids	Liquid, slightly alkaline	
Aluminium Etch	6,7	Alibus Etch**							x	x	x	x	x						Sodium-hydroxide	skin eyes corrosive	Strong oxidising agents, Acids, Metals, Water, Alcohols	Powder, alkaline	
		Bonderite Alum Etch #2							x	x	x	x	x						Bonderite CAK Alum Etch Jern 2	skin eyes corrosive	Acids, Water	Powder, alkaline	
Aluminium Pickle	9	Surtec 181							x	x	x	x	x						MDS SurTec 181	skin eyes corrosive	Acids. Reacts with base metals as aluminium.	Liquid, alkaline	
		DS544**	x	x	x	x	x	x	x	x	x	x	x						Nitric Acid	skin eyes corrosive	Reducing agents, Bases, Acids, Metals, Water, Alcohols	Liquid, acidic	
Desmut	10	Nitric Acid	x	x	x	x	x	x											Nitric acid	skin eyes corrosive	Reducing agents, Bases, Acids, Metals, Water, Alcohols	Liquid, acidic	
		Adhitec 295 G0	x	x	x	x	x	x											Adhitec 295 G0 sds v1 (2)	skin eyes corrosive	Strong reducing agents, strong bases, metals	Liquid, acidic	
Titanium Etch	11, 12	HF Nitric	x	x	x	x	x	x											Hydrofluoric acid	skin eyes Toxic	Contact with strong acids	Powder, slightly alkaline	
		TFSA	x	x	x	x	x	x											Sulphuric acid	skin eyes Toxic	Contact with strong acids	Liquid, acidic	
Ti Conversion coating	18	Fluoride phosphate (m of tribasic sodium phosphate, of and Potassium Fluoride) etc	x	x	x	x	x	x	x	x	x	x	x					x	Trisodium phosphate	skin eyes Toxic	Contact with strong acids	Liquid, acidic	
																			Potassium Fluoride	skin eyes Toxic	Contact with strong acids	Powder, slightly alkaline	
Anodise seal	19,20	SurTec 650V							x	x	x	x	x						SOS SurTec 650	skin eyes Toxic	Contact with strong acids	Liquid, acidic	
		Strovert FDS																	Strovert FDS	Eyes	Contact with strong acids	Liquid, acidic	
HW Seal/FACS	23	Socoo/FACS/hydrogen peroxide mix***							x	x	x	x	x						Socoo/FACS/SOS	skin eyes Toxic	Contact with strong acids	Liquid, acidic	
																			Hydrogen peroxide	skin eyes Toxic	Contact with strong acids	Liquid, acidic	


Primary chemical not compatible

x not compatible

**these are not proprietary chemicals. Therefore generic SDS sourced from Fisher for Sodium Hydroxide

***these are not proprietary chemicals. Therefore generic SDS sourced from Fisher for individual components. If Brenntag are going to supply this as a ready made solution, they should be able to supply SDS for the mixture

****generic SDS for hydrogen peroxide sourced from Fisher



Risk Matrices

©2013 HFL Risk Services Limited

PEOPLE RISK MATRIX											
101-200 fatalities	7										
51-100 fatalities	6										
11-50 fatalities	5										
2-10 fatalities	4										
Single fatality	3										
Major injury	2										
Minor injury	1										
No Injury	0										
Severity											
Likelihood		1	2	3	4	5	6	7	8	9	10
		< 10 ⁻⁶	10 ⁻⁶ to 10 ⁻⁵	10 ⁻⁵ to 10 ⁻⁴	10 ⁻⁴ to 10 ⁻³	10 ⁻³ to 10 ⁻²	10 ⁻² to 10 ⁻¹	10 ⁻¹ to 1	1	>1	

Legend		
 	HIGH	Further action essential to reduce the risks to an acceptable level within an agreed upon and specified time.
 	MEDIUM	Further action should be considered to reduce the risks as opportunities are recognised. Must be confident that the
 	LOW	No mitigation required but further action may be considered to reduce the risks.
 	HIGH Boundary (Offsite Risk)	Further action essential to reduce the risks to an acceptable level within an agreed upon and specified time.

ENVIRONMENT RISK MATRIX											
MATTE	7										
Offsite on Listed Sites	6										
Offsite on Listed Sites	5										
Offsite on Unlisted	4										
Minor Offsite Effects	3										
Onsite Effects	2										
Minor Onsite Effects	1										
Minor Spill	0										
No Effects	0										
Severity											
Likelihood		1	2	3	4	5	6	7	8	9	10
		< 10 ⁻⁶	10 ⁻⁶ to 10 ⁻⁵	10 ⁻⁵ to 10 ⁻⁴	10 ⁻⁴ to 10 ⁻³	10 ⁻³ to 10 ⁻²	10 ⁻² to 10 ⁻¹	10 ⁻¹ to 1	1	>1	

Legend		
 	HIGH	Further action essential to reduce the risks to an acceptable level within an agreed upon and specified time.
 	MEDIUM	Further action should be considered to reduce the risks as opportunities are recognised. Must be confident that the
 	LOW	No mitigation required but further action may be considered to reduce the risks.