

| | | | |
|--|--|------------|-----|
| E | Up to date - Results of detailed calculations and of the acoustic colored maps (§7.1 & 7.2) given | 29/07/2016 | |
| D1 | Mitigations to reach a calculated noise at ESR1 of 31,1dB(A) night time. 6 coolers instead of 8 coolers - coolers move by 2,4m on the roof- Decrease LP in tipping hall and bunker hall to 76dB(A) - fast acting doors for the tipping hall - decrease the step up transformer PWL by 4dB(A)- take into account the direction change at the bottom of the stack -Reached 32,3 dB(A) instead of 31,1dB(A) | 02/04/2015 | |
| C | Walls at site boundary to protect from plant noise ESR1 deleted. ESR1 elevation is higher than the EfW Plant elevation. | 12/02/2015 | |
| B | New model to take into account the new boiler (vertical one). | 11/02/2015 | |
| A | First emission | 28/01/2015 | |
| REV. | OBJET | DATES | ENR |
| Un trait dans la marge signale une évolution du texte depuis l'indice précédent. | | | |

Le présent document est la propriété de CNIM, il ne doit être ni utilisé, ni reproduit, ni

DESIGNATION DE L'AFFAIRE :

| |
|--|
| |
|--|

Keighley
Acoustic study

| |
|--|
| <p>Keighley <i>Acoustic study</i></p> |
|--|

Ce document dans son statut BPE reste applicable pendant toute la phase de réalisation

| | | |
|-----------------------|---------------|-------------------------|
| Auteurs : Charpentier | Vérifié par : | Approbateur :D.Bendahan |
| Date :12/02/2015 | Date : | Date :12/02/2015 |
| Visa : | Visa : | Visa : |

DOCUMENT N° : CNIM

Nombre de pages : 19

0H800702 02 / 64 I 0001

IDENTIFICATION CLIENT :

INDEX

- 1 Data and calculation hypothesis
 - 1.1 Air cooled condensers
 - 1.2 Tipping hall and refuse bunker
 - 1.3 Turbine Air coolers
 - 1.4 Turbine hall
 - 1.5 Stack
 - 1.6 Furnace Boiler Flue gas treatment Hall
 - 1.7 Electrical room
 - 1.8 Step up transformer
 - 1.9 Water treatment room
 - 1.10 Bottom ash hall
 - 1.11 Compressor room
 - 1.12 Air extractors
- 2 Mass Plan
- 3 Plant model
- 4 Receptors position
- 5 Attenuation of different materials
- 6 Acoustic pressure to receivers detailed calculations - Night time calculations
- 7 Results acoustic modelling
 - 7.1 Plant area night time - Plant in normal operation
 - 7.2 Results acoustic modelling in the neighbourhood night- Plant in normal operation
- 8 Calculations results - Calculated noise level summary - Night time - Plant in normal operation
- 9 Measured background noise level
- 10 Conclusions
 - 10.1 Plant noise level (permanent noise sources excluding road traffic modification)
 - 10.2 Night-time BS 4142
 - 10.3 Day-time BS 4142
 - 10.4 Conclusions following BS4142

1 Data and calculation hypothesis

1.1 Air cooled condensers

PWL 2 modules = 91dBA

Fans altitude 10m

Preliminary associated acoustic power spectrum

| | | | | | | | | | | |
|-----------------|-------|------|------|------|------|------|------|------|------|------|
| Frequency Hz | 31,50 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
| PWL power level | 92,3 | 92,3 | 90,3 | 87,8 | 86,1 | 83,2 | 78,4 | 71,7 | 62,9 | 88,0 |

1.2 Tipping hall and refuse bunker

Acoustic pressure in the hall

| | | | | | | | | | | |
|--|------|----|-----|-----|-----|------|------|------|------|------|
| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
| Lp reverberant | 80 | 80 | 80 | 73 | 70 | 70 | 70 | 61 | 67 | 75,9 |
| Door attenuation 0,7mm steel | 1 | 3 | 8 | 14 | 20 | 24 | 28 | 32 | 37 | |
| PWL emitted per steel 0,7mm m ² | 73 | 71 | 66 | 53 | 44 | 40 | 36 | 23 | 24 | 52,7 |
| Fast acting doors | 9 | 11 | 14 | 21 | 15 | 19 | 23 | 23 | 23 | |
| | 65 | 63 | 60 | 46 | 49 | 45 | 41 | 32 | 38 | 51,1 |
| Roof in Kingspan KS1000/RW27 40mm | 5 | 13 | 16 | 20 | 25 | 26 | 25 | 41 | 30 | |
| PWL emitted per roof KS1000RW m ² | 69 | 61 | 58 | 47 | 39 | 38 | 39 | 14 | 31 | 46,8 |
| Walls Kingspan KS1000 R/W 40 (9W) | 8 | 12 | 16 | 30 | 40 | 44 | 51 | 64 | 45 | |
| PWL emitted walls KS1000 RW40 (9W)m ² | 66 | 62 | 58 | 37 | 24 | 20 | 13 | -9 | 16 | 43,2 |
| Concrete attenuation | 34 | 38 | 38 | 44 | 48 | 52 | 56 | 60 | 64 | |
| PWL emitted per concrete m ² | 40 | 36 | 36 | 23 | 16 | 12 | 8 | -5 | -3 | 22,6 |

Tipping hall height 13,9m

Bunker height 30m

All the doors in steel 0,7mm

Six doors h=6m l=5m

Roofs in KS1000RW27 40mm and walls in KS1000R/W 40 (9W)

1.3 Turbine Air coolers

fitting of the fans at 14m

we assume 6 cells.

PWL 6 cells = 90,7dBA

| | | | | | | | | | | |
|----------------------------|------|------|------|------|------|------|------|------|------|------|
| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
| PWL per module | 84 | 84 | 84 | 79 | 78 | 81 | 72 | 63 | 53 | 83,0 |
| Total acoustic power level | 91,8 | 91,8 | 91,8 | 86,8 | 85,8 | 88,8 | 79,8 | 70,8 | 60,8 | 90,7 |

On South East and on South West bottom ash walls, an acroter height 4,5 m is necessary.

1.4 Turbine hall

Acoustic pressure in the hall

| | | | | | | | | | | |
|--|------|------|------|------|-----|------|------|------|------|------|
| Frequency Hz | 32 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
| Lp reverberant | 87,5 | 84,5 | 89,5 | 87,5 | 89 | 90 | 89,9 | 84,5 | 79 | 95,0 |
| Concrete attenuation | 34 | 38 | 38 | 44 | 48 | 52 | 56 | 60 | 64 | |
| PWL emitted per concrete m ² | 47,5 | 40,5 | 45,5 | 37,5 | 35 | 32 | 27,9 | 18,5 | 9 | 37,5 |
| Acoustic Louvers Slimshield 600mm | 3 | 7 | 9 | 12 | 24 | 31 | 33 | 29 | 30 | |
| PWL emitted Louvers m ² | 78,5 | 71,5 | 74,5 | 69,5 | 59 | 53 | 50,9 | 49,5 | 43 | 64,5 |
| Acoustic door | 5 | 10 | 15 | 20 | 25 | 30 | 35 | 35 | 40 | |
| PWL emitted per acoustic door m ² | 76,5 | 68,5 | 68,5 | 61,5 | 58 | 54 | 48,9 | 43,5 | 33 | 60,3 |

Hall height H=13,9m

Turbine hall door Width =4m Height = 4m (NE wall)

Walls and roof concrete 16cm thickness

Air inlet with 2 Louvers Slimshield IAC SL600 length 2,5m height 3m on NE and SE walls

Air outlet through 2 air extractors with a silencer downstream air extractor

Acoustic doors

1.5 Stack

Height of the stack =60 m

the directivity of the stack has been taken into account in the calculations

| | | | | | | | | | | |
|---|-------|-------|-------|-------|-------|------|-------|------|------|------|
| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
| PWL downstream fan | 120,4 | 120,2 | 122,1 | 116,6 | 114,2 | 110 | 103,8 | 97 | 90,1 | 116 |
| Silencer Attenuation | 5,4 | 11,2 | 27,1 | 37,6 | 49,2 | 45 | 38,8 | 32 | 15,1 | |
| PWL downstream silencer | 115 | 109 | 95 | 79 | 65 | 65 | 65 | 65 | 75 | 85,5 |
| PWL stack outlet (bend bottom of stack) | 112 | 106 | 92 | 76 | 62 | 62 | 62 | 62 | 72 | 82,5 |

Special silencer with very low noise at stack outlet.

1.6 Furnace Boiler Flue gas treatment Hall

Acoustic pressure in furnace-boiler- FGT hall between levels 0-10m

| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
|--|------|----|-----|-----|-----|------|------|------|------|------|
| Lp reverberant | 86 | 86 | 83 | 83 | 82 | 78 | 78 | 77 | 71 | 85,2 |
| Slimshield IAC SL150 Louvers | 3 | 6 | 6 | 8 | 10 | 14 | 18 | 16 | 15 | |
| PWL emitted Louvers m ² | 77 | 74 | 71 | 69 | 66 | 58 | 54 | 55 | 50 | 66,8 |
| Walls Kingspan KS1000 R/W 40 (9W) | 8 | 12 | 16 | 30 | 40 | 44 | 51 | 64 | 45 | |
| PWL emitted walls KS1000 RW40 (9W)m ² | 72 | 68 | 61 | 47 | 36 | 28 | 21 | 7 | 20 | 47,6 |
| Door attenuation 0,7mm steel | 1 | 3 | 8 | 14 | 20 | 24 | 28 | 32 | 37 | |
| PWL emitted per steel 0,7mm m ² | 79 | 77 | 69 | 63 | 56 | 48 | 44 | 39 | 28 | 59,5 |

For the natural ventilation of boiler & FGT hall, all the louvers are acoustic louvers Slimshield IAC SL150

Roofs in KS1000RW27 40mm and walls in KS1000R/W 40 (9W)

Boiler room height 35m Door on Boiler NE wall h=3m l=3m

All the doors in steel 0,7mm

Air intake, on NE wall, for the ventilation are through acoustic louvers Slimshield IAC SL150

L= 12+9=21m and H=5m S air inlet = 105m²

Air outlet through louvers top of building S=34,6x2=69,2m² on SE boiler wall

Air outlet through louvers top of building S=34,8x2=69,6m² on NW boiler wall

Acoustic pressure in furnace-boiler- FGT hall between levels 10m to roof

| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
|--|------|----|-----|-----|-----|------|------|------|------|------|
| Lp reverberant | 81 | 81 | 78 | 78 | 77 | 73 | 73 | 72 | 66 | 80,2 |
| Slimshield IAC SL150 Louvers | 3 | 6 | 6 | 8 | 10 | 14 | 18 | 16 | 15 | |
| PWL emitted Louvers m ² | 72 | 69 | 66 | 64 | 61 | 53 | 49 | 50 | 45 | 61,8 |
| Roof in Kingspan KS1000/RW27 40mm | 5 | 13 | 16 | 20 | 25 | 26 | 25 | 41 | 30 | |
| PWL emitted per roof KS1000RW m ² | 70 | 62 | 56 | 52 | 46 | 41 | 42 | 25 | 30 | 49,6 |
| Walls Kingspan KS1000 R/W 40 (9W) | 8 | 12 | 16 | 30 | 40 | 44 | 51 | 64 | 45 | |
| PWL emitted walls KS1000 RW40 (9W)m ² | 67 | 63 | 56 | 42 | 31 | 23 | 16 | 2 | 15 | 42,6 |
| attenuation 0,7mm steel | 1 | 3 | 8 | 14 | 20 | 24 | 28 | 32 | 37 | |
| PWL emitted per steel 0,7mm m ² | 74 | 72 | 64 | 58 | 51 | 43 | 39 | 34 | 23 | 54,5 |

1.7 Electrical room

| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
|--|------|----|-----|-----|-----|------|------|------|------|------|
| Lp reverberant | 40 | 53 | 76 | 84 | 77 | 76 | 67 | 65 | 60 | 80,4 |
| Door attenuation 0,7mm steel | 1 | 3 | 8 | 14 | 20 | 24 | 28 | 32 | 37 | |
| PWL emitted per steel 0,7mm m ² | 33 | 44 | 62 | 64 | 51 | 46 | 33 | 27 | 17 | 56,9 |
| Walls Kingspan KS1000 R/W 40 (9W) | 8 | 12 | 16 | 30 | 40 | 44 | 51 | 64 | 45 | |
| PWL emitted walls KS1000 RW40 (9W)m ² | 26 | 35 | 54 | 48 | 31 | 26 | 10 | -5 | 9 | 42,0 |
| Roof in Kingspan KS1000/RW27 40mm | 5 | 13 | 16 | 20 | 25 | 26 | 25 | 41 | 30 | |
| PWL emitted per roof KS1000RW m ² | 29 | 34 | 54 | 58 | 46 | 44 | 36 | 18 | 24 | 51,6 |
| Slimshield IAC SL100 Louvers | 2 | 5 | 4 | 5 | 6 | 9 | 13 | 14 | 13 | |
| PWL emitted per Louvers m ² | 32 | 42 | 66 | 73 | 65 | 61 | 48 | 45 | 41 | 67,6 |

Rooms for transformers TR11 and TR12- MV electrical room Roof height 6m

Walls in KS1000R/W 40 (9W)

All the doors in steel 0,7mm 3 doors h=3m l=2,5m on NE wall

Air inlet through louvers IAC SL100 S=1m² (3 louvres)

Forced air extraction on air outlet

3 air extractors

1.8 Step up transformer

| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
|---|------|----|-----|-----|-----|------|------|------|------|------|
| Lp reverberant | 28 | 41 | 64 | 72 | 65 | 64 | 55 | 53 | 48 | 68,4 |
| Concrete attenuation | 34 | 38 | 38 | 44 | 48 | 52 | 56 | 60 | 64 | |
| PWL emitted per concrete m ² | -12 | -3 | 20 | 22 | 11 | 6 | -7 | -13 | -22 | 15,4 |

PWL emitted through the fence section (5x12=60m²) = 72,4-6+10LOG(60)=84,4dB(A)

1.9 Water treatment room

Acoustic pressure in the hall

| Frequency Hz | 32 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
|--|----|----|-----|-----|-----|------|------|------|------|------|
| Lp reverberant | 86 | 86 | 83 | 83 | 82 | 78 | 78 | 77 | 71 | 85,2 |
| Slimshield Louvers IAC SL-100 | 2 | 5 | 4 | 5 | 6 | 9 | 13 | 14 | 13 | |
| PWL emitted by 1m ² of Louvers | 78 | 75 | 73 | 72 | 70 | 63 | 59 | 57 | 52 | 70,5 |
| Roof in Kingspan KS1000/RW27 40mm | 5 | 13 | 16 | 20 | 25 | 26 | 25 | 41 | 30 | |
| PWL emitted per roof KS1000RW m ² | 75 | 67 | 61 | 57 | 51 | 46 | 47 | 30 | 35 | 54,6 |
| Walls Kingspan KS1000 R/W 40 (9W) | 8 | 12 | 16 | 30 | 40 | 44 | 51 | 64 | 45 | |
| PWL emitted walls KS1000 RW40 (9W)m ² | 72 | 68 | 61 | 47 | 36 | 28 | 21 | 7 | 20 | 47,6 |
| Attenuation 0,7mm steel | 1 | 3 | 8 | 14 | 20 | 24 | 28 | 32 | 37 | |
| PWL emitted per door m ² | 79 | 77 | 69 | 63 | 56 | 48 | 44 | 39 | 28 | 59,5 |

Roofs in KS1000RW27 40mm and walls in KS1000R/W 40 (9W)
 All the doors in steel 0,7mm door h=3m l=2,5m on the NE wall
 Water treatment room height 15m
 Air inlet through louvers slimshield IAC SL-100 l=3m h=2m on the NE wall
 Air exhaust through an air extractor

1.10 Bottom ash hall

Acoustic pressure in the hall

| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
|--|------|----|-----|-----|-----|------|------|------|------|------|
| Lp reverberant | 86 | 85 | 77 | 71 | 71 | 69 | 68 | 68 | 59 | 75,4 |
| Door attenuation steel 0,7mm | 1 | 3 | 8 | 14 | 20 | 24 | 28 | 32 | 37 | |
| PWL emitted per steel 0,7mm m ² | 79 | 76 | 63 | 51 | 45 | 39 | 34 | 30 | 16 | 53,0 |
| Walls Kingspan KS1000 R/W 40 (9W) | 8 | 12 | 16 | 30 | 40 | 44 | 51 | 64 | 45 | |
| PWL emitted walls KS1000 RW40 (9W)m ² | 72 | 67 | 55 | 35 | 25 | 19 | 11 | -2 | 8 | 43,5 |
| Roof in Kingspan KS1000/RW27 40mm | 5 | 13 | 16 | 20 | 25 | 26 | 25 | 41 | 30 | |
| PWL emitted per roof KS1000RW m ² | 75 | 66 | 55 | 45 | 40 | 37 | 37 | 21 | 23 | 46,2 |

Roofs in KS1000RW27 40mm and walls in KS1000R/W 40 (9W)
 All the doors in steel 0,7mm Door on the SW wall l=15m h=5m
 Bottom ash hall height 10,5m

1.11 Compressor room

Acoustic pressure in the hall

| Frequency Hz | 32 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
|--|----|----|-----|-----|-----|------|------|------|------|------|
| Lp reverberant | 80 | 86 | 91 | 84 | 82 | 80 | 77 | 71 | 62 | 85,1 |
| Slimshield IAC SL150 Louvers | 3 | 6 | 6 | 8 | 10 | 14 | 18 | 16 | 15 | |
| PWL emitted Louvers m ² | 71 | 74 | 79 | 70 | 66 | 60 | 53 | 49 | 41 | 68,2 |
| Walls Kingspan KS1000 R/W 40 (9W) | 8 | 12 | 16 | 30 | 40 | 44 | 51 | 64 | 45 | |
| PWL emitted walls KS1000 RW40 (9W)m ² | 66 | 68 | 69 | 48 | 36 | 30 | 20 | 1 | 11 | 53,5 |
| Roof in Kingspan KS1000/RW27 40mm | 5 | 13 | 16 | 20 | 25 | 26 | 25 | 41 | 30 | |
| PWL emitted per roof KS1000RW m ² | 69 | 67 | 69 | 58 | 51 | 48 | 46 | 24 | 26 | 56,7 |
| Door attenuation steel 0,7mm | 1 | 3 | 8 | 14 | 20 | 24 | 28 | 32 | 37 | |
| PWL emitted per 0,7mm steel m ² | 73 | 77 | 77 | 64 | 56 | 50 | 43 | 33 | 19 | 63,1 |

Roofs in KS1000RW27 40mm and walls in KS1000R/W 40 (9W)
 Door in steel 0,7mm h=3m l=2,5m
 Compressor room height 15m Louvers on air inlet Slimshield IAC SL150 on SE wall S=2x1m2

1.12 Air extractors

All these information are hypothesis to confirm later.

Electrical rooms

Transformers rooms and MV distribution room 3 air extractors on NE wall
 Estimated PWL downstream silencer = 77,5dB(A)

Height of the three noise sources 8m

Turbine hall 2 air extractors on the roof **direction of the outlet of the pipe south east**

Estimated PWL downstream silencer = 88,8dB(A)

Height of the noise source 12m

Air compressor room 1 air extractor on north west wall
 Estimated PWL downstream silencer = 80,3dB(A)


Height of the noise source 6m

Water treatment hall 1 air extractor on the NE wall
 Estimated PWL downstream silencer = 89,9dB(A)


Height of the noise source 10m


| Frequency Hz | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 | A |
|--------------------------------------|------|----|-----|-----|-----|------|------|------|------|------|
| PWL downstream silencer compressor | 100 | 98 | 89 | 80 | 67 | 59 | 66 | 73 | 75 | 80,3 |
| PWL downstream silencer water hall | 101 | 89 | 89 | 80 | 82 | 87 | 83 | 78 | 72 | 89,9 |
| PWL downstream silencer turbine hall | 87 | 88 | 93 | 80 | 71 | 85 | 82 | 80 | 77 | 88,8 |
| PWL downstream silencer elec room | 65 | 65 | 74 | 77 | 67 | 68 | 71 | 72 | 66 | 77,5 |

2 Mass plan




3 Plant model





4 Receptors position



5 Attenuation of different materials

| <i>Sound reduction index</i> | 31,5 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 |
|---|------|----|-----|-----|-----|------|------|------|------|
| Type of materials | | | | | | | | | |
| Concrete 16cm | 34 | 38 | 38 | 44 | 48 | 52 | 56 | 60 | 64 |
| Acoustic door | 5 | 10 | 15 | 20 | 25 | 30 | 35 | 35 | 40 |
| 0,7mm steel (steel 5,5kg/m ²) | 1 | 3 | 8 | 14 | 20 | 24 | 28 | 32 | 37 |
| Slimshield IAC SL100 Louvers | 2 | 5 | 4 | 5 | 6 | 9 | 13 | 14 | 13 |
| Slimshield IAC SL150 Louvers | 3 | 6 | 6 | 8 | 10 | 14 | 18 | 16 | 15 |
| Slimshield IAC SL300 Louvers | 3 | 6 | 7 | 10 | 12 | 18 | 18 | 14 | 13 |
| Slimshield IAC SL600 Louvers | 3 | 7 | 9 | 12 | 24 | 31 | 33 | 29 | 30 |
| Roof in Kingspan KS1000/RW27 40mm | 5 | 13 | 16 | 20 | 25 | 26 | 25 | 41 | 30 |
| Walls Kingspan KS1000 R/W 40 (9W) | 8 | 12 | 16 | 30 | 40 | 44 | 51 | 64 | 45 |

6 Acoustic pressure to receivers detailed calculations - Night time calculations

| Calculation file | Keighley E.IPR | x = 7,00 m | y = 9,00 m | z = 1,50 m |
|------------------|----------------------|------------|------------|------------|
| IPkt001 » | ESR1 | L r,i,A | L r,A | |
| EZQi013 » | extractor Compressor | 22,324 | 22,324 | |
| EZQi016 » | Extractor turbine 2 | 20,68 | 24,589 | |
| EZQi007 » | Cooler 3 | 20,332 | 25,973 | |
| EZQi001 » | Stack | 19,881 | 26,928 | |
| FLQi225 » | Boiler louveres out3 | 19,868 | 27,708 | |
| FLQi204 » | Step up transf/WAND3 | 19,182 | 28,279 | |
| FLQi179 » | Compressor /WAND6 | 18,795 | 28,742 | |
| FLQi180 » | Compressor /DACH | 18,079 | 29,1 | |
| FLQi045 » | Water treatment/DACH | 17,905 | 29,418 | |
| FLQi207 » | Tipping hall doors | 17,754 | 29,704 | |
| FLQi026 » | Waste bunker /WAND6 | 17,365 | 29,95 | |
| FLQi088 » | Boiler SW low | 17,163 | 30,173 | |
| EZQi011 » | Cooler 7 | 16,743 | 30,366 | |
| FLQi219 » | Bottom ash door | 16,473 | 30,54 | |
| FLQi082 » | Boiler and FGT/WAND6 | 16,363 | 30,703 | |
| EZQi006 » | Cooler 2 | 16,152 | 30,852 | |
| FLQi178 » | Compressor /WAND5 | 16,126 | 30,996 | |
| EZQi014 » | extractor water hall | 15,966 | 31,13 | |
| FLQi044 » | Water treatmen/WAND4 | 15,602 | 31,25 | |
| FLQi005 » | Tipping hall /DACH | 15,2 | 31,357 | |
| FLQi177 » | Compressor /WAND4 | 15,147 | 31,46 | |
| EZQi015 » | Extractor turbine 1 | 14,208 | 31,541 | |
| FLQi084 » | Boiler and FGT /DACH | 14,03 | 31,617 | |
| FLQi028 » | Waste bunker /DACH | 13,85 | 31,689 | |
| FLQi004 » | Tipping hall /WAND4 | 13,72 | 31,758 | |
| EZQi010 » | Cooler 6 | 13,415 | 31,821 | |
| EZQi002 » | ACC 1 | 12,98 | 31,877 | |
| FLQi003 » | Tipping hall /WAND3 | 12,467 | 31,927 | |
| FLQi027 » | Waste bunker /WAND7 | 12,449 | 31,975 | |
| EZQi005 » | Cooler 1 | 12,384 | 32,023 | |
| FLQi175 » | Compressor /WAND2 | 12,239 | 32,068 | |
| FLQi063 » | Bottom ash /DACH | 11,545 | 32,107 | |
| EZQi003 » | ACC 2 | 10,701 | 32,138 | |
| EZQi009 » | Cooler 5 | 10,591 | 32,168 | |
| FLQi060 » | Bottom ash /WAND3 | 10,268 | 32,196 | |
| FLQi221 » | Boiler NE1 louveres | 8,351 | 32,214 | |
| FLQi226 » | Compressor door | 7,292 | 32,228 | |
| FLQi217 » | Water louveres | 6,637 | 32,24 | |
| FLQi061 » | FGT SW bottomashconv | 5,836 | 32,25 | |
| FLQi224 » | Boiler louveres out2 | 5,784 | 32,26 | |
| FLQi222 » | Boiler NE3 louveres | 4,241 | 32,267 | |
| FLQi227 » | Compressor louveres | 4,232 | 32,273 | |
| FLQi083 » | Boiler and FGT/WAND7 | 3,71 | 32,279 | |
| FLQi041 » | Water treatmen/WAND1 | 3,501 | 32,285 | |
| FLQi059 » | Bottom ash /WAND2 | 2,9 | 32,29 | |
| FLQi025 » | Waste bunker /WAND5 | 2,553 | 32,295 | |
| FLQi081 » | Boiler and FGT/WAND5 | 2,143 | 32,299 | |
| FLQi223 » | Boiler louveres out1 | 1,489 | 32,303 | |
| EZQi017 » | Extractor elec 1 | 0,5 | 32,305 | |
| EZQi018 » | Extractor elec 2 | 0,355 | 32,308 | |
| EZQi019 » | Extractor elec 3 | 0,193 | 32,311 | |
| FLQi210 » | Turbine Louvres SE | -0,955 | 32,313 | |
| FLQi218 » | Water door | -1,766 | 32,315 | |
| FLQi022 » | Waste bunker /WAND2 | -2,201 | 32,316 | |
| FLQi077 » | Boiler and FGT/WAND1 | -3,359 | 32,317 | |
| FLQi080 » | Boiler and FGT/WAND4 | -3,881 | 32,318 | |
| FLQi085 » | Boiler NE1 low | -5,048 | 32,319 | |
| FLQi220 » | Boiler NE1 door | -5,377 | 32,32 | |
| FLQi023 » | Waste bunker /WAND3 | -5,86 | 32,321 | |
| FLQi209 » | Turbine louveres NE | -5,982 | 32,321 | |
| FLQi208 » | Turbine door | -7,142 | 32,322 | |
| FLQi213 » | Elec louveres1 | -7,711 | 32,322 | |
| FLQi010 » | Turbine hall /WAND4 | -7,735 | 32,323 | |
| FLQi079 » | Boiler and FGT/WAND3 | -7,8 | 32,323 | |
| FLQi214 » | Elec louveres 2 | -7,828 | 32,323 | |
| FLQi078 » | Boiler and FGT/WAND2 | -7,965 | 32,324 | |
| FLQi216 » | Elec louveres 3 | -7,967 | 32,324 | |
| FLQi013 » | Turbine hall /DACH | -8,503 | 32,325 | |
| | Somme | | 32,327 | |


| IPkt002 » | ESR2 | x = 623,00 m | y = 191,00 m | z = 1,50 m |
|-----------|----------------------|--------------|--------------|------------|
| | | L r,i,A | L r,A | |
| EZQi003 » | ACC 2 | 24,406 | 24,406 | |
| EZQi002 » | ACC 1 | 24,383 | 27,405 | |
| EZQi015 » | Extractor turbine 1 | 24,028 | 29,047 | |
| EZQi016 » | Extractor turbine 2 | 18,88 | 29,446 | |
| EZQi014 » | extractor water hall | 18,007 | 29,747 | |
| EZQi001 » | Stack | 16,59 | 29,952 | |
| EZQi009 » | Cooler 5 | 15,386 | 30,101 | |
| EZQi010 » | Cooler 6 | 15,359 | 30,245 | |
| EZQi005 » | Cooler 1 | 15,341 | 30,383 | |
| EZQi011 » | Cooler 7 | 15,326 | 30,516 | |
| EZQi006 » | Cooler 2 | 15,318 | 30,646 | |
| EZQi007 » | Cooler 3 | 15,29 | 30,77 | |
| FLQi224 » | Boiler louvres out2 | 11,374 | 30,82 | |
| FLQi084 » | Boiler and FGT /DACH | 9,295 | 30,851 | |
| FLQi223 » | Boiler louvres out1 | 9,02 | 30,879 | |
| FLQi221 » | Boiler NE1 louvres | 8,765 | 30,906 | |
| FLQi204 » | Step up transf/WAND3 | 8,449 | 30,93 | |
| FLQi063 » | Bottom ash /DACH | 7,633 | 30,95 | |
| FLQi208 » | Turbine door | 7,467 | 30,97 | |
| FLQi219 » | Bottom ash door | 6,068 | 30,984 | |
| FLQi222 » | Boiler NE3 louvres | 5,995 | 30,998 | |
| FLQi217 » | Water louvres | 5,81 | 31,011 | |
| FLQi081 » | Boiler and FGT/WAND5 | 4,439 | 31,02 | |
| FLQi088 » | Boiler SW low | 3,646 | 31,028 | |
| FLQi209 » | Turbine louvres NE | 3,481 | 31,036 | |
| FLQi180 » | Compressor /DACH | 3,322 | 31,043 | |
| FLQi082 » | Boiler and FGT/WAND6 | 3,081 | 31,05 | |
| FLQi077 » | Boiler and FGT/WAND1 | 2,819 | 31,057 | |
| FLQi026 » | Waste bunker /WAND6 | 2,255 | 31,062 | |
| FLQi022 » | Waste bunker /WAND2 | 1,741 | 31,067 | |
| FLQi041 » | Water treatmen/WAND1 | 1,54 | 31,072 | |
| FLQi175 » | Compressor /WAND2 | 1,43 | 31,077 | |
| FLQi080 » | Boiler and FGT/WAND4 | 1,41 | 31,082 | |
| EZQi017 » | Extractor elec 1 | 0,929 | 31,086 | |
| EZQi018 » | Extractor elec 2 | 0,864 | 31,09 | |
| FLQi060 » | Bottom ash /WAND3 | 0,769 | 31,094 | |
| EZQi019 » | Extractor elec 3 | 0,736 | 31,098 | |
| FLQi079 » | Boiler and FGT/WAND3 | 0,698 | 31,102 | |
| FLQi078 » | Boiler and FGT/WAND2 | -0,866 | 31,105 | |
| FLQi085 » | Boiler NE1 low | -0,921 | 31,107 | |
| FLQi023 » | Waste bunker /WAND3 | -1,19 | 31,11 | |
| FLQi045 » | Water treatment/DACH | -1,679 | 31,112 | |
| FLQi218 » | Water door | -2,03 | 31,114 | |
| EZQi013 » | extractor Compressor | -2,075 | 31,117 | |
| FLQi013 » | Turbine hall /DACH | -2,153 | 31,119 | |
| FLQi025 » | Waste bunker /WAND5 | -2,752 | 31,12 | |
| FLQi028 » | Waste bunker /DACH | -3,055 | 31,122 | |
| FLQi225 » | Boiler louvres out3 | -3,623 | 31,123 | |
| FLQi003 » | Tipping hall /WAND3 | -4,134 | 31,125 | |
| FLQi059 » | Bottom ash /WAND2 | -4,325 | 31,126 | |
| FLQi210 » | Turbine Louvres SE | -4,856 | 31,127 | |
| FLQi226 » | Compressor door | -5,139 | 31,128 | |
| FLQi220 » | Boiler NE1 door | -5,14 | 31,129 | |
| FLQi008 » | Turbine hall /WAND2 | -5,259 | 31,13 | |
| FLQi061 » | FGT SW bottomashconv | -5,457 | 31,131 | |
| FLQi044 » | Water treatmen/WAND4 | -6,057 | 31,132 | |
| FLQi086 » | Boiler NE2 low | -6,072 | 31,133 | |
| FLQi007 » | FGT big bag zone NE | -6,331 | 31,134 | |
| FLQi179 » | Compressor /WAND6 | -6,831 | 31,134 | |
| FLQi009 » | Turbine hall /WAND3 | -6,896 | 31,135 | |
| FLQi087 » | Boiler NE3 low | -7,014 | 31,136 | |
| FLQi227 » | Compressor louvres | -9,114 | 31,136 | |
| FLQi012 » | FGT big bag zone NW | -9,182 | 31,136 | |
| FLQi213 » | Elec louvres1 | -9,697 | 31,137 | |
| FLQi214 » | Elec louvres 2 | -9,786 | 31,137 | |
| FLQi216 » | Elec louvres 3 | -9,845 | 31,137 | |
| FLQi010 » | Turbine hall /WAND4 | -9,964 | 31,138 | |
| FLQi211 » | Elec TR12 door | -10,225 | 31,138 | |
| FLQi212 » | Elec TR11 door | -10,319 | 31,138 | |
| FLQi215 » | Elec MVdis door | -10,348 | 31,139 | |
| | Somme | | 31,141 | |

| IPkt003 » | ESR3 | x = 281,00 m L r,i,A | y = 805,00 m L r,A | z = 1,50 m |
|-----------|----------------------|-------------------------|-----------------------|------------|
| EZQi003 » | ACC 2 | 22,519 | 22,519 | |
| EZQi002 » | ACC 1 | 22,456 | 25,498 | |
| EZQi014 » | extractor water hall | 21,169 | 26,862 | |
| FLQi221 » | Boiler NE1 louvres | 15,837 | 27,192 | |
| FLQi222 » | Boiler NE3 louvres | 14,671 | 27,429 | |
| EZQi001 » | Stack | 14,448 | 27,642 | |
| EZQi011 » | Cooler 7 | 10,777 | 27,731 | |
| EZQi010 » | Cooler 6 | 10,77 | 27,817 | |
| EZQi007 » | Cooler 3 | 10,768 | 27,902 | |
| EZQi009 » | Cooler 5 | 10,763 | 27,985 | |
| EZQi006 » | Cooler 2 | 10,761 | 28,067 | |
| EZQi005 » | Cooler 1 | 10,753 | 28,146 | |
| FLQi217 » | Water louvres | 9,155 | 28,201 | |
| EZQi017 » | Extractor elec 1 | 8,767 | 28,25 | |
| FLQi180 » | Compressor /DACH | 8,417 | 28,295 | |
| FLQi224 » | Boiler louvres out2 | 8,115 | 28,336 | |
| FLQi045 » | Water treatment/DACH | 7,231 | 28,37 | |
| FLQi084 » | Boiler and FGT /DACH | 6,486 | 28,398 | |
| EZQi015 » | Extractor turbine 1 | 6,182 | 28,424 | |
| FLQi223 » | Boiler louvres out1 | 6,02 | 28,449 | |
| EZQi019 » | Extractor elec 3 | 5,91 | 28,473 | |
| EZQi018 » | Extractor elec 2 | 5,868 | 28,497 | |
| EZQi016 » | Extractor turbine 2 | 5,725 | 28,52 | |
| FLQi041 » | Water treatmen/WAND1 | 4,758 | 28,538 | |
| FLQi209 » | Turbine louvres NE | 4,249 | 28,554 | |
| FLQi210 » | Turbine Louvres SE | 4,171 | 28,57 | |
| FLQi208 » | Turbine door | 4,001 | 28,585 | |
| FLQi028 » | Waste bunker /DACH | 3,298 | 28,598 | |
| FLQi077 » | Boiler and FGT/WAND1 | 2,654 | 28,609 | |
| FLQi085 » | Boiler NE1 low | 2,182 | 28,619 | |
| EZQi013 » | extractor Compressor | 1,942 | 28,628 | |
| FLQi220 » | Boiler NE1 door | 1,855 | 28,637 | |
| FLQi022 » | Waste bunker /WAND2 | 1,395 | 28,645 | |
| FLQi225 » | Boiler louvres out3 | 1,319 | 28,653 | |
| FLQi218 » | Water door | 1,118 | 28,661 | |
| FLQi175 » | Compressor /WAND2 | 0,749 | 28,668 | |
| FLQi081 » | Boiler and FGT/WAND5 | 0,502 | 28,675 | |
| FLQi213 » | Elec louvres1 | 0,429 | 28,681 | |
| FLQi079 » | Boiler and FGT/WAND3 | -0,031 | 28,687 | |
| FLQi063 » | Bottom ash /DACH | -0,062 | 28,693 | |
| FLQi059 » | Bottom ash /WAND2 | -0,181 | 28,699 | |
| FLQi044 » | Water treatmen/WAND4 | -0,253 | 28,704 | |
| FLQi087 » | Boiler NE3 low | -0,913 | 28,709 | |
| FLQi080 » | Boiler and FGT/WAND4 | -1,242 | 28,713 | |
| FLQi023 » | Waste bunker /WAND3 | -1,527 | 28,717 | |
| FLQi216 » | Elec louvres 3 | -2,45 | 28,721 | |
| FLQi214 » | Elec louvres 2 | -2,492 | 28,724 | |
| FLQi179 » | Compressor /WAND6 | -2,572 | 28,727 | |
| FLQi078 » | Boiler and FGT/WAND2 | -2,658 | 28,73 | |
| FLQi086 » | Boiler NE2 low | -4,024 | 28,733 | |
| FLQi204 » | Step up transf/WAND3 | -4,146 | 28,735 | |
| FLQi211 » | Elec TR12 door | -4,436 | 28,737 | |
| FLQi005 » | Tipping hall /DACH | -4,454 | 28,739 | |
| FLQi008 » | Turbine hall /WAND2 | -4,913 | 28,741 | |
| FLQi215 » | Elec MVdis door | -5,138 | 28,743 | |
| FLQi212 » | Elec TR11 door | -5,157 | 28,744 | |
| FLQi219 » | Bottom ash door | -5,262 | 28,746 | |
| FLQi027 » | Waste bunker /WAND7 | -5,344 | 28,748 | |
| FLQi007 » | FGT big bag zone NE | -5,52 | 28,749 | |
| FLQi009 » | Turbine hall /WAND3 | -6,576 | 28,751 | |
| FLQi004 » | Tipping hall /WAND4 | -7,501 | 28,752 | |
| FLQi013 » | Turbine hall /DACH | -7,634 | 28,753 | |
| FLQi083 » | Boiler and FGT/WAND7 | -7,671 | 28,754 | |
| FLQi207 » | Tipping hall doors | -7,956 | 28,755 | |
| FLQi012 » | FGT big bag zone NW | -8,052 | 28,756 | |
| FLQi088 » | Boiler SW low | -8,363 | 28,756 | |
| FLQi226 » | Compressor door | -8,447 | 28,757 | |
| FLQi029 » | Elec TR11 -12 | -8,944 | 28,758 | |
| FLQi082 » | Boiler and FGT/WAND6 | -10,014 | 28,759 | |
| FLQi178 » | Compressor /WAND5 | -10,104 | 28,759 | |
| | Somme | | 28,762 | |

7 Results acoustic modelling


7.1 Plant area night time - Plant in normal operation

Keighley E.IPR



7.2 Results acoustic modelling in the neighbourhood night- Plant in normal operation

Keighley E.IPR



8 Calculations results - Calculated noise level summary - Night time - Plant in normal operation

Calculation hypothesis are described in chapter 1.

Calculation method following ISO 9613.

Ground effect G=0,5 ; mixed ground between absorbant and reverberant ground

Calculation file Keighley E.IPR

Acoustic power level for the outdoor equipment:

Total air cooled condenser PWL = 91dB(A)
 Total turbine coolers PWL = 90,7dB(A)
 One stack PWL = 82,5dB(A)

All these mitigation actions have to be done to reach the following calculated results:

- On South East and on south west Bottom Ash Hall walls, an acroter height 4,5m
- All the Louvers are acoustic Louvers for all the rooms
- Walls in double skin - See § 5 for attenuation - Walls Kingspan KS1000 R/W 40 (9W)
- Roofs in double skin - See § 5 for attenuation - Roof in Kingspan KS1000/RW27 40mm
- More efficient silencer before stack outlet

Predicted plant noise level (permanent noise sources excluding road traffic modification)

Night calculation results at receptors in dB(A):

| | | | |
|------|--|----------|------------|
| ESR1 | 6 The Croft, Thwaites, Keighley | BD21 4ND | 32,3 dB(A) |
| ESR2 | 3 Marley Cottages, Aire Valley Road , Keighley | BD21 4LT | 31,1 dB(A) |
| ESR3 | 224 Bradford Road Riddlesden , Keighley | BD20 5JT | 28,8 dB(A) |

At sensitive receptors:

| | ACC | Boiler and FGT Hall | Bunker hall & tipping hall | Compress or room | Coolers | Air extractors | Stack | Step up transformer | Turbine hall | Rest of the Plant | Total |
|------|------|---------------------|----------------------------|------------------|---------|----------------|-------|---------------------|--------------|-------------------|-------|
| ESR1 | 15,0 | 23,8 | 23,7 | 23,8 | 23,9 | 25,5 | 19,9 | 19,2 | 2,1 | 22,5 | 32,3 |
| ESR2 | 27,4 | 17,5 | 7,5 | 6,3 | 23,1 | 26,0 | 16,6 | 8,4 | 9,7 | 12,8 | 31,1 |
| ESR3 | 25,5 | 19,8 | 7,3 | 9,6 | 18,5 | 21,9 | 14,4 | -4,1 | 9,3 | 13,9 | 28,8 |

Predicted plant noise level (permanent noise sources excluding road traffic modification)

including margin for uncertainties concerning wind direction and topography.

Night calculation results at receptors in dB(A):

| | | | |
|------|--|----------|------------|
| ESR1 | 6 The Croft, Thwaites, Keighley | BD21 4ND | 32,8 dB(A) |
| ESR2 | 3 Marley Cottages, Aire Valley Road , Keighley | BD21 4LT | 33,1 dB(A) |
| ESR3 | 224 Bradford Road Riddlesden , Keighley | BD20 5JT | 30,8 dB(A) |

9 Measured background noise level

From Document 13_04217_FUL-REVISED_-_CHAPTER_13_-_NOISE__APPENDIX_7_-3871570.pdf
and
Appendix 13.1 - noise levels.pdf

Definition of the receptors:

| | | |
|------|--|----------|
| ESR1 | 6 The Croft, Thwaites, Keighley | BD21 4ND |
| ESR2 | 3 Marley Cottages, Aire Valley Road , Keighley | BD21 4LT |
| ESR3 | 224 Bradford Road Riddlesden , Keighley | BD20 5JT |

Results of the noise monitoring:

Night time

| | |
|------|-------------|
| | LA90 30 min |
| ESR1 | 38,1 |
| ESR2 | 44,6 |
| ESR3 | 36,5 |

Day time

| | |
|------|----------------------------|
| | Min figure for LA90 30 min |
| ESR1 | 44,3 |
| ESR2 | 57,3 |
| ESR3 | 46 |

[This document also specify that :](#)

"Environmental Health usually asks for a specific noise of 5dB(A) below existing background.

10 Conclusions

The calculation hypothesis are all described in paragraph 1.

All these mitigation actions have to be done to reach the following calculated results:

- On South East and on south west Bottom Ash Hall walls, an acroter height 4,5m
- All the Louvers are acoustic Louvers for all the rooms
- Walls in double skin - See § 5 for attenuation - Walls Kingspan KS1000 R/W 40 (9W)
- Roofs in double skin - See § 5 for attenuation - Roof in Kingspan KS1000/RW27 40mm
- More efficient silencer before stack outlet

Calculation method following ISO 9613.

10.1 Plant noise level (permanent noise sources excluding road traffic modification)

Night time acoustic pressure at receptors

| | Global calculated level | |
|---------------|-------------------------|--|
| Location ESR1 | 32,8 | 6 The Croft, Thwaites, Keighley |
| Location ESR2 | 33,1 | 3 Marley Cottages, Aire Valley Road , Keighley |
| Location ESR3 | 30,8 | 224 Bradford Road Riddlesden , Keighley |

10.2 Night-time BS 4142

| | Measured minimum residual noise LA90 Planning requirement | Predicted plant noise level | Difference | |
|---------------|---|-----------------------------|------------|--|
| Location ESR1 | 38,1 | 32,8 | -5,3 | 6 The Croft, Thwaites, Keighley |
| Location ESR2 | 44,6 | 33,1 | -11,5 | 3 Marley Cottages, Aire Valley Road , Keighley |
| Location ESR3 | 36,5 | 30,8 | -5,7 | 224 Bradford Road Riddlesden , Keighley |

10.3 Day-time BS 4142

| | Measured minimum residual noise LA90 Planning requirement | Predicted plant noise level | Difference | |
|---------------|---|-----------------------------|------------|--|
| Location ESR1 | 44,3 | 37,8 | -6 | 6 The Croft, Thwaites, Keighley |
| Location ESR2 | 57,3 | 38,1 | -19 | 3 Marley Cottages, Aire Valley Road , Keighley |
| Location ESR3 | 46 | 35,8 | -10 | 224 Bradford Road Riddlesden , Keighley |

10.4 Conclusions following BS4142

BS4142 states:

“A difference of around 10dB or higher indicates that complaints are likely. A difference of around 5dB is of marginal significance. A difference of -10dB is a positive indication that complaints are unlikely”.

With reference to the above, Table 10.2 details the BS4142 for fixed plant associated with the proposed EfW development during **night-time**.

The table indicates that noise levels generated by fixed plant will lead to:

- a situation between marginal significance and complaints unlikely at:
6 The Croft, Thwaites, Keighley and 224 Bradford Road Riddlesden , Keighley
- a situation giving a positive indication that complaints are unlikely at :
3 Marley Cottages, Aire Valley Road , Keighley

Table 11.3 details the BS4142 for fixed plant associated with the proposed EfW development during **Day** operations (excluding road noise traffic modification). The table indicates that noise levels generated by fixed plant will lead to:

- a situation between marginal significance and complaints unlikely at:
6 The Croft, Thwaites, Keighley
- a situation giving a positive indication that complaints are unlikely at :
3 Marley Cottages, Aire Valley Road , Keighley and 224 Bradford Road Riddlesden , Keighley