

		Sheet No:	2 of 2	Project No:	WIE18671
Project Title:	Canford EfW Facility	By:	S Whelan	Date:	02/08/2022
Calculations Title:	Proposed Foul Flow Estimate	Checked:	B McCarthy	Date:	02/08/2022

		Dry Weather Flow Rate (per day)	Source	Number of	Factor	Profile (hours)	Peak Flow Rate (litres/second)
Residential					2.12	24	
Existing property =	160 litres/person/day	400.0 litres per unit	Thames Water Guidelines (2016)	0 existing units			0.0
New property =	125 litres/person/day	312.5 litres per unit	Thames Water Guidelines (2016)	0 proposed units			0.0
Occupancy =	2.5 persons						
Hotel		500.0 litres per room	British Water (2013)	0 rooms	3	24	0.0
Student Accommodation		200.0 litres per bed	Thames Water Guidelines (2016)	0 beds	3	24	0.0
Offices		750.0 litres per 100m ²	Jones (1992)	0 m ²	3	10	0.0
Retail		400.0 litres per 100m ²	Jones (1992)	0 m ²	3	12	0.0
Cinema		10.0 litres per seat	Jones (1992)	0 seats*	3	8	0.0
Health Club/Sports Centre		50.0 litres per customer	British Water (2013)	0 customers**	3	16	0.0
Day School		90.0 litres per pupil	British Water (2013)	0 pupils	3	10	0.0
Boarding School		175.0 litres per pupil	British Water (2013)	0 pupils	3	24	0.0
Hospital		625.0 litres per bed	Jones (1992)	0 beds	3	24	0.0
Nursing Home		350.0 litres per bed	British Water (2013)	0 beds	3	24	0.0
Restaurant		30.0 litres per cover	British Water (2013)	0 covers	3	8	0.0
Pub/Club		15.0 litres per customer	Butler and Davies (2004)	0 customers***	3	12	0.0
Warehouse		150.0 litres per 100m ²	Jones (1992)	0 m ²	3	12	0.0
Manufacturing		550.0 litres per 100m ²	Jones (1992)	9135 m ²	3	12	3.5
Commercial		300.0 litres per 100m ²	Jones (1992)	0 m ²	3	12	0.0
SUB TOTAL							3.5
Infiltration percentage	10%						0.3
TOTAL							3.8

* Foul flow rate needs to be calculated based on number of seats. An allowance of 4m² has been made for each seat.

1606 m² Floor area =

4 m² per person

4 m² per person

** Foul flow rate needs to be calculated based on number of customers. An allowance of 4m² has been made for each customer.

Floor area = 0 m²

*** Foul flow rate needs to be calculated based on number of customers. An allowance of 4m² has been made for each customer.

Floor area = 0 m^2 $4 \text{ m}^2 \text{ per person}$