



MARTIN GmbH

Stoker capacity diagram Avonmouth / GB


Draft


Document number: 00-051576-P0010-V9

Processed by: FuE-SM

Date: 23.08.2022

Number of runs: V - 3
 Grate width: 7,820 m
 Grate area: 55,6 m²
 Number of steps: 13

 Normal load range

 Range for control fluctuations
(set point specification not permitted!)

 Potential Overload Cases (*)


(*) Load cases are just a theoretical calculations without having checked the peripheral plant components (feed water pumps, safety valves, etc.) for their suitability and power reserves. The actual feasibility must be evaluated in a feasibility study

