DISCHARGE TO PUBLIC SEWER. SW1

64m x 6m x 1.25m DEEP ATTENUATION TANK TO STORE EXCESS VOLUME FROM FINAL CAMPUS FLOW RESTRICTION.

LOCATION OF AQUA FILTER, ON FINAL OUTFALL FROM SITE.

41m x 8m x 1m DEEP ATTENUATION TANK TO STORE EXCESS VOLUME FROM KLON01 FLOW RESTRICTION.

S9A FITTED WITH HYDROBRAKE TO LIMIT OFFSITE FLOW RATES TO 11.8l/s.

DC1-4 FITTED WITH HYDROBRAKE TO LIMIT KLON01 FLOW RATES TO 4l/s.

26m x 10m x 1m DEEP & 52m x 7m x 1m DEEP ATTENUATION TANKS TO STORE EXCESS VOLUME FROM KLON02 FLOW RESTRICTION.

HB1 FITTED WITH HYDROBRAKE TO LIMIT KLON02 FLOW RATES TO 3l/s.

SPEL FORECOURT SEPARATOR PROTECTS SURFACE WATER NETWORK FROM SPILLAGES IN GENERATOR FUELING AREA, HATCHED GREEN.

HB1 FITTED WITH HYDROBRAKE TO LIMIT KLON03 FLOW RATES TO 3l/s.

55m x 3m x 1m DEEP & 61m x 7m x 1m DEEP ATTENUATION TANKS TO STORE EXCESS VOLUME FROM KLON03 FLOW RESTRICTION.

SPEL FORECOURT SEPARATOR PROTECTS SURFACE WATER NETWORK FROM SPILLAGES IN GENERATOR FUELING AREA, HATCHED GREEN.

AREA NOT PART OF THE ENVIRONMENTAL PERMIT APPLICATION.

DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS TO BE CHECKED ON SITE.
THIS DRAWING IS SUBJECT TO REVISION. PLEASE CHECK THE CURRENT VERSION OF THIS DRAWING PRIOR TO USE.
THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE RELEVANT SPECIFICATIONS AND CONTRACT DOCUMENTATION.

CDM REGULATIONS 2015 RESIDUAL HAZARDS

RESIDUAL HAZARDS IDENTIFIED ⚠

CONSTRUCTION

1. NO SIGNIFICANT RESIDUAL HAZARDS BEYOND THOSE KNOWN TO AN EXPERIENCED CONTRACTOR.

FUTURE DEMOLITION

A. NO SIGNIFICANT RESIDUAL HAZARDS BEYOND THOSE KNOWN TO AN EXPERIENCED CONTRACTOR.

THIS REGISTER IS A NON-EXHAUSTIVE LIST OF RESIDUAL HAZARDS RELATING TO THE WORKS SHOWN ON THIS DRAWING THAT HAVE BEEN IDENTIFIED DURING THE DESIGN STAGE.

IT IS ASSUMED THAT ALL WORKS WILL BE CARRIED OUT BY A CONTRACTOR WITH THE APPROPRIATE SKILLS, KNOWLEDGE & EXPERIENCE, AND IF THEY ARE AN ORGANISATION, THE ORGANISATIONAL CAPABILITY NECESSARY TO FULFILL THE ROLE.

Rev	Drawn By	Date	Chkd By	Date	Apprvd By	Date
P02	MH	06.12.24	MH	06.12.24	MH	06.12.24
P01	MH	20.11.24	HJ	20.11.24	HJ	20.11.24

P02 FORMATTING UPDATED FOLLOWING COMMENTS RECEIVED.
P01 PRELIMINARY ISSUE.

Revisions

abstruct consulting
Structural & Civil Engineers
The Highland Suite, Great Hollanden Business Centre,
Mill Lane, Underriver, Sevenoaks, Kent TN15 0SQ
T: 01732 838050 E: info@abstruct-consult.com www.abstruct-consult.com

Client

KAO DATA

Project

KAO DATA LONDON 03 (KLON03)

Drawing Title

CAMPUS WIDE KEY DRAINAGE ELEMENTS

Status S1 FOR INFORMATION

Scale 1:500 @A1 Proj.No. AC21329

Drawing No. KL03-ABS-XX-XX-DR-C-11002 Revision P02

© Copyright abstruct consulting