



Storage Area Details PART 2 OF 2

Plan Ref	Description	Storage type	Containment / type	Height of fire wall (m)	Max Width (m)	Max Length (m)	Max storage height (m)	Approx. Area (m ²)	Conversion factor used	Approx. volume (m ³)	Max storage time
AREA 12	Drained fluids from ELVs comprising, oil, break fluid and screen wash	Unprocessed (liquid)	Double skinned/bunded tanks	N/A	N/A	N/A	1	N/A	1	10,000 litres	<12 weeks
AREA 13	Drained fluids from ELVs petrol, diesel, oil, brake fluid and screen wash	Unprocessed (liquid)	Double skinned/bunded tanks	N/A	N/A	N/A	1	N/A	1	10,000 litres	<12 weeks
AREA 14	Containers of scrap metal	Sealed skip (40 cubic yard)	Sealed skip / concrete panel wall	4.8	6.1	2.44	2.62	15 (per container)	1	40 (per container)	<1 week
AREA 15	Depolluted ELVs awaiting baling	Processed / fully stripped ELV shell	Freestanding / concrete panel wall	4.8	1.85 (per ELV)	4.8 (per ELV)	1.5 (per ELV)	8.325 x 6 ELVs = 50	1	50	<12 hours
AREA 16	Waste vehicle parts	Removed from ELV	Freestanding pile / interlocking block wall	4.8	4	4	1.5	16 (per bay)	0.75	20 (per bay)	<1 week
AREA 17	Waste vehicle parts	Removed from ELV	Freestanding pile / interlocking block wall	4.8	4	4	1.5	16 (per bay)	0.75	20 (per bay)	<1 week
AREA 18	Baled depolluted ELVs & waste vehicle parts	Processed	As above	4.8	13	6.5	1	82	1	82	<1 week
AREA 19A & 19B	Waste tyres and alloys wheels	Removed from ELV	Free standing pile / three-sided interlocking block wall	4.8	13	7	1	91	0.75	68	<1 week



Oaktree Environmental Ltd
Waste, Planning and Environmental Consultants



DRAWING TITLE
SITE LAYOUT & FIRE PLAN (PART 2 OF 2)

CLIENT
Assington Autos Ltd

PROJECT/SITE
The Breakers Yard, Barracks Road, Assington CO10 5LP

SCALE @ A1
1:250

CLIENT NO
3041

JOB NO
001

DRAWING NUMBER
BAR/3041/03B

REV
A

STATUS
Issued

DRAWN BY
CP

CHECKED
AAL

DATE
20.04.23

NOTES
Drawing for indication only. Reproduced with the permission of the controller of H.M.S.O. Crown copyright licence No. 100022432. This drawing is copyright and property of Oaktree Environmental Ltd.

REVISION HISTORY

Rev:	Date:	Init:	Description:
-	07.04.22	CP	Application copy
A	20.04.23	CP	Updated site layout + infrastructure improvements