

Provide the following details with regards to all oil storage tanks on the installation. Describe the tanks, their volume, construction and how they will comply with the oil storage regulations and CIRIA C736. Where the tanks do not comply with any standards please make this clear.

Oil storage regulations - <https://www.gov.uk/guidance/storing-oil-at-a-home-or-business> .
CIRIA 737 - https://www.countydrains.co.uk/user_uploads/files/CIRIA%20C736-Containment%20systems%20%20for%20the%20prevention%20of%20%20pollution-s.pdf

There is one oil storage tank of site (drawing attached).

The tank is a mild steel double skinned tank with a capacity of 45m³ of fuel oil.

The tank is not bunded and therefore does not comply with the oil storage regulations which does not allow the double skin as secondary containment.

The tank is in an area where any spillage would be contained within the site drainage system so would not enter any water course but would lead to a significant clear up cost in the yard / drain system / waste water treatment plant