

Finally, could you please confirm the following:

- Does the AD Plant have a Grid connection and export electricity to the national grid?

The AD Plant has two grid connections which are located on our site and exports electricity through both of them should the Konings factory not use the electricity being generated at that time. We track the amount of electricity exported as it has an impact on how much electricity we pay for.

- Does anyone else discharge to the lagoon other than Konings?

The farm surface water drains run into the lagoon at a different entry point to the Konings discharge point