


## 9. APPENDIX: GRATE DIAGRAM

 <b>MARTIN GmbH</b>	<h3>Stoker capacity diagram</h3> <h3>Beddington SLWP</h3>	Document number: 00-051122-P0010-V4
		Processed by: Her / PA2
		Date: 05.06.2012

Number of runs: 3  
 Grate width: V - 6,320 mm  
 Grate area: 44.9 m<sup>2</sup>  
 Number of steps: 13



normal load



Range for control fluctuations  
 (set point specification not permitted!)

