

Our ref: AC/AS/ST20075 /008
Your ref: EPR/XP3434HX/V013

Date: 2nd April 2024

Jonty Bates
Aqua House
20 Lionel Street
Birmingham
B31AQ

Dear Jonty

Information Request Response EPR/XP3434HX/V013

With regards the request for further information you sent, dated 22nd March 2024, for the Shelford Landfill Materials Recycling Facility. Please find below our response to your questions. The questions have been replicated below in ***bold italics*** for clarity with our response directly below.

An updated version of the Fire prevention Plan, Dust Management Plan and Odour Management Plan are attached to this response.

All plans and supporting documents

I note from ECL.9592.R05.001 Shelford MRF Drainage Strategy (attached to the FPP) that the site plans have been updated to reflect the constructed MRF rather than the proposed structure and internal lay out. At the end of the FPP before the aforementioned document, is pages 1 and 2 of SHF-MRF2000, which show the proposed facility and do not reflect the updated plans. Further, the DEMP has SHF247 appended to the document, which also shows the proposed facility. Please update these documents to reflect the as-built MRF.

An updated version of drawing SHF247 has been attached to the FPP and DEMP.

An updated version of drawing SHF-MRF2000 has been attached to the FPP.

I do not believe that any of the other management plans contain plans showing the proposed MRF, but please ensure all management plans are updated accordingly where the proposed MRF is represented instead of the constructed facility along with any key information relevant to the specific plan shown.

FPP



Wardell Armstrong is the trading name of Wardell Armstrong LLP, Registered in England No. OC307138.

Registered office: Sir Henry Doulton House, Forge Lane, Etruria, Stoke-on-Trent, ST1 5BD, United Kingdom

UK Offices: Stoke-on-Trent, Birmingham, Bolton, Bristol, Bury St Edmunds, Cardiff, Carlisle, Edinburgh, Glasgow, Leeds, London, Newcastle upon Tyne and Truro. International Office: Almaty.

ENERGY AND CLIMATE CHANGE
ENVIRONMENT AND SUSTAINABILITY
INFRASTRUCTURE AND UTILITIES
LAND AND PROPERTY
MINING AND MINERAL PROCESSING
MINERAL ESTATES
WASTE RESOURCE MANAGEMENT



Thank you for attaching the Drainage Strategy showing the site drainage. However, the FPP references:

- **60,000 litres of water storage; and,**
- **Mains access for refilling the tanks in the event of prolonged active fire fighting.**

The water tanks are shown on SHF247 but it is not clear where these are located on any of the updated plans showing the constructed MRF. Please include these in the updated plans so it is clear where these are located as referenced in section 5.4 of the FPP. Page 1 of SHF-MRF-2000, which is at a smaller scale, showing the relevant section of the site does not show a hydrant or mains connection (as you have indicated in Information Request Response EPR/XP3434HX/V013). If this cannot be shown due to scale, please include information about where this is located and/or accessed as it is indicated as a means of supply during active firefighting in section 5.4.

Water supply details are in Section 5.4.5 of the FPP and these features are on Drawing SHF-MRF2000. There are no hydrants in close proximity to the site and that is why they have not been included as a viable water supply option in the FPP

An updated version of drawing SHF247 has been attached to the FPP.

I note that the FPP does have SHF118 also attached, which shows the layout as constructed; however, this does not contain any of the safety and induction information as shown in SHF-MRF2000. As such, it is not clear where these safety measures are located in the as-built facility plan considering the internal layout has changed. Please provide an updated plan with these same measures shown in situ.

An updated version of drawing SHF-MRF2000 has been attached to the FPP.

OMP

Please incorporate the specific good housekeeping measures, as outlined in Information Request Response EPR/XP3434HX/V013, into section 5 of the OMP (MRF Odour Controls) or please refer to the relevant section of the Operating Techniques where these measures are outlined.

Please find attached, these have been added into Section 5 as requested.



**Yours sincerely
for Wardell Armstrong LLP**

**ALISON COOK
Technical Director
acook@wardell-armstrong.com**