


APPROVAL FORM

1.1.F03
Issue 3 (Oct 2004)

Document Title :	Crayford Discharge Consent S/WR 0965 dated 07/05/2004	
Issue Number :	One	(detail revisions below)
Issue Date	21/12/07.	
Approved	Signatory One	Signatory Two
Signed :		
Name :	S P Hodges	H Holland
Position :	Director of Engineering	Management Systems Administrator
Date :	21/12/07	21/12/07.

Document History

Issue No	Details	Issue Date	Initial
Issue 2			
Issue 3			
Issue 4			
Issue 5			
Issue 6			
Issue 7			
Issue 8			
Issue 9			
Issue 10			

If document attached is a CONTROLLED DOCUMENT, include Registration Stamp & Binder Number:

**MASTER
COPY**



**ENVIRONMENT
AGENCY**

Consent to Discharge

Water Resources Act 1991 (as amended by the Environment Act 1995)

Consent Holder(s)

**Grosvenor Waste Management Ltd
Century Wharf
Crayford Creek
Crayford
Kent
DA1 4QG**

Consent to Discharge from

**Grosvenor Waste Management Ltd.
Century Wharf
Crayford Creek
Crayford
Kent
DA1 4QG**


Consent Number

S/WR 0965

Environment Agency Thames Region, SE Area

Swift House, Frimley Business Park, Frimley, Camberley, Surrey, GU16 7SQ

Tel: 01276 454300 Fax: 01276 454301



Consent to Discharge

Water Resources Act 1991
Section 88, Schedule 10
(as amended by the
Environment Act 1995)



**ENVIRONMENT
AGENCY**

Consent to Discharge

Consent Number

S/WR 0965

To: ("the Consent Holder")

**Grosvenor Waste Management Ltd
Century Wharf
Crayford Creek
Crayford
Kent
DA1 4QG**

The Environment Agency ("the Agency") in pursuance of its powers under the Water Resources Act 1991 (as amended by the Environment Act 1995) hereby consents to the making of a discharge:

Of:

Trade effluent consisting of site drainage ("the Discharge")

From:

A Waste Transfer Station

At:

**Grosvenor Waste Management Ltd., Century Wharf, Crayford Creek,
Crayford, Kent, DA1 4QG**

To:

Crayford Creek

Subject to the conditions set out in this notice of Consent to Discharge.

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991 (as amended by the Environment Act 1995), no notice shall be served by the Agency, altering this consent, without the agreement of the Consent Holder, during a period of 4 years from the date this notice is issued.

This Consent is issued on: **07 MAY 2004**

This Consent takes effect on: **07 MAY 2004**

Signed

A handwritten signature in black ink, appearing to read 'L. Farmer'.

Louise Farmer, Team Leader Environment Management

1 Conditions of Consent for trade effluent consisting of site drainage

1.1 Nature

1.1.1 The Discharge shall consist solely of trade effluent consisting of site drainage.

1.2 Place of Discharge

1.2.1

The Discharge shall be made in the manner and at the place specified as:

- a discharging to Crayford Creek;
- b at National Grid Reference TQ 5295 7560;
- c shown marked "OUTLET" on Site Plan attached to this consent.

1.3 Sampling Point Requirements

1.3.1

A sample point shall be provided and maintained at National Grid Reference TQ 5295 7560 as shown marked "SAMPLE POINT" on the Site Plan attached to this consent, so that a representative sample of the Discharge may be obtained. The Consent Holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown that any sample of the Discharge taken at the said sampling point is a sample of what was discharging into controlled waters.

1.4 Composition

1.4.1

The Discharge shall not contain more than 100 milligrammes per litre of suspended solids (measured after drying at 105°C).

1.4.2

As far as is reasonably practicable, the site shall be operated so as to prevent the Discharge from containing any significant trace of visible oil or grease.

1.5 Works Operation

1.5.1

- a The oil separator shall be operated and the effluent treated in a manner which, so far as reasonably practicable, minimises the polluting effects of the Discharge on controlled waters.
- b This condition does not require any alteration of the type of treatment used from that specified in the application.

1.6 Maintenance

1.6.1

The oil separator shall be operated and maintained in accordance with good operational practice such that:

- a it remains fully operational except at times of unavoidable mechanical or electrical breakdown which shall be attended to, and the Agency informed of the failure, as soon as practicable after the failure;
- b following a failure all equipment shall be returned to normal operation as soon as practicable;
- c it shall be desludged at sufficient frequency and in such a manner to prevent excessive carryover of suspended solids.

1.7

Recording and Reporting

1.7.1

- a** The Consent Holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- b** On request the Consent Holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality
- c** The Consent Holder shall as soon as reasonably practicable report to the Agency all non-routine actions that may have adversely affected effluent quality.



**NOTIFICATION OF CHANGE
OF CONSENT HOLDER**

Consent: S/WR 0965

Name of present Holder:

Current Discharge address: Grosvenor Waste Management Ltd., Century Wharf, Crayford
Creek, Crayford, Kent DA1 4QG

1 Name of new Holder:

2 Address of new Holder:

3. Other alterations:

3. If the discharge is no longer being made and the consent is no longer required, please state why. For instance the premises may now be connected to the foul sewer.

Date of change:

Signed:

Name (BLOCK CAPITALS):

Please use this form to notify the Agency of any change regarding this discharge consent. If notification is not given within twenty-one days of any change, it is possible that the consent will lapse and you will not be entitled to make the discharge.

Please return the form to

Water Quality Consenting, Environment Agency, Thames Region, South East Area Office, Swift House, Frimley Business Park, Frimley, Camberley, Surrey, GU16 7SQ

If you need advice, please ring the Agency on (01276) 454300