

PAT Testing Logbook

Job No:

04

Page No:

3

of

3

Your PAT Testing Was Completed By:

Client Name: U B H Group

Date: 1.5.2025

Engineer: 1m

Client Address: U B H B1-3

Manuelway Business Park Swanscombe

Calibration Date: 1.5.2025

Equipment Make / Model:

Serial No:

Company: 1m
Contact: MICHELLE
Phone No: 07939997260

Asset No.	Appliance Description	Location	Re-Test Date	Visual ✓ or x	CLASS I		CLASS I & II		Extension Leads ✓ or x	Pass or Fail ✓ or x	Notes
					Earth Bond Ω	Insulation MΩ	Load/Earth Leakage Load A	Leakage mA			
0.45	AIR FRYER	KITCHEN 2	MAY 2026	✓	1.4	19.99	✓	0	✓	✓	
0.46	FRIDGE	"	"	✓	0.17	4.29	✓	0.1	✓	✓	
0.47	FREEZER	"	"	✓	0.17	19.99	✓	0.1	✓	✓	
0.48	WAFER OVEN	"	"	✓	0.2	17.99	✓	0	✓	✓	
0.49	SOCKETS	OFFICE 1	"	✓						✓	Passed
0.50	"	" 2	"	✓						✓	Passed
0.51	"	" 3	"	✓						✓	Passed
0.52	"	KITCHEN 1	"	✓						✓	Passed
0.53	"	" 2	"	✓						✓	Passed

PAT Testing Logbook

Job No:

014

Page No:

2

of

2

Your PAT Testing Was Completed By:

Client Name: UBH Group

Client Address: Unit B1-3 Meadow Business Park Swanscombe

Equipment Make / Model:

Serial No:

Calibration Date: 1.5.2025

Company: 1mf
Contact: MICHELE
Phone No: 09539991260

Date: 1.5.2025

Engineer: 1mf

Asset No.	Appliance Description	Location	Re-Test Date	Visual ✓ or x	CLASS I		CLASS I & II		Extension Leads ✓ or x	Pass or Fail ✓ or x	Notes
					Earth Bond Ω	Insulation MΩ	Load/Earth Leakage A	Leakage mA			
0.13	Power Tool	Workhouse 2	Mar 2026	✓	0.16	19.99	—	0.1	✓	✓	
0.24	"	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.25	"	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.26	"	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.27	"	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.28	Extension Lead	"	"	✓	0.21	19.99	—	0	✓	✓	
0.29	"	"	"	✓	0.21	19.99	—	0	✓	✓	
0.30	"	"	"	✓	0.21	19.99	—	0	✓	✓	
0.31	"	"	"	✓	0.21	19.99	—	0	✓	✓	
0.32	"	"	"	✓	0.21	19.99	—	0	✓	✓	
0.33	Power Tool	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.34	"	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.35	"	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.36	"	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.37	"	"	"	✓	0.16	19.99	—	0.1	✓	✓	
0.38	HEATER	Office 4	"	✓	0.21	19.99	—	0.1	✓	✓	
0.39	"	"	"	✓	0.21	19.99	—	0.1	✓	✓	
0.40	"	"	"	✓	0.21	19.99	—	0.1	✓	✓	
0.41	"	"	"	✓	0.21	19.99	—	0.1	✓	✓	
0.42	TV	"	"	✓	N/A	19.99	—	0.1	✓	✓	
0.43	COFFEE MACHINE	Kitchen 2	"	✓	0	17.48	—	0	✓	✓	
0.44	KESTLE BASE	"	"	✓	0.1	19.99	—	0	✓	✓	

PAT Testing Logbook

Job No:

04

Page No:

1

of

2

Your PAT Testing Was Completed By:

Client Name:

UBH Group

Date:

1.5.2025

Client Address:

Unit B1-3 Manorway Business Park Swanscombe

Engineer:

IMF

Serial No:

Calibration Date: 1.5.2025

Equipment Make / Model:

Company:

IMF

Contact:

Michael

Phone No:

07959997260

Asset No.	Appliance Description	Location	Re-Test Date	Visual ✓ or x	CLASS I & II				Extension Leads ✓ or x	Pass or Fail ✓ or x	Notes
					CLASS I		CLASS I & II				
					Earth Bond Ω	Insulation MΩ	Load/Earth Leakage Load A	Leakage mA			
001	HEATER	OFFICE	MAY 2026	✓	0.21	19.99					
002	LAMP FOR CHARGER	OFFICE	"	✓	0.2	19.99					
003	EXTENSION LEAD	OFFICE	"	✓	0.2	19.99	✓	0.1	✓	✓	
004	HEATER	OFFICE 2	"	✓	0.2	19.99					
005	PAINTER	OFFICE 2	"	✓	0.1	19.99					
006	LAMP FOR CHARGER	OFFICE 3	"	✓	N/A	19.99	✓	0.1	✓	✓	
007	EXTENSION LEAD	OFFICE 3	"	✓	0.2	19.99					
008	HEATER	OFFICE 3	"	✓	0.21	19.99					
009	LAMP	OFFICE 3	"	✓	0.4	19.99	✓	0.1			
010	LAMP FOR CHARGER	OFFICE 3	"	✓	0.2	19.99	✓	0.1	✓	✓	
011	KETTLE BASE	OFFICE 2	"	✓	0.1	19.99					
012	M. CROWAVE	OFFICE 2	"	✓	0.13	19.99	✓	0.68	✓	✓	
013	DISH WASHER	OFFICE 2	"	✓	0.17	19.99	✓	0.1	✓	✓	
014	FRIDGE	OFFICE 2	"	✓	0.17	19.99	✓	0.1	✓	✓	
015	HOOVER	WASHHOUSE 1	"	✓	N/A	19.99	✓	0.1	✓	✓	
016	VAC	WASHHOUSE 1	"	✓	N/A	19.99	✓	0.1	✓	✓	
017	PRO BOLE	"	"	✓	N/A	19.99	✓	0.1	✓	✓	
018	CHARGER 1	WASHHOUSE 2	"	✓	N/A	19.99	✓	0.1	✓	✓	
019	CHARGER 2	"	"	✓	N/A	19.99	✓	0.1	✓	✓	
020	CHARGER 3	"	"	✓	N/A	19.99	✓	0.1	✓	✓	
021	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
022	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
023	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
024	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
025	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
026	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
027	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
028	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
029	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
030	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
031	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
032	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
033	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
034	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
035	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
036	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
037	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
038	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
039	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
040	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
041	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
042	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
043	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
044	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
045	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
046	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
047	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
048	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
049	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
050	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
051	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
052	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
053	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
054	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
055	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
056	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
057	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
058	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
059	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
060	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
061	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
062	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
063	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
064	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
065	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
066	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
067	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
068	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
069	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
070	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
071	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
072	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
073	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
074	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
075	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
076	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
077	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
078	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
079	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
080	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
081	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
082	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
083	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
084	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
085	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
086	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
087	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
088	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
089	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
090	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
091	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
092	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
093	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
094	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
095	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
096	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
097	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
098	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
099	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
100	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
101	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
102	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
103	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
104	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
105	ADAPTER	"	"	✓	0.16	19.99	✓	0.1	✓	✓	
106											