

REPORT TO BE SENT TO:

Steven Wraith  
SC Johnson Professional Limited  
Denby Hall Way  
Derby Road  
Denby  
DE5 8JZ

## ANALYSIS REPORT

-----  
SAMPLING POINT CODE 9979097

SAMPLE FROM: SC Johnson Professional Limited  
Denby Hall Way  
Derby Road  
Denby  
DE5 8JZ

DESCRIPTION: Detergents

SAMPLE NUMBER: 1382127

SAMPLE DATE: 30/01/2023

SAMPLE TIME: 08:00:00

CHARGEABLE Y

SAMPLE METHOD: Spot

SAMPLE REASON: Routine Program

TAKEN BY : 487

-----

DETERMINAND	RESULT VALUE	UNITS	CONSENT LIMITS
SS	107	mg/l	IM 0: 2000
ANIONIC DETERGENTS	58.1	mg/l	
NON IONIC DETERGENTS	657.0	mg/l	
COD 1h settled	3440	mg/l	IM 0: 25000
Visual Quality (site test)	P		
Sampling Access (TE site test)	P		
PH	8.0	pH_unit	IM 6: 10

-----

REPORT DATE: 10/02/23

ENQUIRIES REGARDING THIS REPORT SHOULD

BE MADE TO:

TIM CLARK

07771 938672

tim.clark@severntrent.co.uk

SIGNED:

DATE: