

Thornton Le Moor Poultry Unit Standby Generator.

Thornton Le Moor Poultry Unit operations has a standby generator.

The generator has a thermal input of 250kwth.

Generator will not be tested more than 50hrs per annum.

Generator will not be operated more than 500hrs per annum averaged over 3 years, as backup for mains interruption, including testing.