



- Key:**
- Site Boundary
  - - - ACO Drain
  - Process Water Drainage Pipe
  - Subsurface Drainage Pipe
  - Subsurface Attenuation Tank
  - Fall of Surfacing
  - Penstock
  - Silt Trap
  - Petrol Interceptor
  - Surface Water Sewer
  - Foul Water Sewer
  - Impermeable Concrete Surfacing
  - RWT Rainwater Harvesting Tank
  - CWT Clean Water Tank
  - Fuel Storage Area
  - Oil Storage Area
  - X TED1 Emission Monitoring Location
  - X SW1 Emission Monitoring Location

- Notes:**
1. Clean roof water will be harvested, where possible, for re-use within the wet processing areas, fire / dust suppression and maintenance.
  2. Fuel storage area is sealed and double-bunded to prevent spillage.
  3. Monitoring locations also shown on Monitoring Plan.

Rev.	Details	Drawn Chkd.	Date
Project 203162 Wharf Road, Doncaster			
Title Drainage Plan			
<b>AA Environmental Ltd</b> Units 4-8 Cholswell Court Shippon Abingdon Oxon OX13 6HX T: (01235) 536042 F: (01235) 523849 info@aae-ltd.co.uk www.aae-ltd.co.uk			
Scale 1:500@A3	Date Dec '20	Drawn JM	Chkd. ML
Drg. No. 203162/D/004		Rev.	