



- Key:**
- Site Boundary
 - Fire Engine Route
 - Impermeable Concrete Surfacing
 - Fire Hydrant
 - Fixed / Mobile Plant Location
 - Fire Quarantine Area with 6 m Buffer
 - Fire Containment Area (FC1)
 - Inert Non-combustible Soils
 - Muster Point
 - Pump / Hose Storage Location
 - Fuel Storage Area
 - Oil Storage Area

- Notes:**
1. All site operations will be undertaken on impermeable concrete surfacing.
 2. See drawing 'Site Layout Plan' (drawing ref- 203162/D/003) and 'Drainage Plan' (drawing ref- 203162/D/004) for detail on the site layout and surface water drainage design.
 3. The prevailing wind direction is from the south - southwest.
 4. Mobile plant will be stored outside, and at least 6 m away from combustible waste.
 5. Waste bays to be segregated by 0.5 m thick concrete legio block walled bays

Rev.	Details	Drawn Chkd.	Date
Project 203162 Wharf Road, Doncaster			
Title Fire Prevention Plan			
		AA Environmental Ltd Units 4-8 Cholswell Court Shippon Abingdon Oxon OX13 6HX T: (01235) 536042 F: (01235) 523849 info@aae-ltd.co.uk www.aae-ltd.co.uk	
Scale 1:500@A3	Date Dec '20	Drawn JM	Chkd. ML
Drg. No. 203162/D/007		Rev.	