

Sector of the Installation	MCPD							
Installation name	RWE - Grimsby Power Station							
Name of contact	Micheal Pollard							
Contact email	micheal.pollard@rwe.com							
Contact phone	+44(0)7795 353616							
Report No of previous monitoring	NA							
Date of previous monitoring	NA							
Planned Date of monitoring	04/11/2019							
Test laboratory name	Uniper Technologies							
Test laboratory address	Technology Centre Ratcliffe on Soar Nottingham NG11 0EE							
Test laboratory email	mark.muter@uniper.energy							
Test laboratory phone number	+44 (0) 7818 075730							
Test laboratory UKAS number	2200							
Test laboratory staff								
Name	MCERTS Registration Number	Current Certification						
		Trainee	MCERTS Level 1	MCERTS Level 2	TE 1	TE 2	TE 3	TE 4
Ben Morley	MM 02 024			✓	✓	✓	✓	✓
Chris Beech	MM 16 1381	✓						
Part 2 - Monitoring objectives								
Overall aim of monitoring campaign								
Emission Testing to demonstrate that emissions from the release point comply with the Limit Values set within the site's permit								✓
Substance to be monitored at each emission point & emission limit value								
Periodic monitoring								
Emission point	Determinand	Source	Short term ELV (Calendar monthly mean)	Daily average ELV (95% of validated daily means within a calendar year)	Monitoring frequency	Monitoring standard	Uncertainty requirement	
			mg/Nm3	mg/Nm3				
A1 - TA 25295	NOx (as NO ₂)	Cummins Gas Engine No 1	95	NA	3 yearly	BS EN 14792	20	
A2 - TA 25296	NOx (as NO ₂)	Cummins Gas Engine No2	95	NA	3 yearly	BS EN 14792	20	
A3 - TA 25298	NOx (as NO ₂)	Cummins Gas Engine No3	95	NA	3 yearly	BS EN 14792	20	
A4 - TA 25299	NOx (as NO ₂)	Cummins Gas Engine No4	95	NA	3 yearly	BS EN 14792	20	
A5 - TA 25300	NOx (as NO ₂)	Cummins Gas Engine No5	95	NA	3 yearly	BS EN 14792	20	
A6 - TA 25301	NOx (as NO ₂)	Cummins Gas Engine No6	95	NA	3 yearly	BS EN 14792	20	
A7 - TA 25303	NOx (as NO ₂)	Cummins Gas Engine No7	95	NA	3 yearly	BS EN 14792	20	
A8 - TA 25304	NOx (as NO ₂)	Cummins Gas Engine No8	95	NA	3 yearly	BS EN 14792	20	
A9 - TA 25305	NOx (as NO ₂)	Cummins Gas Engine No9	95	NA	3 yearly	BS EN 14792	20	
A10 - TA 25307	NOx (as NO ₂)	Cummins Gas Engine No10	95	NA	3 yearly	BS EN 14792	20	
Reference conditions at which results are expressed								
Moisture %	0							
Pressure mbar	1013							
Oxygen % dry	15							
Temperature °C	0							
Details of monitoring methods								

Determinand	SRM Standard Applied	Equipment Type	Principle	SRM Work Instruction Number (TOI)	Overall uncertainty of monitoring methods %
NOx (as NO2)	BS EN 14792	Horiba PG250a	Chemiluminescence	TOL_APT_004_1	~5%

Part 2 - Operating information

Type of process	Combined bank of 10 gas engines for the production of electricity.										
Description of the process	X10 Gas engines, each engine has a thermal rating of 4.8MWth (with and aggregated capacity of 48MWth)										
Process operation: Continuous, Batch, Standby etc	A1 - TA 25295 As Required	A2 - TA 25296 As Required	A3 - TA 25298 As Required	A4 - TA 25299 As Required	A5 - TA 25300 As Required	A6 - TA 25301 As Required	A7 - TA 25303 As Required	A8 - TA 25304 As Required	A9 - TA 25305 As Required	A10 - TA 25307 As Required	
Fuel type	Natural gas	Natural gas	Natural gas	Natural gas	Natural gas	Natural gas	Natural gas	Natural gas	Natural gas	Natural gas	
Feedstock	NA	NA	NA	NA	NA	NA	NA	NA	NA	NA	
The normal load, throughput or continuous rating	4.8 MWth	4.8 MWth	4.8 MWth	4.8 MWth	4.8 MWth	4.8 MWth	4.8 MWth	4.8 MWth	4.8 MWth	4.8 MWth	
Any unusual occurrences that can take place	Start up and shut down										
Stack temperature °C	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	
Stack velocity m/s	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	Unknown	
What type of abatement is fitted	None	None	None	None	None	None	None	None	None	None	
DAHS details	NA										
Process details to be collected over the monitoring period	%Load										

Part 2 - Sample location

Rectangular or circular stack	Circular engine exhaust duct										
Dimensions of stack & sampling platform	<1m diameter										
Description of the monitoring location	Engine/Catalytic Converter exhaust										
Description of sample ports and number of lines	Single 1" BSP plug on each engine.										
Number of sampling points per line	1										
Gaseous sampling position	~0.1m deep										
Summary of compliance with CEN standards	EN15259 not applicable for small duct										
Access	The sample ports are located at ground level, a small step may be needed to access the sampling port. Access to the Power Station is gained by pre arrangement only.										
Adequate work area at the monitoring location	Yes										
Availability of required utilities	3 pin 240V power supply, the power is stepped down to 110v using a 240/110 voltage transformer.										
Pitot tube traverse of the velocity profile	NA										
Temperature of stack	NA										
Moisture of stack	NA										
Homogeneity test result	NA										
Restrictions on using equipment	None										
Physical restrictions to using equipment	None										
Appropriate measurement equipment for the application	Portable equipment with MCERTS										

Summary of compliance with BS EN 15259

NA

Diagram of emission point, platform and location



Part 2 - Details of monitoring

Determinand - Compliance	Expected emission values	Units	Lower Detection limit	Units
NOx (as NO2)	< 100	ppm	< 2	ppm
NOx (as NO2)	< 100	ppm	< 1	ppm
NOx (as NO2)	< 100	ppm	< 1	ppm
NOx (as NO2)	< 15	%	< 0.02	%
Equipment used for analysing each substance monitored	As per requirements of standards quoted			
Chemical analysis method and laboratory details	NA			
Any modifications to technical procedure, with justifications and any resulting changes to the uncertainties	None			
Reason why any substance in the monitoring objective is not monitored	NA			
Explanation why any substance will not be monitored in accordance with the monitoring method	NA			