


PHILLIPS 66 – HUMBER ZERO

CO₂ Venting & Dispersion Report



Document no. 215005-00857-00-PM-REP-00001
15th December 2023

27 Great West Road
Brentford Middlesex
TW8 9BW
United Kingdom
T: +44 208 326 5000
Worley Europe Limited
Company Number: 4334425
VAT Reg No 945 6484 83

© Copyright 2023 Worley ACN 096 090 158. No part of this document or the information it contains may be reproduced or transmitted in any form or by any means electronic or mechanical, including photocopying, recording, or by any information storage and retrieval system, without permission in writing from Worley.

worley.com

Disclaimer

This report has been prepared on behalf of and for the exclusive use of Phillips 66, and is subject to and issued in accordance with the agreement between Phillips 66 and Worley Europe Limited. Worley Europe Limited accepts no liability or responsibility whatsoever for it in respect of any use of or reliance upon this report by any third party. Copying this report without the permission of Phillips 66 or Worley Europe Limited is not permitted.

215005-00857 – Humber Zero – CO₂ Venting & Dispersion Report

Rev	Description	Originator	Reviewer	Worley Approver	Revision Date	Phillips 66 Approver	Approval Date
Rev A	Issued for Information	AMD	PK	PK	07 th Dec 2023	N/A	
Rev B	Re Issued for Information	AMD	PK	PK	15 Dec 2023	N/A	
		Andrew Dickinson	Paul King	Paul King			




DocuSigned by:  DocuSigned by:  DocuSigned by: 

Table of Contents

1.	Executive Summary.....	5
2.	Introduction.....	7
3.	Modelling Software & Validation.....	8
3.1	Modelling Software.....	8
3.2	Modelling Uncertainty.....	8
3.3	Modelling Confidence.....	9
4.	Modelling Basis and Assumptions.....	11
4.1	Concentration Exposure Limits.....	11
4.2	Weather Data.....	12
4.3	Vent Location & Arrangement.....	12
4.4	Receptor Locations.....	14
4.4.1	Offsite Receptors.....	14
4.4.2	Local Plant Receptors.....	15
5.	Venting Scenarios.....	16
5.1	Start Up.....	16
5.2	Shutdown.....	17
5.3	CO ₂ Off Specification.....	17
5.4	Relief Valve Discharges.....	17
6.	Results Summary.....	18
6.1	HP01 5,000 ppm.....	18
6.2	HP01 15,000 ppm.....	18
6.3	HP02 5,000 ppm.....	19
6.4	HP02 15,000 ppm.....	19
6.5	HP03 5,000 ppm.....	20
6.6	HP03 15,000 ppm.....	20
6.7	Vent Plume Extent.....	21
7.	Conclusions.....	23
8.	References.....	24
9.	Appendix.....	25
9.1	Venting Diagram Case HP01, Shut Down - Solvent Stripping.....	25
9.2	Venting Diagram Case HP02, Shut Down - Depressure of HP & LP Systems.....	26
9.3	Venting Diagram Case HP03, Shut Down – De Pressure HP & LP.....	27

List of Tables

Table 1.1 Summary of Dispersion Modelling Results.....	5
Table 3.1 List of CO ₂ experiments used for PHAST model validation	9
Table 4.1 HSE Toxic Load Assessment - Concentration vs time consequences for CO ₂ inhalation	11
Table 4.2 Summary of vent sources into CO ₂ vent stack	13
Table 4.3 Offsite receptors.....	14
Table 4.4 Local plant receptors	15
Table 5.1 Venting scenarios	16

List of Figures

Figure 3-1 PHAST 8.7 release notes.....	8
Figure 3-2 PHAST validation of Shell and BP CO ₂ dispersion experiments.....	10
Figure 3-3: Pointwise observed vs predicted maximum concentrations for COSHER experiments.....	10
Figure 3-4: Arcwise observed vs predicted maximum concentrations for COSHER experiments.....	10
Figure 4-1 Wind rose data for Immingham (meteoblue).....	12
Figure 4-2 Model Screenshot showing location of vent.	13
Figure 4-3 Map of offsite receptors.....	15

1. Executive Summary

The scope of this report is to evaluate the various concentrated CO₂ venting scenarios and impacts to the local population associated with the new post combustion FCC Carbon Capture Unit (CCU) to be installed at the Phillips 66 Humber Refinery.

The requirement for the direct venting of concentrated CO₂ has been minimised as far as possible through the recycling of CO₂ vent streams to the CCU absorber. Where this is not feasible for some plant shutdown activities and process upsets there is a requirement to vent concentrated CO₂ to atmosphere.

Through assessment of the various plant modes of operation, the following scenarios for the venting of concentrated CO₂ have been identified. These form the basis for dispersion modelling to establish the potential impacts upon plant personnel and the local population.

	Start-Up	Shutdown		CO ₂ Off Specification @ HP
		Solvent Stripping	HP/ LP- De Pressuring	
Dispersion Modelling Scenario Reference	N/A	HP01	HP02	HP03
Venting Rate	N/A	62,845 lb/hr	62,845 lb/hr	22,050 lb/hr
Discharge Temp	N/A	46 °F	44 °F	40 °F
5,000 ppm Dispersion Radius		33 m	33 m	37 m
15,000 ppm Dispersion Radius		9 m	9 m	15 m
Distance to Nearest Offsite Receptor		630 m	630 m	630 m

Table 1.1 Summary of Dispersion Modelling Results

Dispersion modelling has assessed concentrations of 5,000 and 15,000 ppm based upon the Long-Term Exposure Limit (LTEL) and Short-Term Exposure Limit (STEL) for CO₂ respectively. Venting due to off spec CO₂ within the HP system provides the worst case maximum dispersion radius. Associated dispersion modelling results show a concentration of 5,000 ppm is not exceeded beyond the site boundary or at any offsite receptor locations.

The impact upon adjacent plant structures has also been assessed and dispersion results show no ‘slumping’ of the CO₂ plume below the stack elevation. A stack height of 40m x 200mm diameter has been specified to ensure sufficient elevation above pipe racks and structures within the direct vicinity. Some local structures including the wet gas scrubber, absorber and amine regeneration column are elevated above the 40m stack

height, however all are sufficient distance from the vent to ensure adequate dispersion, ensuring concentrations are less than 5,000 ppm at all accessible locations across the site.

2. Introduction

Under the Humber Zero suite of projects, Phillips 66 intend to install a post combustion Carbon Capture Unit (CCU) on the Humber Oil Refinery downstream of the existing Fluid Catalytic Cracker (FCC) unit. As part of the proposed plant operation, the venting of concentrated CO₂ to atmosphere can occur during shutdown and upset operating scenarios. Dispersion modelling has been conducted against associated planned and unplanned venting scenarios to assess the impact upon the environment and local population.

This report presents the modelling basis and venting scenarios along with results and conclusions from dispersion modelling.

3. Modelling Software & Validation

3.1 Modelling Software

The Det Norske Veritas (DNV) Germanischer Lloyd (GL) consequence modelling software Process Hazard Analysis Software Tool (PHASt) version 8.7 shall be used to determine extents of the worst-case events in terms of CO₂ concentration. PHAST is an industry standard consequence modelling software which examines the progress of a potential incident from the initial release (source term) to far-field dispersion analysis, together with gas dispersion, jet fire thermal radiation modelling, flash fire and explosion effects calculation.

The current versions of PHAST software are capable of modelling CO₂. The Peng-Robinson equation of state is used for CO₂ releases for more accurate and robust behaviour particularly for temperatures closer to critical temperature. There are several validations for leak scenario which indicate that flowrates are predicted better with Peng-Robinson compared to the default equations of state. DNV recommends using the Peng-Robinson equations of state for CO₂ modelling.

Vertical concentration contours were generated covering the concentrations of concern at different weather conditions as stated below. DNV recommended using release angles slightly less than 90° for vertical releases such as from the vent stack. See PHAST 8.71 Release notes below:

67975	Dispersion results for vertical releases
Description	The dispersion calculations for vertical releases can be problematic, particularly when determining downwind concentrations. The algorithms are based on tangents to the centreline, and therefore vertical or near vertical clouds can run into difficulties that require special handling. In some cases, it has become apparent that this can lead to concentration predictions that are generally over-conservative. In most cases these problems can be solved by reducing the release angle, so it is just off vertical, e.g., to 85 degrees from the horizontal.

Figure 3-1 PHAST 8.7 release notes

3.2 Modelling Uncertainty

The PHAST software includes a large number of mathematical models. The theory, verification and validation of these models is included in the technical documentation provided with PHAST and in various technical publications. References to detailed validation analysis are provided rather than repeating the information here. For CO₂ (and other materials), an overview of key verification and validation is given in Witlox et al., (2018) and provides a good general introduction.

	BP	Shell	CO2PIPETRANS: Pipe releases	CO2PIPETRANS: Orifice releases	COSHER
Scenario	Orifice, horizontal	Orifice, horizontal	Long pipe, horizontal	Orifice, horizontal	Buried long pipe
Pressure [bar]	82 – 158	80 - 152	98 - 105	26 - 78	152
Temperature [°C]	5 – 149	0 - 71	3 - 14	-10 - 14	13.1

	BP	Shell	CO2PIPETRANS: Pipe releases	CO2PIPETRANS: Orifice releases	COSHER
Fluid phase	Dense liquid, super-critical	Dense liquid, super-critical	Dense liquid	Liquid, dense liquid	Dense liquid
Hole diameter [mm]	6 – 26	6 - 25	10 – 50	25 - 150	219.1 (full-bore rupture)
Year	2006-07	2010-11	2012-13	2013	2013
Location	Spadeadam	Spadeadam	Spadeadam	Spadeadam	Spadeadam
Reference	(Witlox, et al., 2014) ¹⁴	(Witlox, et al., 2014) ¹⁴	(Holt, et al., 2015) ¹⁰	(Witlox, et al., 2015) ¹¹	(Ahmad, et al., 2015) ¹²

Table 3.1 List of CO₂ experiments used for PHAST model validation

Over the past 10 years there have been several improvements in PHAST CO₂ modelling. These relate to the modelling of solid-vapour equilibrium calculations and solid properties, and special considerations for some physical properties (particularly density). This affects models from discharge through to dispersion. There is also a crater model which, while more generally applicable, was derived based on CO₂ buried pipeline experiments. The toxic effects of CO₂ are taken into account by using probit values derived from the HSE.

3.3 Modelling Confidence

The PHAST Model has been validated against BP and Shell experimental data made available via the CO2PIPETRANS JIP8. The experiments were of pressurised CO₂ releases involving steady-state and transient dense liquid phase releases, and time-varying supercritical releases. Initial pressure ranged from 80 bar to 158 bar, initial temperatures from 0°C to 149°C, and orifices diameters from 6 mm to 26 mm. The releases were horizontal and not impinged.

The releases were all modelled by the UDM as steady-state releases, with 20-seconds averaged flow rates applied for the time-varying BP releases and with the initial maximum flow rate applied for the time-varying Shell releases. For all cases the solid carbon dioxide was found to sublime rapidly, and no fallout was predicted, which was in line with experimental observations. The concentrations were found to be predicted accurately, as indicated in the figures below, where the vast majority of predicted concentrations are well within a factor of two.




Figure 3-2 PHAST validation of Shell and BP CO₂ dispersion experiments




Figure 3-3: Pointwise observed vs predicted maximum concentrations for COSHER experiments.




Figure 3-4: Arcwise observed vs predicted maximum concentrations for COSHER experiments.

The findings from this experimental data show that the Peng-Robinson equation of state (PR EoS) more accurately predicts CO₂ density in some regimes than the default method in PHAST. Vent modeling within PHAST will be completed using the 'short pipe' method to obtain similar results to those completed during the experiments mentioned above.

4. Modelling Basis and Assumptions

4.1 Concentration Exposure Limits

Concentration exposure limits are based on HSE Workplace Exposure Limit guidance (EH40) and HSE’s Dangerous Toxic Load Assessment:

- 5,000 ppm (concentration of CO₂ of 0.5 % v/v in air): The Long-Term Exposure Limit (LTEL, based on an 8-hour time weighted average period)
- 15,000 ppm (concentration of CO₂ of 1.5 % v/v in air): The Short-Term Exposure Limit (STEL, based on a 15-minute time weighted average period)

It is noted that the HSE’s Dangerous Toxic Load assessment for CO₂ shows a significant danger to humans if they inhale CO₂ at concentrations above the following:

- 14% in air (i.e. > 1400,000 ppm) for 1 min and;
- 8.4% in air (i.e. > 84,000 ppm) for 60 mins.

These concentrations correlate to the significant likelihood of death figures shown within Table 4.1. SLOD is defined as causing 50% lethality from a single exposure over a known amount of time.

Inhalation Exposure Time (min)	SLOT: 1-5% Fatalities CO ₂ Concentrations in air		SLOD: 50% Fatalities CO ₂ Concentrations in air	
	%	ppm	%	ppm
60	6.3	63,000	8.4	84,000
30	6.9	69,000	9.2	92,000
20	7.2	72,000	9.6	92,000
10	7.9	79,000	10.5	96,000
5	8.6	86,000	11.5	115,000
1	10.5	105,000	14	140,000

Table 4.1 HSE Toxic Load Assessment - Concentration vs time consequences for CO₂ inhalation

For the purposes of this assessment we will solely focus on the STEL and LTEL as these are the lower limits prescribed by HSE for CO₂ concentration exposure.

4.2 Weather Data

Three weather conditions assessed for the study have been selected based on annual weather conditions for the Immingham area using the wind rose data (Figure 4-1) and are assumed typical for assessment of all installations.




Figure 4-1 Wind rose data for Immingham (meteoblue)

Weather parameters within PHAST are designated using letters. The letter (ranging from A to F) associated to a Pasquill Stability Class refers to how stable an environment is in terms of atmospheric turbulence. The number (ranging from <2 to >13) associated to a Pasquill Stability Class refers to the surface wind speed (in m/s) measured at a 10 m height.

The following conditions were considered:

Pasquill Stability Classes:

- D: Neutral conditions, with wind speeds of 5 m/s ("5D") This class represents the conditions for weather condition for day time.
- F: Moderately stable conditions, with wind speeds of 2 m/s ("2F") This class represents the conditions for weather condition for night time.
- F: Moderately stable conditions, with wind speeds of 1 m/s ("1F") This class represents the conditions for weather condition with poor visibility, e.g. fog and / or mist.

Ambient Air temperature = 50°F

Relative Humidity = 80%

4.3 Vent Location & Arrangement

All concentrated CO₂ vents shall be routed via a common atmospheric vent (NGR grid reference 515601, 416926) referred to in this document as the CO₂ vent stack. Table 4.2 provides a summary of proposed vent sources into the CO₂ vent stack.

Source	Location	Controlled	Vent Heating
LP Vent	Downstream of the Deoxy and Dehydration units	Flow	
HP Vent	Discharge of HP compressor	Flow	Yes
Export Vent	Export line downstream of HP analysis	Flow	Yes
Relief	Various relief devices to be specified in subsequent design phases.	No	

Table 4.2 Summary of vent sources into CO₂ vent stack

With the exception of relief vents, flowrates shall be regulated across a flow control valve to ensure specified venting flowrates are maintained. For HP vents on the compressor discharge and export line, venting shall be via an inline knock out drum and heater to ensure liquids/ solids formed from the high pressure let down are vaporised prior to venting to atmosphere.

The elevation of adjacent pipe racks and structures is ~ 25m. Dispersion modelling is based upon a proposed stack height of 40m x 200mm diameter to ensure personnel working on adjacent structures are not at risk from excess CO₂ concentration levels against the identified venting scenarios.




Figure 4-2 Model Screenshot showing location of vent.

4.4 Receptor Locations

4.4.1 Offsite Receptors

Receptors potentially affected by the emissions from the installation, including local residential and amenity receptors, have been identified through site knowledge and desk study of local mapping. Isopleth figures of pollutant dispersion have been examined to identify the receptors that will receive the highest point source contributions and these receptors have been included in the model set up as discrete receptors.

The receptors are selected to be representative of residential dwellings and recreational areas around the installation and are shown in Table 4.3. The nearest receptor to the CO₂ vent stack is taken as Melrose, South Killingholme.

Receptor I.D	Receptor	Distance from Stack	NGR Grid Reference
CO ₂ Vent Stack			515601 , 416926
R1	Hazel Dene, Marsh Lane	1780 m	517330, 417311
R2	Station House, Station Road	2300 m	517333, 418345
R3	Fairfield House, North Garth	2160 m	514687, 418769
R4	Old Vicarage, North Garth	1820 m	514428, 418197
R5	Manor Farm, North Killingholme	1380 m	514515, 417653
R6	Church Lane, North Killingholme	990 m	514763, 417331
R7	Westfield Farm, North Killingholme	900 m	514708, 416785
R8	Melrose, South Killingholme	630 m	515115, 416417
R9	Town St/ Humber Road, South Killingholme	690 m	515516, 416120
R10	South Killingholme Primary School	1000 m	514880, 416120
R11	East End Farm	1120 m	515935, 415730
R12	Immingham	2640 m	517765, 415255

Table 4.3 Offsite receptors



Figure 4-3 Map of offsite receptors

4.4.2 Local Plant Receptors

The following provides a summary of all adjacent elevated plant equipment and horizontal distance from the CO₂ vent stack. Dispersion modelling shall consider the impacts of operatives accessing adjacent structures.

Plant Item	Distance from Stack
Compression Building	35 m (1)
Fin Fan Coolers	54 m
Solvent Stripper Column	70 m
Absorber Column	110 m
Wet Gas Scrubber	140 m

Table 4.4 Local plant receptors

- (1) Although within max dispersion radius, compression building is elevated below 40m so concentration is < 5,000 ppm.

5. Venting Scenarios

Venting scenarios associated with start-up, shutdown and off specification have been assessed. The following provides a summary of all scenarios where concentrated CO₂ is vented via the CO₂ vent stack. Where identified venting activities can be planned as necessary to minimise any potential disruption associated with excess noise levels.

Vent discharge conditions have been derived using UniSim process simulation software using the Peng-Robinson equation of state, and are calculated upon letting down to atmospheric conditions from defined upstream operating temperatures and pressures. Upstream and discharge conditions are identified within Table 5.1 below.

	Start-Up	Shutdown		CO ₂ Off Specification
		Solvent Strip	HP/ LP- De Pressuring	@ HP
Source	N/A	LP Vent	LP + HP + Export	Export
Discharge Location	N/A	CO ₂ vent stack	CO ₂ vent stack	CO ₂ vent stack
Vent Stream Composition		100% CO ₂ (1)	100% CO ₂ (1)	100% CO ₂ (1)
Venting Mass Flow	N/A	62,845 lb/hr	62,845 lb/hr	22,050 lb/hr
Vent Tip Diameter	N/A	0.656 ft	0.656 ft	0.656 ft
Velocity @ Vent Tip	N/A	430 ft/s	428 ft/s	149 ft/s
Upstream Pressure	N/A	534 psig	100 psig	116 psig
Upstream Temperature	N/A	118 °F	59 °F	58 °F
Discharge Temp	N/A	46 °F	44 °F	40 °F
Planned	N/A	Yes	Yes	No
Release Frequency	N/A	0.2 /yr	0.2 /yr	(2)
Duration	N/A	< 8hrs	~ 8 hrs	~ 8 hrs

Table 5.1 Venting scenarios

- (1) Composition of vented vent stream is taken as 100% CO₂ for the purposes of PHAST modelling. Actual vent stream likely to contain trace levels of H₂O (30 ppm)
- (2) Release associated with unplanned plant deviation

5.1 Start Up

The proposal for all phases of plant start up is to recycle off specification CO₂ back to the absorber inlet. Excess CO₂ will be discharged along with the flue gases to atmosphere via the absorber vent. At this point it shall be a diluted stream and no venting of concentrated CO₂ will occur.

5.2 Shutdown

Venting of concentrated CO₂ shall take place as part of a planned operation when the CCU is shutdown. This is required to 'strip' CO₂ from the solvent prior to being sent to storage and to de-pressurise the LP and HP systems prior to purging and maintenance. Shutdown shall coincide with the FCC outage once every 5 years (0.2/yr).

During shutdown, flue gases from the FCC shall be vented to atmosphere via the wet gas scrubber and the flow to the CCU stopped. As the CO₂ flow reaches the minimum turn down for the Deoxy and Dehydration units there is potential the CO₂ will go off specification. At this point concentrated CO₂ would be discharged to the CO₂ vent stack via the LP & HP vents until stripping of CO₂ from the solvent has ceased. Under this scenario CO₂ would be vented at a rate equivalent to the minimum turndown of the Deoxy and Dehydration units (62,845 lb/hr). Refer to Appendix 9.1 for associated venting diagram.

On completion of solvent stripping the final phase of the CCU shutdown is to de-pressurise the HP and LP stages of the compressor. Venting rates shall be controlled to ensure peak discharge rates are within those for CO₂ stripping and do not exceed 62,845 lb/hr. Refer to Appendix 9.2 for associated venting diagram.

5.3 CO₂ Off Specification

Continuous analysis is provided in both the LP and HP systems. Where possible this would provide early indication of material going out of specification, and allow corrective action to be taken ensuring atmospheric venting is minimised. It shall be necessary however to vent CO₂ if off specification CO₂ is detected.

In the event of LP going out of specification, flow to the HP system is stopped and flow to the LP system is reduced to the minimum turndown for the Deoxy and Dehydration units and recycled back to the absorber inlet. CO₂ is then vented along with the flue gases via the absorber vent as a diluted stream and no venting of concentrated CO₂ will occur.

In the event of HP going out of specification, flow to the HP system is stopped and flow to the LP system is vented to the absorber as per LP out of specification. De pressuring of the HP system would however be through the HP vent to atmosphere as a concentrated CO₂ stream via the CO₂ vent stack. Depressuring of the HP line would occur at a flow of 22,050 lb/hr governed by the capacity of the HP vent heating system. Refer to Appendix 9.19.3 for associated venting diagram.


5.4 Relief Valve Discharges

Relief valves including those identified on the LP and HP compressor suction drums shall discharge concentrated CO₂ to atmosphere via the CO₂ vent stack. Relief venting shall however be infrequent and only in the event of plant upset. Determination of required relief provisions and sizing will be conducted at detailed design along with dispersion modelling as necessary to ensure discharged CO₂ concentrations are acceptable.


6. Results Summary

Consequence Model Contours for each scenario, associated with all weather conditions are shown below for 5,000 ppm and 15,000 ppm respectively.


6.1 HP01 5,000 ppm




6.2 HP01 15,000 ppm




6.3 HP02 5,000 ppm




6.4 HP02 15,000 ppm



6.5 HP03 5,000 ppm



6.6 HP03 15,000 ppm



6.7 Vent Plume Extent

The following shows the extent of the CO₂ vent plumes from the CO₂ Vent Stack against a 5,000ppm CO₂ concentration.



Figure 6-1 Case HP01 5,000ppm CO₂ extent at 40m elevation



Figure 6-2 Case HP02 5,000ppm CO₂ extent at 40m elevation



Figure 6-3 Case HP03 5,000ppm CO₂ extent at 40m elevation

7. Conclusions

The vent dispersion results presented within this report show the modelling results using DNV PHAST exhibit the type of behaviour observed from real time experiments conducted by others for the concentrations chosen. Concentrations of interest used within the model demonstrate that CO₂ plumes do not touch down to grade and can be shown that venting of CO₂ from the FCC will not create an adverse effect to people or animals.

The scenario representing the worst case dispersion impact is associated with controlled venting of the HP system in the event of CO₂ going out of specification.


Against a specified stack height of 40m x 200mm diameter, the associated concentration does not exceed the LTEL (5,000 ppm) both offsite and at onsite elevated structures.

8. References


1. UK EA & DEFRA, 2014 – 2021, Guidance on Environmental permitting: air dispersion modelling reports (Environmental permitting: air dispersion modelling reports - GOV.UK (www.gov.uk))
2. UK EA & DEFRA, 2016 – 2023, Guidance on Air emissions risk assessment for your environmental permit (Air emissions risk assessment for your environmental permit - GOV.UK (www.gov.uk))
3. Dr Peter Harper, UK Health and Safety Executive (HSE), Assessment of the major hazard potential of carbon dioxide (CO₂).
4. UK Health and Safety Executive (HSE), Fourth Edition 2020, EH40/2005 Workplace exposure limits.
5. Energy institute, Rev. C Draft 2023, EI123/013, Hazard Analysis for Onshore and Offshore Carbon Capture Installations and Pipelines
6. C.M. Dixon Et Al, 2012, Validation of Dispersion Models for High Pressure Carbon Dioxide Releases, Hazards XXIII Symposium Series no 158
7. DNV, Rev. 3 (June 2023), Application of Phast and Safeti to carbon dioxide consequences and risks.

9. Appendix

9.1 Venting Diagram Case HP01, Shut Down - Solvent Stripping



9.2 Venting Diagram Case HP02, Shut Down - Depressure of HP & LP Systems



9.3 Venting Diagram Case HP03, Shut Down – De Pressure HP & LP

