
Air Summary Tables

(Substances screened as insignificant are not shown)

Option 1 - Base-Case

Release Points

Number	Description	Location	Effective Height	Efflux Velocity	Total Flow
			metres	m/s	m3/hr
1	Generator Exhaust	Process Building	2	2.7	240

Short Term Impact

Substance Assessed	Background Contribution	EAL	PC	PEC	% PC of EAL	% PEC of EAL	EQ
	µg/l	µg/m3	µg/m3	µg/m3			
Nitrogen Dioxide		200.00	2.15733		1.08		0.01
						Total:	0.01

Option Summary
