

Table 2 – Emissions Points

Emissions points

Points are marked on site emissions plans as per their point reference.

Installation name		Enfield AD plant		
Point source emissions to air				
Emission point reference and location	Source	Parameter	Quantity	Unit
A1. CHP 1	Stacks on engine	Oxides of nitrogen	500	mg/m3
		Carbon Monoxide	1400	mg/m3
		Sulphur Dioxide	350	mg/m3
		Total VOCs	1000	mg/m3
A2. CHP 2	Stacks on engine	Oxides of Nitrogen	500	mg/m3
		Carbon Monoxide	1400	mg/m3
		Sulphur Dioxide	350	mg/m3
		Total VOCs	1000	mg/m3
A3. Auxiliary flare	flare	Oxides of Nitrogen	150	mg/m3
		Carbon Monoxide	50	mg/m3
		Total VOCs	10	mg/m3
A4. Boiler	boiler	n/a parameter	No limit set	
A5. Gas upgrade unit	Upgrade unit	n/a parameter	No limit set	
Point source emissions to water				
W1.	Point A	Oil, grease and suspended solids	No visible trace	
W2.	Point B	Oil, grease and suspended solids	No visible trace	