

UK Remediation Ltd
Richard Dalton
Director
Unit 11a Hill Barton Business Park
Clyst St Mary
Devon
EX5 1DR

Direct Line: 01392 205782
e-mail: tradeeffluenteast@southwestwater.co.uk

Our Ref: MD 178 – UK Remediation - Exeter

12th December 2014

Dear Richard,

Ref: Minimum Discharge Exemption Certificate

Please accept this letter as the approval by South West Water Limited (SWW), as the sewerage undertaker, for the minimal discharge of effluent (Water Industry Act 1991) comprising **effluent from a soil treatment facility** from the premises at **UK Remediation Ltd, Unit 11a Hill Barton Business, Clyst St Mary, Devon, EX5 1DR** subject to the following:

- Average daily discharge is less than 2000 litres.
- Discharge rate is no more than 2 litres per second.
- pH of effluent >5 and <10.
- Total Oils and Grease are less than 150 mg/l.
- Total suspended solids are less than 200 mg/l.
- Discharge is to a foul sewer.


While the minimal nature of this discharge remains, and unless we notify you to the contrary, we do not propose to apply the full provisions of trade effluent control legislation. You are required to notify us forthwith of any change in the process, materials used or any other circumstances likely to alter the nature, composition or volume of the effluent.

This exemption certificate supersedes any previous exemption certificates issued for your premises.

In accordance with the SWW charges scheme 2014 - 2015, there is an annual fee of £106.00 subject to VAT for the approval and registration of the proposed discharge by trade effluent staff, invoice to follow.

South West Water Ltd reserves the right to review the status of the discharge and liability for trade effluent charges at a future date.

Yours sincerely



Nick Gardner
Works Performance Scientist