

Explanation as to why the discharge is made above the mean low water spring tide mark

Extending the outfall would cause issues for accessibility and maintenance of the flap valve. It would increase the risk of the outfall blocking and being entrained with sediment, as sediment must be cleared out from its current location, any extension would increase this risk. It's thought this was accepted for the original design of the outfall.