

Non-Technical Summary for Phear Park SPST Exmouth

This is a permit variation for Phear Park Sewage Pumping Station. This site is located at SY 00585 81522, in Exmouth, Devon.

As part of the overall strategy for the Exmouth catchment, the pass forward flow from Phear Park Sewage Pumping Station is increasing from 120 litres per second to 200 litres per second.

The aim of this is to increase the capacity of flow taken by Maer Lane Sewage Treatment Works, so the number of spills at the sewage pumping station is reduced. Therefore, this is an important step towards achieving the overall strategy for the Exmouth catchment.

Phear Park Sewage Pumping Station has one outlet that discharges both emergency overflows and storm overflows. This outlet is located at SX 9996 8146.