Maintenance Report

Unit:	Indoor Ambient	Filters Cleaned:	Air Off: (Heat)	Air Off: (Cool)	Outdoor Ambient:	Coils Cleaned:	Air Off: (Heat)	Air Off: (Cool)	Ref Charge(Kg):	Refrigerant Type:
Managers Office	23	Y	39	5	18	Y	8	38	2.55	R410a
Admin Office	20	Y	40	8	18	Y	7	38	1.8	R410a
Control Room	21	Y	37	8	18	Y	7	36	3.8	R410a
Laboratory	20	Y	36	6	18	Y	9	37	3.8	R410a