

# Report for the Periodic Monitoring of Emissions to Atmosphere

Stack Emissions Test Report Commissioned by: Environmental Monitoring Solutions Ltd

## Holmfirth Dryers Ltd

### Boiler 2

Permit No: N/A  
Installation: Holmfirth  
Monitoring Dates: 22nd June 2022  
Site Address: Ribblesden Dye Works, Dunford Rd, Holmfirth, HD9 2DP

Report Number: ES-0911                      Version: 1                      Visit: 1 in 2022  
Date of Report: 21st July 2022  
Report Author: Kriss Wells  
MCERTS No: MM 06 701                      MCERTS Level: 2 (TE1,TE2,TE4)

Approved By: Andy Dykes                      Function: Operations Manager  
MCERTS No: MM 04 500                      MCERTS Level: 2 (TE1, TE2, TE3, TE4)

Signed:



T: 01274 738668

E: [info@envirocare.org](mailto:info@envirocare.org)

Envirocare Technical Consultancy Ltd

Unit 36, Bradford Chamber Business Park, New Lane, Bradford, BD4 8BX

## YOUR INDUSTRY EXPERTS



# Contents

|                                      |        |
|--------------------------------------|--------|
| Executive Summary                    |        |
| Monitoring Objectives                | 3      |
| Monitoring Results                   | 4      |
| Operating Information                | 5      |
| Monitoring Deviations                | 5      |
| Supporting Information               |        |
| Appendix 1: General Information      | 6      |
| Appendix 2: Results and Calculations | 7 - 12 |

# Executive Summary

## Monitoring Objectives

Envirocare Technical Consultancy were contracted by Environmental Monitoring Solutions Ltd to carry out emissions monitoring at Holmfirth Dryers Ltd, to determine the compliance of Boiler 2 as part of the the Part A permit application process. The methodologies utilised and the results obtained form the basis of this report.

The substances requested for monitoring are listed below.

## Emission Point Identification

| Substances to be Monitored               | Boiler 2 |
|--|----------|
| Carbon Monoxide                          | ✓        |
| Oxides of Nitrogen (as NO <sub>2</sub> ) | ✓        |
| Total VOC                                | ✓        |
| Oxygen                                   | ✓        |
| Volumetric Flow                          | ✓        |
| Water Vapour                             | ✓        |

Special requirements: none

Opinions and interpretations expressed within this report are outside the scope of Envirocare Technical Consultancy's MCERTS and UKAS accreditation. Envirocare accepts no responsibility for information in this report that was provided by the client, the client's representative or employees of the client. Where such information has been provided by external sources this is identified in footnotes of the respective tables.

# Executive Summary

## Monitoring Results

where MU = Measurement Uncertainty associated with the result (95% Confidence)

| Substance                                | Limit (mg/m <sup>3</sup> ) | Concentration               |                                  |      | Reference Conditions                     | Mass Emission |               |                                  | Sampling Date | Sampling Times |
|--|----------------------------|-----------------------------|----------------------------------|------|--|---------------|---------------|----------------------------------|---------------|----------------|
|  |                            | Result (mg/m <sup>3</sup> ) | Measurement Uncertainty (MU) +/- |      |  | Limit (g/hr)  | Result (g/hr) | Measurement Uncertainty (MU) +/- |               |                |
| Water Vapour                             | R1                         | -                           | 11.7%                            | -    | 273K, 101.3kPa                           | -             | -             | -                                | 22/06/2022    | 09:30-10:30    |
| Carbon Monoxide                          | R1                         | -                           | 1.6                              | 6.3  | 273k, 101.3kPa, Dry, 3% O <sub>2</sub> . | -             | 10.3          | 39.7                             | 22/06/2022    | 09:30-10:30    |
| Oxides of Nitrogen (as NO <sub>2</sub> ) | R1                         | -                           | 181                              | 2.4  | 273k, 101.3kPa, Dry, 3% O <sub>2</sub> . | -             | 1135          | 57.0                             | 22/06/2022    | 09:30-10:30    |
| Total VOC                                | R1                         | -                           | 4.9                              | 9.0  | 273k, 101.3kPa, Dry, 3% O <sub>2</sub> . | -             | 30.6          | 56.3                             | 22/06/2022    | 09:30-10:30    |
| Oxygen                                   | R1                         | -                           | 6.4%                             | 0.09 | 273k, 101.3kPa, Dry, 3% O <sub>2</sub> . | -             | -             | -                                | 22/06/2022    | 09:30-10:30    |
| Volumetric Flow                          | R1                         | -                           | 6,280 m <sup>3</sup> /h          | 304  | 273k, 101.3kPa, Dry, 3% O <sub>2</sub> . | -             | -             | -                                | 22/06/2022    | 08:35-08:45    |

Reference conditions (REF) are: 273k, 101.3kPa, Dry, 3% O<sub>2</sub>.

# Supporting Information

## Appendix 1: General Information

### Operating Information

| Parameter                                    | Process Details |
|--|-----------------|
| Process Type                                 | Boiler          |
| Continuous or Batch Process                  | Continuous      |
| Operating Status                             | Normal          |
| Feedstock                                    | Natural Gas     |
| Normal Load, Throughput or Continuous Rating | 100%            |
| Abatement System                             | None            |
| Abatement System Status                      | -               |
| Process Fuel                                 | Natural Gas     |
| Plume Appearance                             | None            |

### Monitoring Deviations

| Parameter      | Run   | Deviation  |
|----------------|-------|--|
| All Parameters | Run 1 | There are no deviations associated with the monitoring undertaken. |

### Monitoring Organisation Staff Details

| Personnel  | Position    | MCERTS Level    | MCERTS Number |
|------------|-------------|-----------------|---------------|
| Mr K Wells | Team Leader | 2 (TE1,TE2,TE4) | MM 06 701     |
| Mr C Welsh | Technician  | Trainee         | MM 20 1692    |

## Monitoring Methods

| Pollutant Species  | Standard          | Technical Procedure | Testing MCERTS | Analysis Laboratory  | Analytical Procedure | Analytical Technique | Analysis MCERTS |
|--------------------|-------------------|---------------------|----------------|--|----------------------|----------------------|-----------------|
| Volumetric Flow    | BS EN ISO 16911-1 | ETC-SE-24a          | Yes            | Pitot Tube and Thermocouple  |                      |                      |                 |
| Carbon Monoxide    | BS EN 15058       | ETC-SE-10 (a/b)     | Yes            | NDIR by Horiba PG-250 or PG350E  |                      |                      |                 |
| Oxides of Nitrogen | BS EN 14792       | ETC-SE-10 (a/b)     | Yes            | Chemiluminescence by Horiba PG-250 or Horiba PG-350                      |                      |                      |                 |
| Oxygen             | BS EN 14789       | ETC-SE-10 (a/b)     | Yes            | Dry Zirconia Cell by Horiba PG-250 or Dry Paramagnetic by Horiba PG-350E |                      |                      |                 |
| Total VOC          | BS EN 12619       | ETC-SE-04           | Yes            | Flame Ionisation Detector by M&C Thermo FID or Sick 3006 FID             |                      |                      |                 |
| Water Vapour       | BS EN 14790       | ETC-SE-11           | Yes            | ENV  | ETC-SE-11            | Gravimetric          | Yes             |

RPS Laboratories Ltd (RPS) - Accreditation Number: 0605 | Marchwood Scientific Services - Accreditation Number: 1668 | Olfasense - Accreditation Number: 2430

## Equipment Checklist


| Extractive Sampling    |                | Instrumental Analysers      |                | Miscellaneous Items           |                 |
|------------------------|----------------|-----------------------------|----------------|-------------------------------|-----------------|
| Equipment Type         | Equipment I.D. | Equipment Type              | Equipment I.D. | Equipment Type                | Equipment I.D.  |
| Control Box DGM        | ETC-S8.1       | Horiba PG-250               | -              | Tape Measure                  | ETC-S17.05      |
| Box Thermocouples      | ETC-S2.10a     | Horiba PG-250 SRM           | -              | Bevel Box                     | -               |
| Box Thermocouple In    | ETC-S3.32      | Horiba PG-350               | ETC-S12.01     | Stopwatch                     | ETC-S10.14      |
| Box Thermocouple Out   | ETC-S3.33      | JCT JCC Cooler              | -              | Barometer                     | ETC-SMet office |
| Control Box Timer      | ETC-S10.14     | MAK10 Cooler                | -              | Digital Manometer             | ETC-S24.04      |
| Umbilical              | ETC-S2.10b     | Horiba PS200 Cooler         | -              | Digital Temperature Meter     | ETC-S24.04      |
| Oven Box               | ETC-S9.06      | M&C PSS Gas Preparation     | ETC-S3.41b     | Dual Channel Heat Controller  | -               |
| Heated Probe (1)       | ETC-S4.12      | Gasmet DX4000 FTIR          | -              | 1m Heated Line                | -               |
| Heated Probe (2)       | -              | Gasmet Sampling System      | -              | 3m Heated Line                | -               |
| Stack Thermocouple (1) | ETC-S1.12      | SK-Thermo FID               | ETC-S13.07     | 5m Heated Line                | -               |
| Stack Thermocouple (2) | ETC-S1.36      | Bernath 3006 FID            | -              | 10m Heated Line               | ETC-S5.08       |
| S-Type Pitot (1)       | ETC-S4629      | Testo 350XL                 | -              | 20m Heated Line               | -               |
| S-Type Pitot (2)       | -              | M&C PSP 4000                | ETC-S7.08      | 30m Heated Line               | -               |
| L-Type Pitot           | -              | Easylogger EN-EL-12 Bit     | -              | Impinger Arm Thermocouple (1) | -               |
| Site Balance           | ETC-S18.02     | Hioki 5043 (V)              | -              | Impinger Arm Thermocouple (2) | -               |
| 500g Check Weight      | ETC-S18.02a    | Analyser Temperature Logger | -              | Dioxins Kit Thermocouple      | -               |
| 1KG Check Weight       | ETC-S18.02b    | -                           | -              | Sample Temperature Logger     | -               |
| Digital Callipers      | ETC-S16.08     | -                           | -              | Laboratory Balance            | -               |

## Appendix 2: Boiler 2 Results and Calculations

Picture of the sampling location



Sampling Points Diagram



### Duct Characteristics

| Parameter                   | Units          | Value      |
|-----------------------------|----------------|------------|
| Type                        | -              | Circular   |
| Depth                       | m              | 0.90       |
| Width                       | m              | -          |
| Area                        | m <sup>2</sup> | 0.64       |
| Port Depth                  | cm             | 9.0        |
| Orientation of Stack / Duct | -              | Horizontal |
| Sampling Port Size          | -              | 4" BSP     |
| Number of Ports             | -              | 2          |

| Manual Sampling Points       | Used / Required |
|------------------------------|-----------------|
| Number of Sampling Lines     | 1 / 1           |
| Number of Sampling Points    | 1 / 1           |
| Instrumental Sampling Points | Used / Required |
| Number of Sampling Lines     | 1 / 1           |
| Number of Sampling Points    | 1 / 1           |

| Platform Type and Location            |           |
|---------------------------------------|-----------|
| Platform Type - Permanent / Temporary | Permanent |
| Location - Inside / Outside           | Outside   |

| EA Technical Guidance Note M1 Platform Requirements |   |     |
|---|---|-----|
| Load Baring Capacity                                | Load baring capacity of platform sufficient to fulfil the measurement objective | No  |
| Position & Work Space                               | Sufficient work area to manipulate probe & operate the measurement instruments  | Yes |
|   | Depth of work area > internal diameter of stack and wall thickness plus 1.5m    | No  |
|   | Ports on vertical ducts 1.2m to 1.5m above platform floor                       | Yes |
|   | Platform has chains / self closing gates at top of ladders                      | N/A |
| Fall Prevention                                     | Platform has adequate drainage to prevent accumulation of free-standing water   | N/A |
|   | Platform has 2 levels of handrails (approx. 0.5m & 1.0m high)                   | N/A |
| Access  | Gaps between handrails not >0,5m  | N/A |
|   | Platform has vertical base boards (approx. 0.25m high)                          | N/A |
|   | Access to sampling ports unhindered by obstructions                             | N/A |
|   | Easy & safe access and egress available   | No  |

### Sampling Location / Platform Recommendations

All sampling platforms should be designed in accordance with the requirements specified in Environment Agency Guidance Note M1 and BS EN 15259.

## Water Vapour Measurements

| Parameter           | Value      | Unit |
|---------------------|------------|------|
| Sampling Date       | 22/06/2022 | -    |
| Start Time          | 09:30      | -    |
| End Time            | 10:30      | -    |
| Barometric Pressure | 1020       | mbar |

| Parameter                      | Value | Unit  |
|--------------------------------|-------|-------|
| Stack Temperature              | 182.0 | °C    |
| Corrected Volume               | 228.1 | L     |
| Collected Mass                 | 24.2  | g     |
| Stack Gas Water Vapour Content | 11.7  | % v/v |

## Flow Criteria Measurements

| Duct Diameter (m) | Cross Sectional Area (m <sup>2</sup> ) | Barometric Pressure (mbar) | Ambient Temperature (°C) | Mean Oxygen (%) | Mean Carbon Dioxide (%) | Mean Water Vapour (%) | Stack Gas Molecular mass (g/mol) | Pitot Coefficient |
|-------------------|--|----------------------------|--------------------------|-----------------|-------------------------|-----------------------|----------------------------------|-------------------|
| 0.90              | 0.64                                   | 1020                       | 13.0                     | 6.4             | 8.0                     | 5.7                   | 28.9                             | 0.846             |

| Sample Line | Traverse Point | Position (cm) | Differential Pressure Reading (cmH <sub>2</sub> O) |      |      |         | Stack Velocity (m/s) | Stack Temp (°C) | Angle of Swirl |
|-------------|----------------|---------------|--|------|------|---------|----------------------|-----------------|----------------|
|             |                |               | 1  | 2    | 3    | Average |                      |                 |                |
| A           | A1             | 13.1          | 0.20   | 0.20 | 0.20 | 0.20    | 6.2                  | 217             | 13             |
|             | A2             | 76.9          | 0.21   | 0.21 | 0.21 | 0.21    | 6.3                  | 216             | 11             |

| Sample Line | Traverse Point | Position (cm) | Differential Pressure Reading (cmH <sub>2</sub> O) |      |      |         | Stack Velocity (m/s) | Stack Temp (°C) | Angle of Swirl |
|-------------|----------------|---------------|--|------|------|---------|----------------------|-----------------|----------------|
|             |                |               | 1  | 2    | 3    | Average |                      |                 |                |
| B           | B1             | 13.1          | 0.20   | 0.20 | 0.20 | 0.20    | 6.2                  | 217             | 13             |
|             | B2             | 76.9          | 0.23   | 0.23 | 0.23 | 0.23    | 6.7                  | 216             | 10             |

| Parameter | Mean Duct Velocity | Velocity Ratio (Max:Min) | Mean Stack Temperature | Mean Stack Temperature | Stack Gas Volume Flow Actual | Stack Gas Volume Flow @ STP Wet | Stack Gas Volume Flow @ REF Conditions |
|-----------|--------------------|--------------------------|------------------------|------------------------|------------------------------|---------------------------------|--|
| Value     | 6.36               | 1.1:1                    | 217                    | 490                    | 14577                        | 8185                            | 6280                                   |
| Units     | m/s                | -                        | °C                     | K                      | m <sup>3</sup> /hr           | Nm <sup>3</sup> /hr             | Nm <sup>3</sup> /hr                    |



## Instrumental Gas Analyser Calibrations


| Date       | Operators | Combustion Gas Analyser | Flame Ionisation Detector |
|------------|-----------|-------------------------|---------------------------|
| 22/06/2022 | KW/CW     | ETC-S12.01              | ETC-S13.07                |

| Calibration Gas   | Certified Concentration | Analyser Range | T90 Time | Analyser Span | Pre-sample Cal |       | Post-sample Cal |       | Zero Drift | Span Drift | Drift Acceptable |
|-------------------|-------------------------|----------------|----------|---------------|----------------|-------|-----------------|-------|------------|------------|------------------|
|                   |                         |                |          |               | Zero           | Span  | Zero            | Span  |            |            |                  |
| Carbon Monoxide   | 160.81ppm               | 200ppm         | 22       | 160.8         | 0.20           | 160.8 | 0.00            | 156.4 | 0.00       | -2.7       | Yes              |
| Nitrogen Monoxide | 201.66ppm               | 250ppm         | 28       | 201.7         | 0.10           | 201.7 | -0.10           | 201.8 | -0.05      | 0.10       | Yes              |
| Propane           | 804.62ppm               | 1000ppm        | 16       | 804           | 0.02           | 802.3 | 0.50            | 802.1 | 0.06       | -0.30      | Yes              |
| Oxygen            | 21.23%                  | 25%            | 24       | 21.23         | 0.01           | 21.23 | 0.00            | 21.23 | 0.00       | 0.00       | Yes              |

## Instrumental Gas Analyser Results

| Substance                                | Run | Corrected Concentration |        |        | Units             | Basis                              | O <sub>2</sub> Correction |
|--|-----|-------------------------|--------|--------|-------------------|------------------------------------|---------------------------|
|  |     | Average                 | Max    | Min    |                   |                                    |                           |
| Carbon Monoxide                          | 1   | 1.6                     | 3.6    | 0.03   | mg/m <sup>3</sup> | -                                  | 3%                        |
| Oxides of Nitrogen (as NO <sub>2</sub> ) | 1   | 180.69                  | 205.27 | 156.02 | mg/m <sup>3</sup> | NO <sub>x</sub> as NO <sub>2</sub> | 3%                        |
| Total VOC                                | 1   | 4.9                     | 11.5   | 1.97   | mg/m <sup>3</sup> | VOC as C                           | 3%                        |
| Oxygen                                   | 1   | 6.36                    | 9.17   | 3.94   | %                 | -                                  | -                         |

## Instrumental Gas Analyser Chart - Run 1



## Uncertainty

### Uncertainty of Carbon Monoxide by Horiba Analyser

| Parameter                  | Value | Unit              |
|----------------------------|-------|-------------------|
| Emission Limit Value (ELV) | -     | mg/m <sup>3</sup> |
| Reading                    | 1.3   | ppm               |
| Span Gas Certified Value   | 160.8 | ppm               |
| Range                      | 200   | ppm               |

| Cal Gas |
|---------|
| CO      |

| Source of Uncertainty   | Uncertainty Criteria | Probability Distribution | Divisor | Source Uncertainty u | Combined Uncertainty u <sup>2</sup> |
|---|----------------------|--------------------------|---------|----------------------|-------------------------------------|
| Zero Drift/Lower limit of detection (ppm)                                   | 0.20                 | Rectangular              | 1.7     | 0.12                 | 0.01                                |
| Span Drift (ppm)  | 4.4                  | Rectangular              | 1.7     | 2.5                  | 6.5                                 |
| Linearity (% of value)  | 1.1                  | Rectangular              | 1.7     | 0.01                 | 0.0001                              |
| Setting Gas Divider (% of value)  | 0.35                 | Normal                   | 1.0     | 0.005                | 0.00002                             |
| Interference (% of value)   | -0.48                | Rectangular              | 1.7     | -0.004               | 0.00001                             |
| Standard deviation of repeatability at zero point (% of range)              | 0.10                 | Rectangular              | -       | 0.20                 | 0.04                                |
| Standard deviation of repeatability at span point (% of range)              | 0.20                 | Rectangular              | -       | 0.40                 | 0.16                                |
| <b>Total</b>  |                      |                          |         |                      | 6.7                                 |
| <b>Combined Standard Uncertainty [(sum u<sup>2</sup>)<sup>0.5</sup>]</b>    |                      |                          |         |                      | 2.6                                 |
| <b>Expanded Total Uncertainty (ppm) (95% confidence)</b>                    |                      |                          |         |                      | 5.1                                 |
| <b>Expanded Total Uncertainty as a % of emission conc. (95% confidence)</b> |                      |                          |         |                      | 385                                 |
| <b>Expanded Total Uncertainty (mg/m<sup>3</sup>) (95% confidence)</b>       |                      |                          |         |                      | 6.3                                 |

### Uncertainty of Oxides of Nitrogen by Horiba gas Analyser

| Parameter                  | Value | Unit              |
|----------------------------|-------|-------------------|
| Emission Limit Value (ELV) | -     | mg/m <sup>3</sup> |
| Reading                    | 88.0  | ppm               |
| Span Gas Certified Value   | 201.7 | ppm               |
| Range                      | 250   | ppm               |

| Cal Gas |
|---------|
| NO      |

| Source of Uncertainty   | Uncertainty Criteria | Probability Distribution | Divisor | Source Uncertainty u | Combined Uncertainty u <sup>2</sup> |
|---|----------------------|--------------------------|---------|----------------------|-------------------------------------|
| Zero Drift/Lower limit of detection (ppm)                                   | 0.10                 | Rectangular              | 1.7     | 0.06                 | 0.003                               |
| Span Drift (ppm)  | -0.10                | Rectangular              | 1.7     | -0.06                | 0.003                               |
| Linearity (% of value)  | 0.63                 | Rectangular              | 1.7     | 0.32                 | 0.10                                |
| Setting Gas Divider (% of value)  | 0.35                 | Normal                   | 1.0     | 0.31                 | 0.09                                |
| Interference (% of value)   | 0.63                 | Rectangular              | 1.7     | 0.32                 | 0.10                                |
| Standard deviation of repeatability at zero point (% of range)              | 0.00                 | Rectangular              | -       | 0.00                 | 0.00                                |
| Standard deviation of repeatability at span point (% of range)              | 0.10                 | Rectangular              | -       | 0.25                 | 0.06                                |
| <b>Total</b>  |                      |                          |         |                      | 0.37                                |
| <b>Combined Standard Uncertainty [(sum u<sup>2</sup>)<sup>0.5</sup>]</b>    |                      |                          |         |                      | 0.61                                |
| <b>Expanded Total Uncertainty (ppm) (95% confidence)</b>                    |                      |                          |         |                      | 1.2                                 |
| <b>Expanded Total Uncertainty as a % of emission conc. (95% confidence)</b> |                      |                          |         |                      | 1.4                                 |
| <b>Expanded Total Uncertainty (mg/m<sup>3</sup>) (95% confidence)</b>       |                      |                          |         |                      | 2.4                                 |

## Uncertainty of Total VOC by SK - Run 1

| Parameter                  | Value | Unit              |
|----------------------------|-------|-------------------|
| Emission Limit Value (ELV) | -     | mg/m <sup>3</sup> |
| Reading                    | 3.0   | ppm               |
| Span Gas Certified Value   | 804.6 | ppm               |
| Range                      | 1000  | ppm               |

| Cal Gas                       |
|-------------------------------|
| C <sub>3</sub> H <sub>8</sub> |

| Source of Uncertainty   | Uncertainty Criteria | Probability Distribution | Divisor | Source Uncertainty u | Combined Uncertainty u <sup>2</sup> |
|---|----------------------|--------------------------|---------|----------------------|-------------------------------------|
| Zero Drift/Lower limit of detection (ppm)                                   | -0.48                | Rectangular              | 1.7     | -0.28                | 0.08                                |
| Span Drift (ppm)  | 0.20                 | Rectangular              | 1.7     | 0.12                 | 0.01                                |
| Linearity (% of value)  | 0.40                 | Rectangular              | 1.7     | 0.01                 | 0.00005                             |
| Setting Gas Divider (% of value)  | 0.35                 | Normal                   | 1.0     | 0.01                 | 0.0001                              |
| Noise (ppm)   | 0.10                 | Rectangular              | 1.7     | 0.06                 | 0.003                               |
| Temperature Drift (% of value)  | 1.0                  | Rectangular              | 1.7     | 0.02                 | 0.0003                              |
| Standard deviation of repeatability at zero point (% of range)              | 0.20                 | Rectangular              | -       | 2.0                  | 4.0                                 |
| Standard deviation of repeatability at span point (% of range)              | 0.20                 | Rectangular              | -       | 2.0                  | 4.0                                 |
| <b>Total</b>  |                      |                          |         |                      | 8.1                                 |
| <b>Combined Standard Uncertainty [(sum u<sup>2</sup>)<sup>0.5</sup>]</b>    |                      |                          |         |                      | 2.8                                 |
| <b>Expanded Total Uncertainty (ppm) (95% confidence)</b>                    |                      |                          |         |                      | 5.6                                 |
| <b>Expanded Total Uncertainty as a % of emission conc. (95% confidence)</b> |                      |                          |         |                      | 184                                 |
| <b>Expanded Total Uncertainty (mg/m<sup>3</sup>) (95% confidence)</b>       |                      |                          |         |                      | 9.0                                 |

## Uncertainty of Oxygen by Horiba Analyser

| Parameter                | Value | Unit |
|--------------------------|-------|------|
| Reading                  | 6.36  | %    |
| Span Gas Certified Value | 21.23 | %    |
| Range                    | 25    | %    |

| Cal Gas        |
|----------------|
| O <sub>2</sub> |

| Source of Uncertainty   | Uncertainty Criteria | Probability Distribution | Divisor | Source Uncertainty u | Combined Uncertainty u <sup>2</sup> |
|---|----------------------|--------------------------|---------|----------------------|-------------------------------------|
| Zero Drift/Lower limit of detection (%vol)                                  | 0.05                 | Rectangular              | 1.7     | 0.03                 | 0.001                               |
| Span Drift (%vol)   | 0.00                 | Rectangular              | 1.7     | 0.00                 | 0.00                                |
| Linearity (% of value)  | 0.82                 | Rectangular              | 1.7     | 0.03                 | 0.001                               |
| Setting Gas Divider (% of value)  | 0.35                 | Normal                   | 1.0     | 0.02                 | 0.0005                              |
| Interference (% of value)   | 0.00                 | Rectangular              | 1.7     | 0.00                 | 0.00                                |
| Standard deviation of repeatability at zero point (% of range)              | 0.02                 | Rectangular              | -       | 0.01                 | 0.00003                             |
| Standard deviation of repeatability at span point (% of range)              | 0.02                 | Rectangular              | -       | 0.01                 | 0.00003                             |
| <b>Total</b>  |                      |                          |         |                      | 0.002                               |
| <b>Combined Standard Uncertainty [(sum u<sup>2</sup>)<sup>0.5</sup>]</b>    |                      |                          |         |                      | 0.05                                |
| <b>Expanded Total Uncertainty (%) (95% confidence)</b>                      |                      |                          |         |                      | 0.09                                |
| <b>Expanded Total Uncertainty as a % of emission conc. (95% confidence)</b> |                      |                          |         |                      | 1.5                                 |

Uncertainty of Volumetric Flow - Run 1

| Parameter   | Value  | Unit               |
|---|--------|--------------------|
| Measured Volumetric Flow Rate Actual  | 14577  | L/min              |
| Performance Characteristics & Source Value                                    |        |                    |
|   | Value  | Units              |
| Standard Uncertainty - Pitot tube Coefficient                                 | 0.01   | -                  |
| Standard Uncertainty - Mean Local Dynamic Pressure                            | 1.1    | Pa                 |
| Standard Uncertainty - Molar Mass of Stack Gas                                | 0.0001 | -                  |
| Standard Uncertainty - Stack Gas Temperature                                  | 0.50   | K                  |
| Standard Uncertainty - Absolute Pressure in Duct                              | 176    | Pa                 |
| Standard Uncertainty - Density of Stack Gas                                   | 0.002  | -                  |
| Standard Uncertainty - Mean Velocity  | 0.06   | m/s                |
| <b>Expanded Uncertainty Mean Velocity (95% confidence)</b>                    | 0.11   | m/s                |
| <b>Expanded Uncertainty Mean Velocity (95% Confidence), Relative</b>          | 1.7    | %                  |
| <b>Standard Uncertainty - Volumetric Flow Rate</b>                            | 360    | -                  |
| <b>Standard Uncertainty - Volumetric Flow Rate (95% Confidence)</b>           | 706    | m <sup>3</sup> /hr |
| <b>Standard Uncertainty - Volumetric Flow Rate (95% Confidence), Relative</b> | 4.8    | %                  |
| 95% confidence interval factor - 1.96   |        |                    |

| Document Version Number | Record of change within different version numbers  |
|-------------------------|--|
| V1                      | Original version of the document issued to client. |