



Aylesbury STC

Bioaerosol risk assessment to accompany permit application

January 2024

Mott MacDonald
10 Temple Back
Bristol BS1 6FL
United Kingdom

T +44 (0)117 906 9500
mottmac.com

Aylesbury STC

Bioaerosol risk assessment to accompany permit
application

January 2024

Issue and Revision Record

Revision	Date	Originator	Checker	Approver	Description
A	October 2021	S. Clinton	C. Mills	C. Mills	Draft 1
B	November 2021	S. Clinton	C. Mills	C. Mills	Draft 2
C	January 2024				Draft 3

Document reference: 100415487 | 3 | B

Information class: Standard

This document is issued for the party which commissioned it and for specific purposes connected with the above-captioned project only. It should not be relied upon by any other party or used for any other purpose.

We accept no responsibility for the consequences of this document being relied upon by any other party, or being used for any other purpose, or containing any error or omission which is due to an error or omission in data supplied to us by other parties.

This document contains confidential information and proprietary intellectual property. It should not be shown to other parties without consent from us and from the party which commissioned it.

Contents

1	Introduction	1
1.1	Overview	1
1.2	Site location	1
2	Methodology	3
2.1	Overview	3
2.2	Guidance	3
2.3	Methodology	4
3	Source – Pathway – Receptor model	6
3.1	Overview	6
3.2	Sources	6
3.3	Pathways	8
3.4	Receptors	9
3.5	Summary	12
4	Control measures	13
4.1	Overview	13
4.2	Control measures	13
4.3	Maintenance of control measures	14
4.4	Emergency procedures	15
4.5	Summary	15
5	Risk assessment	16
5.1	Overview	16
5.2	Probability of exposure	16
5.3	Consequence of hazard	17
5.4	Magnitude of risk	19
6	Summary	21

1 Introduction

1.1 Overview

Thames Water Utilities Ltd (TW) is applying for a biological treatment permit (EPR/KP3305MR/A0001) to comply with the requirements of the Industrial Emissions Directive (IED) for the Aylesbury Sludge Treatment Centre (STC) (hereafter referred to as ‘the Site’) at Aylesbury Sewage Treatment Works (STW). Sludge treatment activity is covered by the Environmental Permitting Regulations (EPR) 2016, which incorporates the application of the Industrial Emissions Directive (IED). The Site currently operates under a T21 exemption and does not have an environmental permit.

Regulatory Position Statement 209¹, issued 23 January 2018 by the Environment Agency (EA), states that all sites that have a permit for the treatment of biological waste within 250 metres of a sensitive receptor (a place where people live or work for more than 6 hours at a time) must carry out a site-specific bioaerosol risk assessment. As sensitive receptors are found close to the boundary of the Site, the closest of which is approximately 40m from the nearest potential source of bioaerosols at the Site, a bioaerosol risk assessment has been undertaken to accompany the permit application for this Site.

This bioaerosol risk assessment has assessed the magnitude of risk from potential emissions of bioaerosols from the Site at nearby sensitive human health receptors. The assessment has been undertaken in accordance with the methods and principles outlined in the Environment Agency’s (EA) “*Guidance on the evaluation of bioaerosol risk assessments for composting facilities.*”²


1.2 Site location

The Site is situated within the Rabans Lane industrial estate in Aylesbury, within the administrative area of Aylesbury Vale District Council (AVDC). The location of the Site is shown in Figure 1.1.

¹ Environment Agency (2018) Bioaerosol monitoring at regulated facilities - use of M9: RPS 209. Available online at: <https://www.gov.uk/government/publications/bioaerosol-monitoring-at-regulated-facilities-use-of-m9-rps-209/bioaerosol-monitoring-at-regulated-facilities-use-of-m9-rps-209>

² Drew, G.H., Deacon, L.J., Pankhurst, L., Pollard, S.J.T. and Tyrrel, S.F. (2009). Guidance on the evaluation of bioaerosol risk assessments for composting facilities. Environment Agency.

Figure 1.1: Site location



2 Methodology

2.1 Overview

Bioaerosols are naturally present in the air, but they are also associated with composting, anaerobic digestion (AD) and mechanical biological treatment, which are the main processes used to treat organic waste in the UK.

Bioaerosols are micro-organisms which are suspended in the air; these can include bacteria, fungi and viruses, or parts of living organisms, such as spores and plant pollen. Bioaerosols range in size from 0.02-100µm but are generally smaller than 10µm in diameter so can easily be breathed into the human respiratory system where they can cause adverse health impacts such as respiratory and gastrointestinal illnesses. Especially relevant to waste treatment facilities are infections of the respiratory system caused by *Aspergillus fumigatus*, which can be fatal, especially for at-risk and immuno-compromised patients. Bioaerosols can also cause eye irritation and dermatitis if they come into contact with the eyes and skin.³

2.2 Guidance

There is minimal regulatory guidance available for assessing bioaerosol emissions from AD facilities. Regulatory Position Statement (RPS) 031⁴ states that bioaerosol concerns would normally be associated with composting activities, which are defined as: *'biological decomposition of biodegradable waste under conditions that are predominantly aerobic and that allow the development of thermophilic temperatures as a result of biologically produced heat'*.

This RPS also defines operations which are *'likely to result in the uncontrolled release of high levels of bioaerosols'* as including *'the shredding of waste and the turning of waste in the sanitisation, stabilisation and maturation stages of composting where these operations are not contained or are not subject to exhaust ventilation and scrubbing/filtering'*.

These activities do not occur at the Site as the biological decomposition of waste occurs under controlled, anaerobic conditions. Therefore, the Site is unlikely to be a high-risk site for bioaerosol emissions. This is supported by a 2012 EA guidance note⁵ which states that the EA do not consider bioaerosols from anaerobic digestion to be of serious concern (provided composting activities are not undertaken at the facility).

Nonetheless, current EA guidance⁶ requires any facility which could release bioaerosols to provide a site-specific bioaerosol risk assessment as part of the permit application if there are sensitive receptors within 250m of activities. For new permits there is also a requirement to monitor bioaerosols if the site is within 250m of a sensitive receptor⁷.

³ Drew, G.H., Deacon, L.J., Pankhurst, L., Pollard, S.J.T. and Tyrrel, S.F. (2009). Guidance on the evaluation of bioaerosol risk assessments for composting facilities. Environment Agency.

⁴ Environment Agency. 2011. Composting and potential health effects from bioaerosols: our interim guidance for permit applicants. Regulatory Position Statement 031.

⁵ Environment Agency. 2012. Guidance for developments requiring planning permission and environmental permits' (England)

⁶ Environment Agency (2018) Bioaerosol monitoring at regulated facilities - use of M9: RPS 209. Available online at: <https://www.gov.uk/government/publications/bioaerosol-monitoring-at-regulated-facilities-use-of-m9-rps-209/bioaerosol-monitoring-at-regulated-facilities-use-of-m9-rps-209>

⁷ "Sensitive receptor – any building, other structure or installation, in which at least one person normally lives or works, other than a building, structure or installation within the same ownership or control as the operator/owner of the composting facility." Taken from 'Guidance on the evaluation of bioaerosol risk assessments for composting facilities.'

The Site is part of a new permit application which includes new or replaced assets with the potential to release bioaerosols. Additionally, sensitive human health receptors are found within 250m of the activities at the Site which have the potential to release bioaerosols, therefore a bioaerosol risk assessment has been undertaken.

2.3 Methodology

The method used for this bioaerosol risk assessment is adapted from the EA's 'Guidance on the evaluation of bioaerosol risk assessments for composting facilities'⁸, which recommends using a Source-Pathway-Receptor model to help determine the magnitude of the risk associated with bioaerosol emissions from a facility.

The magnitude of risk is a function of both the probability of exposure and the consequences of the hazard. The probability of exposure to bioaerosols can be described as:


- High – exposure is probable, direct exposure likely with no/few barriers between source and receptor
- Medium – exposure is fairly probable, barriers less controllable
- Low – exposure unlikely, barriers exist to mitigate
- Very low – exposure very unlikely, effective and multiple barriers

The consequence of the hazard considers the nature of the source, the hazard and receptor. These consequences can be described as:

- High – severe consequences, evidence that exposure may result in serious damage
- Medium – significant consequences, evidence that exposure may result in damage that is not severe and is reversible
- Low – minor consequences, damage not apparent, reversible adverse changes possible
- Very low – negligible consequences, no evidence for adverse changes

The probability of exposure and consequence of the hazards are then combined to determine the overall magnitude of the risk, as demonstrated in Figure 2.1.

Figure 2.1: Magnitude of risk matrices



Source: Environment Agency, 2009

⁸ Drew, G.H., Deacon, L.J., Pankhurst, L., Pollard, S.J.T. and Tyrrel, S.F. (2009). Guidance on the evaluation of bioaerosol risk assessments for composting facilities. Environment Agency.

For this bioaerosol risk assessment, a Source-Pathway-Receptor model has been used to help assess the probability of exposure associated with different processes at the Site (Section 3). Existing control measures have also been identified to help inform the probability of exposure (Section 4) such as if the sources are covered, wet and/or at the stage of the treatment process that they are. For example, at the Site, processes which are not covered are wet apart from the cake, however as the sludge has already been through the digestion process and is at the end of the process for the cake, the risk of bioaerosol releases are lower at this stage. The probability of exposure has then been combined with the consequence of the hazard in Section 5 to determine the overall magnitude of risk associated with the different sources of bioaerosols at the Site, using the risk matrix above.

3 Source – Pathway – Receptor model

3.1 Overview

This section provides a summary of the sources of bioaerosols at the Site and the potential pathways that the bioaerosols could travel to sensitive human health receptors.

3.2 Sources

3.2.1 Overview

The Site includes the following assets which could release bioaerosols:


- One cess waste import area
- One sludge import tank
- Two sludge blending tanks
- One raw sludge dewatering building
- One digested sludge dewatering building
- One surplus activated sludge (SAS) tank
- One SAS dewatering building
- One digester feed tank
- Two primary digester tanks
- Six secondary digester tanks
- One gas bag holder
- One combined heat and power (CHP) plant
- Two boilers
- One biogas flare stack
- One cake barn
- One non-compliant cake storage area

The following processes undertaken at the Site involve these assets and therefore, have the potential to release bioaerosols:

- Sludge reception and distribution
- Sludge treatment
- Biogas combustion

Figure 3.1 shows the locations of these different processes and assets across the Site. A summary of the activities which occur at the Site involving these assets is provided within the subsequent sections.

Figure 3.1: Potential sources of bioaerosols at the Site



3.2.2 Sludge reception and distribution

The Site receives raw sludge from the Aylesbury STW primary settlement tanks to the primary digesters via two concrete sludge blending buffer tanks to undergo primary sludge thickening. In addition, imported sludge from satellite sites arrives to the STC approximately 3 times a day via enclosed tankers which discharge the sludge into the enclosed cess waste import area.

3.2.3 Sludge treatment

Indigenous primary sludge from the Aylesbury STW is pumped to two 549m³ uncovered concrete sludge blending tanks. The sludge is then pumped to the raw sludge dewatering building where it is subject to dewatering and thickening with the use of a powdered polymer⁹, before the thickened sludge is transferred to the uncovered 154m³ digester feed tank and mixed with dewatered SAS and imported raw sludge.

The combined sludge is pumped to two 2,094m³ to 1,979m³ covered primary digester tanks to undergo mesophilic anaerobic digestion (AD). After approximately 12 days, the digested sludge is then transferred and held in six 1,436m³ open topped steel secondary digesters for approximately 9 days.

The treated sludge from the secondary digesters is pumped to two dewatering belts within the dewatering building to increase the dry solids content in the sludge before discharging into the cake barn. Non-compliant cake from the dewatering process will be stored in the non-compliant cake pad storage area for disposal off site.

⁹ Polymer is made up from a bulk powder silo using potable water and is automatically made up and dosed to each press, as required.

3.2.4 Odour control

The site does not include any odour control units. The biological treatment process takes place within enclosed primary digestion tanks, however the remaining sludge treatment processes are uncovered.

A leak detection (methane gas analyser) is installed on the gas bag holder to ensure any leaks from the inner bag are detected. Any leaks detected on the biogas system would always be fixed immediately due to the process safety risk posed by biogas.


3.2.5 Biogas combustion

Biogas produced during AD is transferred to the gas bag holder and then to the CHP engine and boilers where it is combusted to generate heat and electricity, which is used onsite to assist with the sludge treatment processes and exported to the National Grid. When more biogas is produced onsite than can be combusted within the CHP and boilers and there is insufficient space in the gas bag holder to store surplus biogas, excess biogas is sent to the flare to be combusted.

3.3 Pathways

Bioaerosols are very small and light in weight so can easily be transport by the wind from source to a receptor. The 2016-2020 wind rose for the most representative meteorological site, RAF Benson (located approximately 29km south west of the Site), is shown in Figure 3.2. This meteorological site experiences dominance in winds from the south.

Figure 3.2: Average wind rose for RAF Benson meteorological site, 2016- 2020



Concentrations of bioaerosols decline rapidly within the first 100m from a source and generally decrease to background concentrations within 250m¹⁰. The local terrain in the 250m area surrounding the Site is generally flat, with some low-lying trees bordering the Site in all directions which could present natural obstacles to the transportation of bioaerosols by the wind.

3.4 Receptors

Environment Agency guidance¹¹ recommends a screening distance of 250m from bioaerosol emission sources to static receptor locations. Sensitive receptors are defined as:

¹⁰ Environment Agency. 2011. Composting and potential health effects from bioaerosols: our interim guidance for permit applicants. Regulatory Position Statement 031.

¹¹ Environment Agency (2018) Technical Guidance Note (Monitoring) M9 – Environmental monitoring of bioaerosols at regulated facilities. Available online at: https://assets.publishing.service.gov.uk/government/uploads/system/uploads/attachment_data/file/730226/M9_Environmental_monitoring_of_bioaerosols_at_regulated_facilities.pdf

'permitted activities where people are likely to be for prolonged periods. This term would therefore apply to dwellings (including any associated gardens) and to many types of workplaces. We would not normally regard a place where people are likely to be present for less than 6 hours at one time as being a sensitive receptor. The term does not apply to those controlling the permitted facility, their staff when they are at work or to visitors to the facility, as their health is covered by Health and Safety at Work legislation, but would apply to dwellings occupied by the family of those controlling the facility.'

There are multiple sensitive receptors found within 250m of potential bioaerosol emission sources at the Site. As demonstrated in Figure 3.3, these receptors are found predominantly to the south east of the Site. There are no sensitive receptors located downwind of the prevailing wind direction (north of the Site) within 250m.

Three areas of sensitive receptors have been identified below in Table 3.1 based on their location and receptor type. For each of these areas, the distance and direction from each potential bioaerosol emission source to the closest sensitive receptor within the area has been identified. Where multiple assets exist for the same process, such as digesters, only the closest asset has been presented.

The receptor closest to a potential emission source is a residential property south east of the STC, which is located approximately 40m north east of the cess waste import area.

Figure 3.3: Sensitive receptors within 250m




Table 3.1: Receptors within 250m of potential emission sources

Receptor	Nearest potential emission source to receptor	Process	Distance (m) from nearest potential emission source (a)	Direction of receptor from closest emission source
Residential property 1 to the south east of the Site	Cess waste import area	Sludge reception and distribution	40	North east
	Secondary digester tanks	Sludge treatment	90	South east
	Sludge import tank	Sludge reception and distribution	185	South east
	Boiler house	Biogas combustion	195	South east
	CHP	Biogas combustion	205	South east
	Primary digester tanks	Sludge treatment	210	South east
	Sludge blending tanks	Sludge treatment	195	South east
	SAS dewatering building	Sludge treatment	205	South east
	SAS tank	Sludge treatment	225	South east
	Cake barn	Sludge treatment	245	South east
Residential property 2 to the south	Cess waste import area	Sludge reception and distribution	65	South east
	Secondary digester tanks	Sludge treatment	235	South east

east of the Site	Sludge import tank	Sludge reception and distribution	235	South east
	Boiler house	Biogas combustion	240	South east
	Sludge blending tanks	Sludge treatment	245	South east
Rabans Lane industrial area (place of work) to the south east of the Site	Cess waste import area	Sludge reception and distribution	100	East

Notes: (a) Distance from source to receptor is rounded to the nearest 5m

3.5 Summary

Table 3.2 below summarises the potential sources of bioaerosol emissions at the Site within 250m of a sensitive receptor, the sensitive receptors most at risk and the pathways through which the bioaerosols could travel from source to receptor.

Table 3.2: Source-Pathway-Receptor model

Source process	Potential emission source	Pathway	Distance to nearest receptor (m)
Sludge reception and distribution	Cess waste import area	Air transport then:	40
	Sludge import tank	• Inhalation (through nose or mouth)	185
Sludge treatment	Primary digester tanks	• Ingestion (eating or swallowing)	210
	Secondary digester tanks	• Absorption/contact (through skin or eyes)	90
	Sludge blending tanks		195
	SAS dewatering building		205
	SAS tank		225
Biogas combustion	Cake barn		245
	Boilers		195
	CHP		205

4 Control measures

4.1 Overview

The three primary ways to mitigate emissions of bioaerosols¹² is to:

- Reduce emissions
- Contain emissions
- Enhance dispersion

The sections below outline the different control measures in place at the Site. These control measures aim to reduce and contain emissions of bioaerosols to prevent the source-pathway-receptor link associated with each of the potential emission sources identified in Section 3.2.5.

4.2 Control measures

4.2.1 Sludge reception and distribution

Domestic sludge is delivered directly into the two concrete blending tanks through an enclosed connection. Imported sludge is offloaded from an enclosed tanker into the enclosed cess waste import area.

If a spillage occurs, operators will carry out clean up as soon as possible. If the spillage is caused by a lorry or tanker, the driver is responsible for cleaning up the spill before leaving site. If a lorry or tanker left a spillage behind, operators will log and report any incident observed and the driver or company involved will be asked to return to the site immediately to clean up. Significant spillage incidents will be recorded in the site diary.

Lorry and tanker drivers are required to hose down any spillage after each loading or unloading. No wheel wash facility is available on the Site but a standpipe is available and can be utilised to wash spillage from vehicles as required. Vehicles entering public roads are not permitted to enter cake storage areas.

4.2.2 Sludge treatment

4.2.2.1 Containment of emissions

To contain emissions of bioaerosols during sludge treatment, doors, covers and hatches to the buildings housing the sludge reception and distribution works and sludge treatment works are kept closed at all times except when access is required. When access is required for operation and maintenance, the doors and hatches to these treatment facilities will only be opened for minimum periods. If access is required for an extended period of time, such as for maintenance activities, the sludge process area will be isolated and process stream diverted or sludge removed from site via tankers to allow maintenance. Sludge will be contained within the existing process areas and therefore no additional bioaerosols will be released.

To further contain bioaerosol emissions, the primary digester tanks used for AD are covered. The remaining processes are not covered, however the sludge is wet for all stages apart from the cake, so the likelihood of the resuspension of bioaerosols is minimised. The cake is at the

¹² Wheeler P.A., Stewart, I., Dumitrean, P. and Donovan, B., 2001. Health Effects of Composting: A Study of Three Compost Sites and Review of Past Data. R&D Technical Report P1-315/TR, Environmental Agency, Bristol.

end of the treatment process and therefore concentrations of bioaerosols are lower at this stage.

4.2.2.2 Reduce emissions

Throughout the sludge treatment process, biological material which could give rise to emissions of bioaerosols is broken down, which primarily occurs during AD. Therefore, at each stage of the sludge treatment process, the quantity of bioaerosols decreases; the concentration of bioaerosols that could potentially be emitted from the cake (at the end of the sludge treatment process) is much lower than from the primary settlement tanks (before AD).

To further reduce potential bioaerosol emissions, sludge produced on Site and sludge that is delivered is processed immediately. This prevents processing of old sludge which is more odorous and difficult to process.

The processed sludge is transferred by two dewatering belts within the dewatering building to the cake barn. The cake barn has a roof but is otherwise open to air, however once deposited, the cake is not disturbed until loaded into enclosed trucks for offsite disposal. If non-compliant cake is produced, this is stored in the non-compliant cake storage area before also being transferred off site by enclosed trucks.

4.2.3 Biogas combustion

All tanks capable of producing biogas are sealed and connected to the biogas system. Biogas produced from these tanks is stored within the gas bag holder before being combusted at high temperatures within the CHP, boilers or flare. The gas bag holder stores the biogas within an air-tight bag which mitigates the release of bioaerosol emissions. During combustion, any bioaerosols present within the biogas would be destroyed. The biogas system is also carefully monitored so that any leaks can be immediately identified and sealed. Therefore, emissions of bioaerosols associated with biogas combustion and probability of exposure to bioaerosols would be de minimis.

4.3 Maintenance of control measures

Daily checks, measurements and sampling is conducted of the treatment processes on site to ensure the equipment is working correctly. The parameters measured include sludge blanket thickness, turbidity and temperature. The quality of the treated air from the odour control unit is also monitored for hydrogen sulphide (H₂S) concentrations and recorded on the site SCADA system. Where desired operating parameters are not met, various corrective actions and operating procedures are in place to rectify the problem. Performance issues and equipment problems are also reported promptly to Process Scientists, M&E technicians, ICA technicians or Specialist Contractors as appropriate.

Daily, weekly and monthly maintenance tasks/servicing is also performed on key equipment across the Site by TW staff and specialist contractors if needed. TW have also issued generic maintenance task manuals for use across all their sites which include protocols for the maintenance of equipment.

Stocks of chemicals onsite are also carefully managed to ensure there are sufficient stocks of chemicals on site so that the necessary treatment processes, control measures and maintenance activities can be undertaken when required.

4.4 Emergency procedures

In the event of plant failures or emergency situations, an alarm would be raised on the Site Supervisory Control and Data Acquisition (SCADA) or telemetry systems, which will be reacted to by on-site or regional control room operators and Duty Managers. Depending upon the nature of the fault or emergency, where required, an operator would contact a mechanical or electrical technician, both of whom are on-call 24-hours, to attend site as soon as practicable. If the on-call technicians are already engaged upon other response work, there is the facility to access staff from other TW geographic divisions, coordinated by the Duty Manager. All faults, breakdowns and emergencies are logged electronically together with records of the action taken and the solutions reached.

One such emergency event would be failure of the flare stack and/or CHP. Such an event would result in releases of biogas from the Whessoe Valves located on the roofs of the digesters and in the gas holder compound, which would release bioaerosols. This occurs to prevent over pressurisation of the digesters and gas systems. While the problem is rectified, biogas generation is reduced by reducing or inhibiting the digester feed.

4.5 Summary

As discussed above, there are a number of control measures in place at the Site to reduce and contain emissions of bioaerosols. These control measures are regularly maintained to sustain their efficacy and reduce the risk of equipment failure. The greatest probability of exposure from bioaerosols emitted from the Site is from uncovered operations, however, all stages before the cake are 'wet' processes so the likelihood of the resuspension of bioaerosols, and therefore the probability of exposure, is minimised. The cake is at the end of the sludge treatment process, is managed to control row height and arrangement and requires no further treatment before being deposited on agricultural land and therefore is likely to have a low concentration of bioaerosols, therefore the probability of exposure from this source is also minimised.

Across the Site, the potential for bioaerosol emissions which could result in significant consequence is limited. The greatest risk of significant bioaerosols from the Site is associated with emergency situations such as a failure of the flare or CHP, which could result in uncontrolled emissions of bioaerosols. However, such events would be unlikely, temporary and infrequent due to the extensive monitoring and maintenance programmes undertaken at the Site as well as the emergency procedures and warning systems in place.

5 Risk assessment

5.1 Overview

This section assesses the probability of exposure and consequence of the hazard associated with potential emissions of bioaerosols at the Site to determine the overall magnitude of risk. The descriptors used ('very low' to 'high') are based on the descriptors outlined in the EA guidance¹³, as summarised in Section 2.3.

5.2 Probability of exposure

As described in Section 3, the main potential sources of bioaerosols at the Site are associated with:

- Sludge reception and distribution
- Sludge treatment
- Biogas combustion

These processes have the potential to emit bioaerosols, which are transported through the air by the wind and could cause harm to nearby human health receptors, the nearest of which is approximately 40m from the cess waste import area. However, as discussed in Section 4, there are multiple control measures in place at the Site which restrict the Source-Pathway-Receptor link by reducing and containing emissions of bioaerosols from these processes.

The probability of exposure of sensitive receptors to bioaerosols from uncovered sources at the Site, such as secondary digesters and blending tanks, is considered to be '**low**' as exposure of the receptors to bioaerosols is "unlikely" as some "barriers exist to mitigate" such as the 'wet' nature of the sludge.

Probability of exposure from the cess waste import area, primary digester tanks, boilers and CHP is considered to be '**very low**' as exposure of the receptors to bioaerosols is "very unlikely" due to the "effective and multiple barriers" (control measures) in place, which consist of covered processes.

The cake is at the end of the sludge treatment process and requires no further treatment before being deposited on agricultural land and therefore has also been considered to be '**very low**'.

The final probability of exposure to bioaerosols assessed for each emission source within 250m of a sensitive receptor is presented below in Table 5.1.

Table 5.1: Probability of exposure to bioaerosols from different sources at the Site

Process	Potential source of bioaerosols	Probability of exposure	Justification
	Cess waste import area	Very Low	Stringent loading and unloading procedures. Covered 'wet' process - uncontrolled release of bioaerosols unlikely

¹³ Drew, G.H., Deacon, L.J., Pankhurst, L., Pollard, S.J.T. and Tyrrel, S.F. (2009). Guidance on the evaluation of bioaerosol risk assessments for composting facilities. Environment Agency.

Sludge reception and distribution	Sludge import tank	Low	Uncovered, 'wet' process - uncontrolled release of bioaerosols unlikely
Sludge treatment	Primary digester tanks	Very Low	Covered, process monitored and regularly maintained – uncontrolled release of bioaerosols very unlikely
	Secondary digester tanks	Low	Uncovered, 'wet' process - uncontrolled release of bioaerosols unlikely
	Sludge blending tanks	Low	Uncovered, 'wet' process - uncontrolled release of bioaerosols unlikely
	SAS dewatering building	Low	Uncovered, 'wet' process - uncontrolled release of bioaerosols unlikely
	SAS tank	Low	Uncovered, 'wet' process - uncontrolled release of bioaerosols unlikely
	Cake barn	Very Low	Cake at the final stage of the sludge treatment process before being deposited on agricultural land – release of bioaerosols very unlikely as bioaerosol content of cake anticipated to be de minimis
Biogas combustion	Boilers	Very Low	Combustion of biogas at very high temperatures which would destroy bioaerosols – uncontrolled release of bioaerosols very unlikely
	CHPs	Very Low	Combustion of biogas at very high temperatures which would destroy bioaerosols – uncontrolled release of bioaerosols very unlikely

5.3 Consequence of hazard

While the probability of exposure of receptors to bioaerosols is predominantly '**very low**' or at worst '**low**' as a result of the control measures in place, there is still a risk that nearby receptors could be exposed bioaerosols, for example while cake is being loaded into lorries or if there is a failure of the control equipment. Should this occur, any exposure to bioaerosols would likely be temporary as the fault would be detected by the SCADA system and the emergency protocols would be undertaken to rectify the fault as soon as possible.

If exposure to bioaerosols did occur, the worst-case impacts could include adverse health impacts at sensitive receptors. These impacts could include (but are not limited to):

- Respiratory infections and inflammation of the respiratory system
- Reduced lung function
- Allergic reactions
- Gastro-intestinal disorders
- Dermatitis
- Eye irritation

The consequence of the hazard at sensitive receptors (i.e. the severity of impacts on human health) is largely determined by the proximity of the receptor to the emission source; concentrations of bioaerosols decline rapidly within the first 50-100m from a source (and generally decrease to background concentrations within 250m)^{14 15}. Therefore, receptors within 100m of bioaerosol emission sources will experience a greater hazard consequence than those

¹⁴ Environment Agency. 2011. Composting and potential health effects from bioaerosols: our interim guidance for permit applicants. Regulatory Position Statement 031.

¹⁵ Health and Safety Executive, 2010. Bioaerosol emissions from waste composting and the potential for workers' exposure.

more than 100m from the emission source. Receptors downwind of the prevailing wind direction which are more than 100m from an emission sources will also experience a greater hazard consequence than those upwind of the emission source at these distances.

For the purpose of this assessment, sources of bioaerosols within 50m of bioaerosol sources and downwind of the prevailing wind direction are considered to be ‘high’ consequence of hazard. This is because within 50m of a source, consequences could be “severe”, and “exposure may result in significant damage”, being downwind of the prevailing wind direction also increases the likelihood of exposure. Receptors within 50m of bioaerosols that are upwind of the prevailing wind direction are considered to have a ‘medium’ consequence of hazard, as though they are in close proximity to a bioaerosol source, they are less likely to be exposed due to the prevailing wind direction.

Sources of bioaerosols within 50-100m of receptors are considered to have a ‘medium’ consequence of hazard. This is because within 50-100m of the source, concentrations of bioaerosols would reduce, so temporary exposure could result in “significant consequences” and potentially result in “damage that is not severe and is reversible”. Beyond 100m, up to 250m, the consequence of the hazard is considered to be ‘low’ as concentrations of bioaerosols would be lower so the consequence of the hazard would also be lower, resulting in “minor consequences” where damage is “not apparent, reversible adverse changes possible”. Beyond 250m, the consequence is considered ‘very low’ as concentrations of bioaerosols generally decrease to background concentrations at this distance so there would be “no evidence for adverse changes” at sensitive receptors at this distance. The final consequence of hazard assessed for each emission source is presented below in Table 5.2.

Table 5.2: Consequence of hazard from bioaerosols

Process	Potential source of bioaerosols	Nearest receptor	Consequence of exposure	Justification
Sludge reception and distribution	Cess waste import area	40m north east, residential receptor	Medium	Nearest receptor <50m away from potential source, not downwind of prevailing wind direction
	Sludge import tank	185m south east, residential receptor	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction
Sludge treatment	Primary digester tanks	210m south east, residential receptor	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction
	Secondary digester tanks	90m south east, residential receptor	Medium	Nearest receptor <100m away from potential source, not downwind of prevailing wind direction
	Sludge blending tanks	195m south east, residential receptor	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction
	SAS dewatering building	205m south east, residential receptor	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction
	SAS tank	225m south east, residential receptor	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction
	Cake barn	245m south east, residential receptor	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction

Process	Potential source of bioaerosols	Nearest receptor	Consequence of exposure	Justification
Biogas combustion	Boilers	195m south east, residential receptor	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction
	CHP	205m south east, residential receptor	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction

Notes: All of the closest receptors to the potential sources of bioaerosols are upwind of the sources (north east or south east). Receptors which are downwind (north of the sources) are all located over 250m away from any source of bioaerosols and therefore the overall consequence of exposure would not change

5.4 Magnitude of risk

Table 5.3 below summarises the probability of exposure, consequence of hazard and resulting magnitude of risk for each potential bioaerosol emission source at the Site. Across all sources, there is a **'very low'** or **'low'** probability of exposure due to the nature of the processes and control measures in place which would prevent uncontrolled releases of bioaerosols. The consequence of exposure is described as **'low'** to **'medium'** depending on the potential emission source's proximity to sensitive receptors and the location of the receptor relative to the prevailing wind direction and potential emission source.

In accordance with EA guidance¹⁶, across all potential bioaerosol emission sources, the magnitude of risk is described as **'low'** or **'medium'** and therefore operation of the Site is unlikely to lead to significant impacts at nearby sensitive receptors from bioaerosol emissions.

Nonetheless, due to the proximity of the Site to sensitive receptors, monitoring of bioaerosols should be undertaken at the Site¹⁷. The requirements for bioaerosol monitoring at the Site will need to be agreed with the Environment Agency within the Environmental Permit issued for the site.

Table 5.3: Magnitude of risk from bioaerosols at the Site

Process	Potential source of bioaerosols	Probability of exposure	Consequence of exposure	Magnitude of risk	Justification
Sludge reception and distribution	Cess waste import area	Very Low	Medium	Low	Nearest receptor <50m away from potential source, not downwind of prevailing wind direction Covered 'wet' process and stringent loading and unloading procedures – uncontrolled release of bioaerosols unlikely
	Sludge import tank	Low	Low	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction Uncovered 'wet' process - uncontrolled release of bioaerosols unlikely

¹⁶ Drew, G.H., Deacon, L.J., Pankhurst, L., Pollard, S.J.T. and Tyrrel, S.F. (2009). Guidance on the evaluation of bioaerosol risk assessments for composting facilities. Environment Agency.

¹⁷ Natural Resource Wales (2014) Technical Guidance Note M17 (Monitoring) – Monitoring Particulate Matter in Ambient Air around Waste Facilities. Available online at: <https://naturalresources.wales/media/2129/technical-guidance-note-m17-monitoring-monitoring-particulate-matter-in-ambient-air-around-waste-facilities.pdf>

Process	Potential source of bioaerosols	Probability of exposure	Consequence of exposure	Magnitude of risk	Justification
Sludge treatment	Primary digester tanks	Very Low	Low	Low	Nearest receptor >100m from potential source, not downwind of prevailing wind direction Digesters covered, process monitored and regularly maintained – uncontrolled release of bioaerosols very unlikely
	Secondary digester tanks	Low	Medium	Medium	Nearest receptor <100m from potential source, not downwind of prevailing wind direction Process monitored and regularly maintained – Uncovered, 'wet' process - uncontrolled release of bioaerosols unlikely
	Sludge blending tanks	Low	Low	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction Uncovered 'wet' process - uncontrolled release of bioaerosols unlikely
	SAS dewatering building	Low	Low	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction Uncovered 'wet' process - uncontrolled release of bioaerosols unlikely
	SAS tank	Low	Low	Low	Nearest receptor >100m away from potential source, not downwind of prevailing wind direction Uncovered 'wet' process - uncontrolled release of bioaerosols unlikely
	Cake barn	Very Low	Low	Low	Nearest receptor >100m from potential source, downwind of prevailing wind direction Cake at the final stage of the sludge treatment process before being deposited on agricultural land – release of bioaerosols very unlikely as bioaerosol content of cake anticipated to be de minimis
Biogas combustion	Boilers	Very Low	Low	Low	Nearest receptor >100m from potential source, not downwind of prevailing wind direction Combustion of biogas at very high temperatures which would destroy bioaerosols - uncontrolled release of bioaerosols very unlikely
	CHPs	Very Low	Low	Low	Nearest receptor >100m from potential source, not downwind of prevailing wind direction Combustion of biogas at very high temperatures which would destroy bioaerosols - uncontrolled release of bioaerosols very unlikely

6 Summary

At the Site, there is the potential for bioaerosol emissions from:

- Sludge reception and distribution
- Sludge treatment
- Biogas combustion

Bioaerosol emissions associated with these processes could be transported by the wind to nearby sensitive human health receptors bordering the Site, resulting in adverse health effects. As these sensitive human health receptors are within 250m of potential emission sources at the Site, a bioaerosol risk assessment has been undertaken in accordance with EA guidance.

To inform the assessment, a Source-Pathway-Receptor model was developed and the control measures at the facility to reduce and contain bioaerosol emissions were reviewed. This was undertaken to determine the probability of exposure, consequence of hazard and overall magnitude of risk associated with different processes at the Site.

Based on the ‘very low’ and ‘low’ probability of exposure and ‘low’ to ‘medium’ consequence of hazards associated with different processes at the Site, the overall magnitude of the risk associated with bioaerosols emissions from the Site is considered to be predominantly ‘low’ with only one asset resulting in a ‘medium’ risk. This is primarily due to the ‘wet’ nature of several processes undertaken at the Site and the control measures in place, which are considered to be effective at reducing and containing emissions of bioaerosols, inhibiting the pathway between source and receptor.

6.1 Sampling

Sampling will take place in relation to SP 78975 14704 (approx. NGR of centre of the cake pad) which are diffuse sources and hence will be monitored purely by agar plates.

In line with M9, ambient sampling will be conducted to identify background emissions. A sampling round, consisting of four individual sampling points, each with its own agar plate will be carried out. One point will be located 50m upwind of the cake pad to give a background concentration, and three will be located in a fan like arrangement downwind and at the same distance to the nearest sensitive receptor (as per M9):

Source	Upwind Location NGR (S)	Downwind Location 1 NGR (N)	Downwind Location 2 NGR (NW)	Downwind Location 3 NGR (NE)
Cake Pad	SP 7897 1465	SP 7897 1497	SP 7883 1493	SP 7911 1494

*Location points may require to be changed due to the presence of existing structures making access unsafe or impractical

NGR’s for sampling locations are only 8 digits at present, to allow the contractor flexibility as to precise location, taking into account the ability to safely locate and access (and security) of the sampling plates.

