

Biomass Boiler

Boiler Model – Jutsen Flex

Number of boilers 1 Total thermal input 995 Kw

Exhaust stack height 8.375m

Adjacent building heights 6 m

Farm Centre Grid Reference

TA16624 34895

Exhaust stack Grid Reference

TA16684 34844

Biomass fuel – Approved biomass fuel – straw, virgin woodchip, miscanthus

Approx storage 50 tonnes, estimated annual use 1000 tonnes

Boiler ash will be securely stored. Boiler ash sent off site with spent litter and spread under U14 exemption.