



NOTES

KEY

- SIZEWELL C MAIN DEVELOPMENT SITE BOUNDARY
- - - DEMARCATION LINE
- COMBINED DISCHARGE OUTFALL LOCATION
- INTAKE TUNNEL
- COOLING WATER OUTFALL TUNNEL
- COOLING WATER DISCHARGE OUTFALL LOCATION
- COOLING WATER INTAKE LOCATION

PLUME EXTENT OF TOTAL RESIDUAL OXIDANT (TRO) 95TH PERCENTILE SURFACE

- $\geq 1 \mu\text{g/l}$
- $\geq 2 \mu\text{g/l}$
- $\geq 4 \mu\text{g/l}$
- $\geq 6 \mu\text{g/l}$
- $\geq 8 \mu\text{g/l}$
- $\geq 10 \mu\text{g/l}$
- $\geq 15 \mu\text{g/l}$
- $\geq 20 \mu\text{g/l}$

NOT PROTECTIVELY MARKED

COPYRIGHT
 Reproduced from Ordnance Survey map with the permission of Ordnance Survey on behalf of the controller of Her Majesty's Stationary Office © Crown Copyright (2019). All Rights reserved. NNB GenCo 0100060408.
 © CEFAS; Royal HaskoningDHV, 2019.



DOCUMENT:
 SIZEWELL C
 SHADOW HRA REPORT
 CHAPTER 5
 SCREENING OF POTENTIAL EFFECTS

DRAWING TITLE:
 95TH PERCENTILE OF TRO CONCENTRATIONS AT THE SURFACE FROM THE OPERATION OF SIZEWELL C.

DRAWING NO:
 FIGURE 5.5

DATE: JAN 2020 **DRAWN:** J.T. **SCALE:** 1:100,000 @A3

