

Sizewell C | 101277766 / 002 | P1 - For Implementation | 04-Jun-2024 | NOT PROTECTIVELY MARKED

## Sizewell C Project

# EPR/GP3226SQ/A001 Request for Information: Noise – BS 4142:2014 + A1:2019 Assessment

© Copyright 2024 Sizewell C Limited. All rights reserved.

Sizewell C Limited. Registered in England and Wales. Registered No. 09284825. Registered Office: 90 Whitfield Street, London, W1T 4EZ

Template No: SZC-SZ0000-XX-000-TEM-100000 UNCONTROLLED WHEN PRINTED  
Template Revision: 02

**NOT PROTECTIVELY MARKED**

Copyright 2024 Sizewell C Limited. All rights reserved.

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

## DOCUMENT CONTROL

This document is stored and approved in the Electronic Document and Records Management System (EDRMS).

<b>Prepared by:</b>	[REDACTED] Senior Consultant
<b>Verified by:</b>	[REDACTED] Associate Director / Associate
<b>Reviewed by:</b>	[REDACTED] Environment Consents and Permits Delivery Lead
<b>Approved by:</b>	[REDACTED] Sizewell C Environment Manager – Construction Permits and Consents

## REVISION HISTORY

Rev	Status	Amendment	Prepared By	Date
01	Final	First Issue	[REDACTED]	23/05/2024
02	Final	Update following EA comments	[REDACTED]	04/06/2024

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

## CONTENTS

<b>1</b>	<b>INTRODUCTION</b> .....	<b>5</b>
<b>1.1</b>	<b>Purpose</b> .....	<b>5</b>
<b>1.2</b>	<b>Scope</b> .....	<b>5</b>
<b>1.3</b>	<b>Definitions</b> .....	<b>6</b>
<b>1.4</b>	<b>References</b> .....	<b>7</b>
<b>2</b>	<b>TERMINOLOGY</b> .....	<b>9</b>
<b>2.1</b>	<b>The decibel scale, A-weighting &amp; typical sound levels</b> .....	<b>9</b>
<b>2.2</b>	<b>Sound power, sound level indices and other descriptors</b> .....	<b>9</b>
<b>3</b>	<b>ASSESSMENT GUIDANCE</b> .....	<b>12</b>
<b>3.1</b>	<b>BS 4142:2014 + A1:2019 Methods of rating and assessing industrial and commercial sound [1]</b>	<b>12</b>
<b>4</b>	<b>ASSESSMENT METHODOLOGY</b> .....	<b>14</b>
<b>4.1</b>	<b>Baseline background sound levels</b> .....	<b>14</b>
<b>4.2</b>	<b>Calculations and assessment</b> .....	<b>14</b>
<b>5</b>	<b>BASELINE SOUND MONITORING</b> .....	<b>16</b>
<b>6</b>	<b>NOISE MODELLING</b> .....	<b>19</b>
<b>6.1</b>	<b>Model inputs</b> .....	<b>19</b>
6.1.1	Static generators.....	19
6.1.2	Mobile generators.....	21
<b>6.2</b>	<b>Model results</b> .....	<b>22</b>
<b>7</b>	<b>BS 4142 ASSESSMENT</b> .....	<b>24</b>
<b>7.1</b>	<b>Establishing rating level (L<sub>Ar,Tr</sub>)</b> .....	<b>24</b>
<b>7.2</b>	<b>Initial estimate of noise impact</b> .....	<b>24</b>
<b>7.3</b>	<b>Context</b> .....	<b>25</b>
7.3.1	Absolute level of the sound.....	25
7.3.2	Character and level of the residual sound compared to the character and level of the specific sound ...	27
	DCO construction noise data.....	27
	Screening of generator noise model results vs DCO predicted construction noise levels.....	31
7.3.3	The sensitivity of the receptor and incorporated design measures.....	33
	Sensitivity of receptors.....	33
	Incorporated design measures.....	33
<b>7.4</b>	<b>Uncertainty</b> .....	<b>33</b>
<b>7.5</b>	<b>Summary</b> .....	<b>34</b>
7.5.1	Establishing rating level.....	34
7.5.2	Initial estimate of noise impact.....	34

Sizewell C | 101277766 / 002 | P1 - For Implementation | 04-Jun-2024 | NOT PROTECTIVELY MARKED

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

7.5.3	Context – absolute level of the sound .....	34
7.5.4	Context – character and level of the residual sound compared to the character and level of the specific sound .....	34
7.5.5	Context – sensitivity of receptors and incorporated design measures .....	35
7.5.6	Uncertainty .....	35
7.5.7	Estimate of noise impact .....	35
<b>8</b>	<b>CONCLUSIONS .....</b>	<b>37</b>

A - APPROVED

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

## 1 INTRODUCTION

### 1.1 Purpose

Sizewell C Ltd (SZC) submitted a permit application for an installation activity environmental permit, EPR Schedule 1, Section 1.1A(1)(a): Burning of any fuel in an appliance with a rated thermal input of 50 MW or more for the installation of diesel generators within the Main Development Site (MDS) on 12<sup>th</sup> April 2024.

A request for further information was received from the Environment Agency (EA) on 10<sup>th</sup> May 2024. Within this, it was noted that the following was missing:

“Noise – Screening Assessment

- 1) *Where no BS 4142 assessment is being carried out, clearly state your screening methodology showing that sound emissions from the proposed generators are low risk. Include detailed supporting evidence such as detailed sound propagation calculations used to arrive at your conclusions.*
- 2) *Provide raw background sound level measurements (including time, date, LA90, LAeq, LMax at each survey location) in an Excel spreadsheet format and any accompanying computer modelling files or calculation spreadsheets.*

*Reason: The submitted report assesses the overall sound emissions from the construction phase of the Sizewell C Nuclear Plan according to BS 5228. The Environment Agency is only permitting the sound emissions from the power generators; therefore, a separate assessment is required to evaluate the sound emissions from these power generators. The Environment Agency guidance clear states, “you must use ‘BS 4142: Methods for rating and assessing industrial and commercial sound’ to quantify the level of environmental noise impact from industrial processes”. In addition to this the BS 4142 standard states within Section 1.1 b), detailing the scope of the standard, that “sound from fixed installations which comprise mechanical and electrical plant and equipment” should be assessed using the BS 4142 method.*

*Where no BS 4142 assessment is being carried out, you must undertake screening to show that sound emissions from the proposed generators are low risk. Where the possibility of impacts, due to sound emissions from the proposed generators, cannot be ruled out at any residential receptor, you must carry out a detailed BS 4142 assessment at these residential receptors. This would be required during determination of the permit application. The Environment Agency will scrutinise the screening methodology used. If we disagree with the screening outcomes in a location, then we will also require a full BS 4142 assessment at that location during determination.”*

### 1.2 Scope

This report presents a BS 4142:2014 + A1:2019 [1] (BS 4142) assessment of the sound levels likely to be generated by the proposed generators at the nearest residential receptors.

An updated round of baseline monitoring has recently been conducted to feed into the Code of Construction Practice (CoCP) and Noise Monitoring and Management Plan (NMMP) control documents for the MDS, including the Ancillary Construction Area (ACA). The BS 4142 [1] assessment draws upon the results of this monitoring, with the raw data provided alongside the submission of this assessment.

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

This assessment has been conducted in accordance with BS 4142 [1], including the use of baseline background sound levels. It should be noted that it is not typical to implement BS 4142 [1] for construction noise, with Section 1.3 of the standard stating *‘The standard is not intended to be applied to the rating and assessment of sound from: ... d) construction and demolition;...’*, which the activities in this permit application would be expected to fall under. The proposed generators will be operating within a construction site, and it is therefore not considered to be in accordance with the scope of the standard to compare the operational sound levels of the generators to the existing baseline background levels at the nearby residential receptors in the absence of the construction activities. Notwithstanding this, SZC has completed a BS 4142 [1] assessment to respond to the EA’s request for further information.

### 1.3 Definitions

Term / Abbreviation	Definition
ACA	Ancillary Construction Area
AD	Associated Development
BMP	Bespoke Mitigation Plan
BPM	Best Practicable Means
BS 4142	British Standard BS 4142:2014 + A1:2019 Methods for rating and assessing industrial and commercial sound
BS 5228	British Standard BS 5228-1:2009 + A1:2014 Code of practice for noise and vibration control on construction and open sites – Part 1: Noise
CoCP	Code of Construction Practice
CoPA	Control of Pollution Act 1974
dB	Decibel
DCO	Development Consent Order
EA	Environment Agency
EDRMS	Electronic Document and Records Management System
ES	Environmental Statement (Book 6, Volume 2)
ESC	East Suffolk Council
ISO 9613	International Organization for Standardization ISO 9613-2:1996 Acoustics – Attenuation of sound during propagation outdoors Part 2: Engineering method for the prediction of sound pressure levels outdoors

Sizewell C | 101277766 / 002 | P1 - For Implementation | 04-Jun-2024 | NOT PROTECTIVELY MARKED

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

Term / Abbreviation	Definition
L <sub>A90,T</sub>	The A-weighted sound level exceeded 90% of the time / background sound level
L <sub>Aeq,T</sub>	The A-weighted equivalent continuous sound level / ambient sound level
L <sub>Amax,T</sub>	The A-weighted maximum recorded sound level
L <sub>Ar,Tr</sub>	Rating level
L <sub>r</sub>	Residual sound
L <sub>s</sub>	Specific sound
MCA	Main Construction Area
MDS	Main Development Site
NMMP	Noise Monitoring and Management Plan
NSR	Noise Sensitive Receptor
SPL	Sound Pressure Level
SWL	Sound Power Level
SZC	Sizewell C
TCA	Temporary Construction Area

### 1.4 References

Ref	Title	Location	Document No.
1	British Standard Institution (2019). <i>BS 4142:2014 + A1:2019 Methods for rating and assessing industrial and commercial sound</i> . BSI, London.	N/A	N/A
2	Bies, D.A., Hansen, C.H., 2009. <i>Engineering Noise Control: Theory &amp; Practice. 4<sup>th</sup> Edition</i> . Abingdon: Spon Press.	N/A	N/A
3	Book 6, Volume 2 Main Development Site Chapter 11 Noise and Vibration	Online	<a href="https://infrastructure.planninginspectorate.gov.uk/wp-content/ipc/uploads/projects/EN010012/EN010012-001822-SZC_Bk6_ES_V2_Ch11_Noise_and_Vibration.pdf">https://infrastructure.planninginspectorate.gov.uk/wp-content/ipc/uploads/projects/EN010012/EN010012-001822-SZC_Bk6_ES_V2_Ch11_Noise_and_Vibration.pdf</a>



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

Ref	Title	Location	Document No.
4	International Organization for Standardization (1996), <i>ISO 9613-2:1996 Acoustics – Attenuation of sound during propagation outdoors Part 2: Engineering method for the prediction of sound pressure levels outdoors</i>	N/A	N/A
5	Appendix C: Air Emission Risk Assessment	EDRMS	101254803
6	Ordnance Survey OS open-source Data – OS Terrain 50	Online	<a href="https://www.ordnancesurvey.co.uk/products/os-terrain-50">https://www.ordnancesurvey.co.uk/products/os-terrain-50</a>
7	Ordnance Survey OS open-source Data – OS OpenMap - Local	Online	<a href="https://osdatahub.os.uk/downloads/open/OpenMapLocal">https://osdatahub.os.uk/downloads/open/OpenMapLocal</a>
8	British Standard Institution (2014). <i>BS 5228-1:2009 + A1:2014 Code of practice for noise and vibration control on construction and open sites – Part 1: Noise</i> . BSI, London.	N/A	N/A
9	Code of Construction Practice (Revision 7)	Online	<a href="https://infrastructure.planninginspectorate.gov.uk/wp-content/ipc/uploads/projects/EN010012/EN010012-008183-Carly%20Vince%20-%20Other-%20Code%20of%20Construction%20Practice%20(clean%20version).pdf">https://infrastructure.planninginspectorate.gov.uk/wp-content/ipc/uploads/projects/EN010012/EN010012-008183-Carly%20Vince%20-%20Other-%20Code%20of%20Construction%20Practice%20(clean%20version).pdf</a>
10	Noise Monitoring and Management Plan - Main Development Site (including Land East of Eastlands Industrial Site), Revision 4.0	Online / EDRMS	<a href="#">DC/24/0363/DRR42</a> 191254668
11	UK Government (1974). <i>Control of Pollution Act 1974</i> .	N/A	N/A



## 2 TERMINOLOGY

This section provides explanations and definitions for the terms used in this report.

### 2.1 The decibel scale, A-weighting & typical sound levels

The ratio between the quietest audible sound and the loudest tolerable sound is a million to one in terms of the change in sound pressure. Due to this wide range, a scale based on logarithms is used in noise level measurement. The scale used is the decibel (dB) scale which, in terms of human response to airborne sound, typically covers a range of 0 to 140dB, corresponding to the intensity of the Sound Pressure Level (SPL).

The human ear has the ability to recognise a particular sound depending on the pitch or frequencies found at the source. Microphones cannot differentiate noise in the same way as the ear; to counter this weakness the noise measuring instrument applies a correction to correspond more closely to the frequency response of the ear. The correction factor is called ‘A-weighting’, and the resulting measurements are written as dBA or dB(A). ‘A-weighting’ refers to the sound level that represents the human ear’s response to sound. The frequency weighting may be included in the descriptor (see **Section 2.2**), in which case the unit is described only as dB.

The dB(A) unit is internationally accepted and has been found to correspond well with people’s subjective reaction to sound. Typical dB(A) sound levels for familiar sounds are given in **Table 2.1**.

**Table 2.1 Typical sound levels [2]**

Approximate noise level dB(A)	Example
0	Threshold for hearing for normal young people
20	Recording studio, ambient level
40	Quiet residential neighbourhood, ambient level
60	Department store, restaurant, speech levels
80	Next to busy highway, shouting
100	Textile mill; press room with presses running; punch press and wood planers, at operators’ position
120	Ship’s engine room, rock concert, in front and close to speakers
140	Moon launch at 100m; artillery fire, gunner’s position.

### 2.2 Sound power, sound level indices and other descriptors

The sound levels given in **Table 2.1** are sound pressure levels ( $L_p$ ) and describe the sound level at a point in space. Sound power levels ( $L_w$ ) are used to describe the sound output of a sound source. Sound levels vary over time depending on sound generating activities. The following indices are used to take account of these variations:

- $L_{Aeq,T}$  – the equivalent continuous sound level. This is the sound level of a steady sound having the same energy as a fluctuating sound over the same period. Ambient sound levels are described with this index.  $L_{Aeq,T}$  is considered the best general-purpose index for

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

environmental sound, as it is the index which generally best represents how sound levels are perceived;

- **$L_{A90,T}$**  – this noise index represents the sound levels exceeded for 90% of the measurement period and is used to indicate quieter times during the measurement period. In BS 4142 [1] assessments it is usually referred to as the background sound level, and describes the quietest 10% of a measurement period; and
- **$L_{Amax}$**  – is the maximum recorded sound level during the measurement period.

In addition, the following descriptors are often used in noise assessments:

- **Ambient sound** is the totally encompassing sound in a given situation, at a given time, usually composed of sound from many sources near and far;
- **Residual sound** is the sound remaining at the assessment location where the specific sound source is suppressed to such a degree that it does not contribute to the ambient sound. This is the case when a sound source/proposed development is yet to be installed and/or be operational. The residual sound level is the equivalent continuous A-weighted sound pressure level deemed to represent the residual sound ( $L_r = L_{Aeq,T}$ ) at the assessment location over a given time interval  $T$ ;
- **Specific sound level** is the equivalent continuous A-weighted sound pressure level produced by a specific sound source (i.e. the sound source under assessment in accordance with BS 4142 [1]) at the assessment location over a given reference time interval  $T$ ;
- **Rating level** is the specific sound level with the addition and inclusion of any acoustic characteristic feature corrections of the sound. If no acoustic features are present, then the rating level is equal to the specific sound level;
- **Fast time weighting** is where a sound pressure level measurement using a 125 ms moving average time weighting period has been used;
- **Tonality** is an acoustic feature which represents the sound level of a source that has a dominant 'pitch' characteristic similar to a sine wave or musical note. Sounds with a perceptible tone are more easily noticeable and should therefore carry a character correction where deemed appropriate under the guidance in BS 4142 [1];
- **Impulsivity** is an acoustic feature where the sound level of a source is highly variable over time. Humans are more sensitive to impulsive sound when compared to a continuous sound of the same sound pressure level. Therefore, an acoustic character feature correction can be applied when deemed appropriate under the guidance in BS 4142 [1].
- **Intermittency** is an acoustic feature considered in BS 4142 [1]. Humans are more sensitive to sounds that are intermittent in nature when compared to a continuous sound of the same specific sound level. Therefore, a correction can be applied for the presence of such a characteristic.
- **Free field** signifies that a sound measurement has been undertaken in 'free field' conditions, i.e. away from any reflecting facades, other than the ground, e.g. building facades, close boarded fence work, etc.; and
- **Façade level:** A standard correction of +3dB may be added to a free field sound level to estimate the sound level 1m away from a façade to account for both the sound upon the façade and the reflected sound from the façade. When considering the break-in of external sound into a room, the sound level which is incident upon the façade, rather than the façade

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

level, is considered because only the incident sound will pass through the fabric of the building, whilst reflected sound travels away from the building. The standard +3dB façade correction is most applicable in situations where the façade has a relatively unobstructed angle of view of the source (i.e. an uninterrupted 180° angle of view of the source in the horizontal plane).

A - APPROVED

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

### 3 ASSESSMENT GUIDANCE

#### 3.1 BS 4142:2014 + A1:2019 Methods of rating and assessing industrial and commercial sound [1]

Section 1.1 of BS 4142 [1] states that:

*“This British Standard describes methods for rating and assessing sound of an industrial and/or commercial nature, which includes:*

- *sound from industrial and manufacturing processes;*
- *sound from fixed installations which comprise mechanical and electrical plant and equipment;*
- *sound from the loading and unloading of goods and materials at industrial and/or commercial premises; and*
- *sound from mobile plant and vehicles that is an intrinsic part of the overall sound emanating from premises or processes, such as that from forklift trucks on or around an industrial and/or commercial site.*

*The methodology contained within BS 4142 uses outdoor sound levels to assess the likely effects of sound on people who might be inside or outside a dwelling or premises used for residential purposes upon which the sound is incident.”*

Section 1.3 of BS 4142 [1] states that:

*“This standard is not intended to be applied to the rating and assessment of sound from:*

- a) recreational activities, including all forms of motorsport;*
- b) music and other entertainment;*
- c) shooting grounds;*
- d) construction and demolition;*
- e) domestic animals;*
- f) people;*
- g) public address systems for speech; and*
- h) other sources falling within the scopes of other standards or guidance.”*

A summary of the approach set out within BS 4142 [1] is set out below:

- establish the specific sound level of the source(s);
- establish the representative background sound level, typically by measurement close to the receptor location;
- rate the specific sound level to account for any distinguishing characteristics (see below);
- estimate the impact by subtracting the background sound level from the rating level; and
- consider the initial estimate of the impact, as determined above, in the context of the noise and its environment.

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

The specific sound level is rated to account for distinguishing characteristics by using the following penalties:

- tonality up to 6dB<sup>1</sup>
- impulsivity up to 9dB<sup>2</sup>
- intermittency 3dB
- other sound characteristics 3dB

The corrections provided above could be applied in a linear fashion. However, this could result in some large penalties, and it is recommended that where two characteristics are present, and one is dominant, that the larger of the two is used.

An initial estimate of the impact of the specific sound is obtained by subtracting the background sound level from the rating level. Using this approach, BS 4142 [1] states:

*“Typically, the greater this difference, the greater the magnitude of impact*

- *a difference of around +10dB or more is likely to be an indication of a significant adverse impact, depending on the context*
- *a difference of around +5dB is likely to be an indication of an adverse impact, depending on the context*
- *the lower the rating level is relative to the measured background sound level, the less likely it is that the specific sound source will have an adverse impact or a significant adverse impact. Where the rating level does not exceed the background sound level, this is an indication of the specific sound source having a low impact, depending on the context.”*

The results of the final assessment should be reached in light of all pertinent contextual factors, including:

- the absolute level of the sound;
- the character and level of the residual sound compared to the character and level of the specific sound;
- the sensitivity of the receptor; and
- the overall context in which the application is being put forward.

<sup>1</sup> BS 4142 suggests that a penalty of “2dB for tone which is just perceptible at the receptor, 4dB where it is clearly perceptible and 6dB where it is highly perceptible” could be applied.

<sup>2</sup> BS 4142 suggests that a penalty of “3dB for impulsivity which is just perceptible at the receptor, 6dB where it is clearly perceptible and 9dB where it is highly perceptible” could be applied.



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

## 4 ASSESSMENT METHODOLOGY

### 4.1 Baseline background sound levels

Baseline sound levels pertinent to this assessment were obtained between 2013 and 2019, with the methodology and results presented within the ES, Volume 2 Chapter 11 of the DCO [3]. An updated round of baseline sound monitoring has been undertaken between September 2023 and May 2024 to feed into the Code of Construction Practice (CoCP) and Noise Monitoring and Management Plan (NMMP) control documents for the MDS, including the Ancillary Construction Area (ACA). The background sound levels of the BS 4142 [1] assessment draw upon the recent data, and not the data presented within the DCO [3].

The baseline noise measurements have been derived without the presence of any associated construction activity. It should be noted that the activity proposed in the permit application (use of generators) would happen concurrently with construction activities on the MDS, including the TCA and ACA, and therefore the baseline background levels used in the assessment represent a worst-case assessment scenario and do not reflect the reality of the situation that will occur.

### 4.2 Calculations and assessment

The generators included within the permit application EPR/GP3226SQ will generate sound. Sound levels at the nearest residential receptors due to the proposed generators have been predicted using SoundPLAN 8.2 acoustic modelling software which implements ISO 9613-2:1996 *Acoustics – Attenuation of sound during propagation outdoors – Part 2: General method of calculation* [4] prediction methodology.

The model consists of a detailed three-dimensional representation of the application site and the surroundings and has been employed to calculate the sound levels likely to be generated by the proposed generators at the nearest receptors.

The model has taken the following into consideration:

- the peak use of generators has been modelled, as described in Appendix C: Air Emission Risk Assessment [5] of the permit application;
- OS open-source Terrain data [6] has been incorporated into the model for the application site and surrounding area, extending to encompass the nearest receptors;
- OS open-source building data [7] has been incorporated into the model, set to include three no. order of reflections from solid structures. All buildings have been set to a height of 8m;
- the static generators included within Appendix C: Air Emission Risk Assessment of the permit application [5] have been incorporated into the model, at a height of 3m;
- the mobile generators included with Appendix C: Air Emission Risk Assessment of the permit application [5] have been incorporated and modelled as area sources, with the total sound power level spread across the area to represent a realistic worst case, at a height of 3m;
- the nearest residential receptors included within Appendix C: Air Emission Risk Assessment of the permit application [5] have been incorporated into the model, at a height of 1.5m for daytime representation;

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

- the percentage on times reported in the emission inventory (peak) spreadsheet (package substations tab) have been assumed within the model. Where a percentage on time was not included, it has been assumed the on time is 100%;
- ground absorption has been included, set to a value of 0.5 for a conservative assessment; and
- all eight barriers included within the ES of the DCO application [3] have been incorporated into the model.

The hours of operation for the proposed generators are 07:00 – 23:00, Monday - Friday. Therefore, no night-time assessment is required.

A - APPROVED



Document Reference Number: 101277766  
Revision 02

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

## 5 BASELINE SOUND MONITORING

Baseline sound monitoring was carried out at the locations in **Figure 5.1** between September 2023 and May 2024. **Table 5.1** presents a summary of the daytime background levels for each identified residential Noise Sensitive Receptor (NSR) in Appendix C: Air Emission Risk Assessment of the permit application [5]. The exception to this is R4 – Ash Wood Cottage which is now a vacant property, and therefore not considered as an NSR.

As stated in **Section 1.2**, this assessment draws upon a recent round of updated baseline noise monitoring. The raw data has been provided to the EA in the requested format (a spreadsheet including time, date,  $L_{A90}$ ,  $L_{Aeq}$  and  $L_{Amax}$  at each survey location) alongside this report, which also includes commentary on the analysis of the baseline background levels.

**Table 5.1 Summary of background levels at each NSR**

NSR Number	NSR Name	Measurement Reference	Location Rationale	Typical $L_{A90,T}$ (dB) daytime
1	Abbey Cottages	MS14	Measurement location is within 100m of the NSR.	44
2	Abbey Farm	MS5	Measurement location is within 100m of the NSR.	31
3	Abbey Road, Leiston	MS19	Measurement location is within 100m of the NSR.	40
5	Barley Rise	MS42 / MS41	Measurement location is approximately 200m east of the NSR. Measurement location is expected to have the same sound environment as the NSR and the location is therefore representative.	39
6	Common Cottages	MS26	Measurement location is approximately 500m south of the NSR. The measurement location is expected to have the same sound environment as the NSR (similar distance from Lover's Lane and Sandy Lane) and the location is therefore representative.	42
7	Crown Lodge	MS30	Measurement location is slightly set back from Lover's Lane and King George's Avenue compared to the NSR and is therefore considered conservatively representative of the sound environment at the NSR.	39
8	Eastbridge	MS1	Measurement location is approximately 130m south of the NSR and is expected to have the same sound environment as the NSR.	33

# NOT PROTECTIVELY MARKED

Document Reference Number: 101277766  
Revision 02



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:

NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

NSR Number	NSR Name	Measurement Reference	Location Rationale	Typical L <sub>A90,T</sub> (dB) daytime
9	Grimsey's Lane	MS42 / MS41	Measurement location is approximately 300m north of NSR and is expected to have a similar sound environment as the NSR. Limited traffic movements on Sizewell Gap are not expected to influence the L <sub>A90,T</sub> levels.	39
10	Heath View	MS45a	Measurement location is approximately 100m north of NSR and is expected to have the same sound environment as the NSR.	48
11	Keepers Cottage	MS26	Monitoring location is approximately 200m south of NSR and is expected to have the same sound environment as the NSR.	42
12	King George's Avenue	MS29	Monitoring location is approximately the same distance from King George's Avenue as the NSR and is expected to have the same sound environment as the NSR.	36
13	Leiston Abbey	MS15	Monitoring location is approximately 600m east of NSR, and approximately 350m from Abbey Road (NSR is approximately 250m from Abbey Road). Measurement location is considered conservatively representative of the sound environment at the NSR.	39
14	Lover's Lane / Sandy Lane Junction	MS25	Monitoring location is within 100m of the NSR.	42
15	Old Abbey Farm / Care Home	MS15	Monitoring location is approximately 170m south of the NSR and is expected to have the same sound environment as the NSR.	39
16	Plantation Cottages	MS5	Monitoring location is approximately 200m east of the NSR and is expected to have the same sound environment as the NSR.	31
17	Potter's Farm	MS15	The monitoring location is approximately the same distance from the B1122 as the NSR and is therefore expected to have a similar sound environment to the NSR and is considered representative.	39
18	Potter's Street	MS15	The monitoring location is approximately the same distance from the B1122 as the NSR and is therefore expected to have a similar sound environment to the NSR and is considered representative.	39
19	Rosery Cottages	MS27	Monitoring location is within 100m of the NSR.	40

Sizewell C | 101277766 / 002 | P1 - For Implementation | 04-Jun-2024 | NOT PROTECTIVELY MARKED

# NOT PROTECTIVELY MARKED

Document Reference Number: 101277766  
Revision 02




## EPR/GP3226SQ/A001 REQUEST FOR INFORMATION: NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

NSR Number	NSR Name	Measurement Reference	Location Rationale	Typical L <sub>A90,T</sub> (dB) daytime
20	Roundhouse	MS4	Monitoring location is approximately 150m west of the NSR and is expected to have the same sound environment as the NSR.	33
21	Sizewell Sports & Social Club	MS45b	Monitoring location is approximately 160m northwest of the NSR and is expected to have the same sound environment as the NSR.	45
22	Sizewell Village	MS28	Monitoring location is within 100m of the NSR.	41
23	The Studio	MS26	Monitoring location is approximately 400m east of the NSR. Given the greater distance between Lover's Lane and the monitoring location compared to the NSR, the monitoring location is considered conservatively representative of the sound environment at the NSR.	42
24	Valley Road North	MS24	Monitoring location is approximately 150m southeast of the NSR and considered representative of the sound environment at the NSR. The nearby trainline is not in use and therefore does not contribute to the sound environment at the monitoring location.	34
25	Valley Road South	MS24	Monitoring location is approximately 150m southeast of the NSR and considered representative of the sound environment at the NSR. The nearby trainline is not in use and therefore does not contribute to the sound environment at the monitoring location.	34

All comments on the equivalence of the acoustic climate between the measurement locations and the NSRs are based on existing conditions, before the SZC construction works commence, and do not reflect the acoustic climate that will be present when the proposed generators are in use.

Sizewell C | 101277766 / 002 | P1 - For Implementation | 04-Jun-2024 | NOT PROTECTIVELY MARKED

Sizewell C | 10127766 / 002 | P1 - For Implementation | 04-Jun-2024 | NOT PROTECTIVELY MARKED



- Key
- Measurement locations
  - Receptor locations
- NSR1. Abbey Cottages
  - NSR2. Abbey Farm
  - NSR3. Abbey Road, Leiston
  - NSR5. Barley Rise
  - NSR6. Common Cottages
  - NSR7. Crown Lodge
  - NSR8. Eastbridge
  - NSR9. Grimseys Lane
  - NSR10. Heath View
  - NSR11. Keepers Cottage
  - NSR12. King George's Avenue
  - NSR13. Leiston Abbey
  - NSR14. Lovers Lane / Sandy Lane Junction
  - NSR15. Old Abbey Farm / Care Home
  - NSR16. Plantation Cottages
  - NSR17. Potters Farm
  - NSR18. Potters Street
  - NSR19. Rosery Cottages
  - NSR20. Roundhouse
  - NSR21. Sizewell Sports & Social Club
  - NSR22. Sizewell Village
  - NSR23. The Studio
  - NSR24. Valley Road North
  - NSR25. Valley Road South

0 0.25 0.5 km  
 Scale at A3: 1:15,000  
 OS Open Background: Contains OS data © Crown Copyright and database right 2020



Sizewell C

**Figure 5.1 - Noise Sensitive Receptors and Monitoring Locations**



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

## 6 NOISE MODELLING

### 6.1 Model inputs

**Section 4.2** lists the considerations given to the noise modelling. This Section aims to provide clarity on the modelling inputs, including locations, assumptions, and sound power levels (SWLs).

#### 6.1.1 Static generators

53no. static generators have been included within Appendix C: Air Emission Risk Assessment of the permit application [5] and have therefore been included within the noise model. The generators, locations and percentage on times are presented in **Table 6.1**.

To provide a conservative worst-case assessment, the loudest generator within Appendix C of BS 5228-1:2009 + A1:2014 [8] (BS 5228) has been assumed to be representative of all static generators. The details are provided in **Table 6.2** and **Table 6.3**.

**Table 6.1 Static generator locations and percentage on times**

Reference	X	Y	% on time
MDS1	645574	263141	50
MDS2	645249	262911	50
MDS3	645708	262873	50
MDS4	645618	262660	50
MDS5	645619	262632	50
MDS6	645619	262594	50
MDS7	647157	263905	Standby <sup>3</sup>
MDS8	647353	264175	Standby <sup>3</sup>
MDS9	647353	264169	Standby <sup>3</sup>
MDS10	647450	264123	Standby <sup>3</sup>
MDS11	647430	264056	Standby <sup>3</sup>
MDS12	645105	264502	50
MDS13	645157	264421	100
MDS14	645350	264395	100
MDS15	645521	264427	100
MDS16	645369	264222	100
MDS17	645409	264074	100
MDS18	646820	264623	100

<sup>3</sup> Where the generators are noted as standby, it is assumed the percentage on time is 0%.

# NOT PROTECTIVELY MARKED

Document Reference Number: 101277766  
Revision 02



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

Reference	X	Y	% on time
MDS19	646759	264603	100
MDS20	646650	264789	100
MDS21	646444	264790	50
MDS22	646540	264616	100
MDS23	646125	264701	50
MDS24	646169	264591	50
MDS25	645980	264699	50
MDS26	646309	264845	50
MDS27	646827	264832	100
MDS28	646760	264789	100
MDS29	645832	264660	50
MDS30	645806	264639	50
MDS31	645718	264552	100
MDS32	647212	264628	100
MDS33	647191	264649	100
MDS34	646983	264670	50
MDS35	646948	264670	50
MDS36	646915	264670	50
MDS37	646956	264722	50
MDS38	646760	264747	100
MDS39	646760	264718	100
MDS40	647456	264384	50
MDS41	647593	263869	50
MDS42	647593	263797	50
MDS43	647112	264350	50
MDS44	647215	264356	50
MDS45	647257	264356	50
AD4_4	643454	263123	100 <sup>4</sup>
AD4_5	644988	262859	100 <sup>4</sup>

<sup>4</sup> Where no percentage on time was available, it has been assumed to be 100%.

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

Reference	X	Y	% on time
AD4_6	644503	263825	100 <sup>4</sup>
AD5_1	645251	262073	100 <sup>4</sup>
AD6_1	644922	264589	100 <sup>4</sup>
AD6_2	644657	263802	100 <sup>4</sup>
AD6_3	645208	263798	100 <sup>4</sup>
AD6_4	645492	263441	100 <sup>4</sup>

**Table 6.2 SWL assumptions for static generators**

BS 5228 [8] Reference	Plant name	L <sub>Aeq,T</sub> at 10m (dB)	L <sub>WA</sub> (dB)
Table C.4 item 96	Diesel generator (directional drill)	77	105

**Table 6.3 Octave band SWL assumptions for static generators**

Plant name	Octave band SWL (dB)							
	63	125	250	500	1000	2000	4000	8000
Diesel Generator (directional drill)	95	108	102	100	100	100	96	89

6.1.2 Mobile generators

Due to the nature of mobile generators, the exact locations are unknown. However, the areas in which the mobile generators will be working are known, along with the number of generators within each working area.

The mobile generators will be used primarily for lighting and cranes, and therefore a reasonable worst-case assumption has been made, using the loudest lighting tower generator listed within Appendix C of BS 5228 [8]. **Table 6.4** displays the areas used within Appendix C: Air Emission Risk Assessment of the permit application [5] and the generator assumptions, whilst **Table 6.5** shows the octave band SWL assumptions for each area. The total sound power from the generators for each area has been spread evenly across the area and modelled as an area source to consider a reasonable worst-case scenario.

It has been assumed the mobile generators will be operational 100% of the time.

**Table 6.4 Mobile generator areas and broadband plant assumptions**

Area reference	BS 5228 [8] reference	Number of plant	L <sub>Aeq,T</sub> at 10m (dB)	L <sub>WA</sub> (dB)
Diesel Generator (lighting towers)	Table C.4 item 87	1	65	93
MCA Deep Dig	Table C.4 item 87	25	79	107
MCA Perimeter	Table C.4 item 87	7	73	101



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

Area reference	BS 5228 [8] reference	Number of plant	L <sub>Aeq,T</sub> at 10m (dB)	L <sub>WA</sub> (dB)
TCA SE	Table C.4 item 87	21	78	106
TCA SW	Table C.4 item 87	39	81	109
TCA NE	Table C.4 item 87	17	77	105
TCA Stockpiles	Table C.4 item 87	10	75	103
TCA Rails	Table C.4 item 87	10	75	103
ACA	Table C.4 item 87	30	80	108

Table 6.5 Octave band SWL assumptions for mobile generators

Area reference	Octave band SWL (dB)							
	63	125	250	500	1000	2000	4000	8000
Diesel Generator (lighting towers)	105	100	92	88	87	85	82	70
MCA Deep Dig	119	114	106	102	101	99	96	84
MCA Perimeter	113	108	100	96	95	93	90	78
TCA SE	118	113	105	101	100	98	95	83
TCA SW	121	116	108	104	103	101	98	86
TCA NE	117	112	104	100	99	97	94	82
TCA Stockpiles	115	110	102	98	97	95	92	80
TCA Rails	115	110	102	98	97	95	92	80
ACA	120	115	107	103	102	100	97	85

## 6.2 Model results

As stated in **Section 4.2**, the above was incorporated into a SoundPLAN model. The predicted L<sub>Aeq,T</sub> results are presented in **Table 6.6**.

Table 6.6 Predicted L<sub>Aeq,T</sub> levels due to the operation of generators at NSRs

NSR No.	NSR Name	Contribution from static generators, L <sub>Aeq,T</sub> (dB)	Contribution from mobile generators, L <sub>Aeq,T</sub> (dB)	Resultant L <sub>Aeq,T</sub> (dB)
1	Abbey Cottages	44	39	45
2	Abbey Farm	37	33	38
3	Abbey Road, Leiston	54	44	54
5	Barley Rise	43	39	45
6	Common Cottages	45	40	46
7	Crown Lodge	47	45	49

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

NSR No.	NSR Name	Contribution from static generators, L <sub>Aeq,T</sub> (dB)	Contribution from mobile generators, L <sub>Aeq,T</sub> (dB)	Resultant L <sub>Aeq,T</sub> (dB)
8	Eastbridge	32	30	34
9	Grimsey's Lane	41	37	42
10	Heath View	42	38	43
11	Keepers Cottage	41	38	43
12	King George's Avenue	47	43	48
13	Leiston Abbey	42	36	43
14	Lover's Lane / Sandy Lane Junction	53	48	54
15	Old Abbey Farm / Care Home	50	47	51
16	Plantation Cottages	36	34	38
17	Potter's Farm	36	32	38
18	Potter's Street	36	32	38
19	Rosery Cottages	37	34	39
20	Roundhouse	40	39	43
21	Sizewell Sports & Social Club	49	43	50
22	Sizewell Village	35	32	37
23	The Studio	49	42	49
24	Valley Road North	53	48	54
25	Valley Road South	51	41	51

Sizewell C | 101277766 / 002 | P1 - For Implementation | 04-Jun-2024 | NOT PROTECTIVELY MARKED

## 7 BS 4142 ASSESSMENT

### 7.1 Establishing rating level ( $L_{Ar,Tr}$ )

**Table 6.6** displays the ambient level results of the noise modelling from the operation of generators. This can also be described as the specific sound level ( $L_s$ ) in the context of BS 4142 [1].

As described in **Section 3.1**, BS 4142 [1] requires consideration of tonality, impulsivity, intermittency and other characteristics of the specific source and where necessary, a penalty is applied to determine a rating level ( $L_{Ar,Tr}$ ).

The generators are not expected to have a tonal element, but instead be a continuous, consistent broadband sound. It is therefore not appropriate to add any penalties to the specific sound levels, and the rating level equals the specific sound level ( $L_{Ar,Tr} = L_s$ ).

### 7.2 Initial estimate of noise impact

**Table 7.1** compares the rating level ( $L_{Ar,Tr}$ ) to the background sound level ( $L_{A90}$ ) at each NSR and provides an initial estimate of noise impact in accordance with BS 4142 [1].

**Table 7.1 BS 4142 [1] initial estimate of noise impact at each NSR**

NSR No.	NSR Name	$L_{A90}$ (dB)	$L_{Ar,Tr}$ (dB)	Difference	Initial impact estimate <sup>5</sup>
1	Abbey Cottages	44	45	+1	Low impact
2	Abbey Farm	31	38	+7	Adverse impact
3	Abbey Road, Leiston	40	54	+14	Significant adverse impact
5	Barley Rise	39	45	+6	Adverse impact
6	Common Cottages	42	46	+4	Low impact
7	Crown Lodge	39	49	+10	Significant adverse impact
8	Eastbridge	33	34	+1	Low impact
9	Grimsey's Lane	39	42	+3	Low impact
10	Heath View	48	43	-5	Low impact
11	Keepers Cottage	42	43	+1	Low impact
12	King George's Avenue	36	48	+12	Significant adverse impact
13	Leiston Abbey	39	43	+4	Low impact
14	Lover's Lane / Sandy Lane Junction	42	54	+12	Significant adverse impact

<sup>5</sup> As defined in Section 3.1

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

NSR No.	NSR Name	L <sub>A90</sub> (dB)	L <sub>Ar,Tr</sub> (dB)	Difference	Initial impact estimate <sup>5</sup>
15	Old Abbey Farm / Care Home	39	51	+12	Significant adverse impact
16	Plantation Cottages	31	38	+7	Adverse impact
17	Potter's Farm	39	38	-1	Low impact
18	Potter's Street	39	38	-1	Low impact
19	Rosery Cottages	40	39	-1	Low impact
20	Roundhouse	33	43	+10	Significant adverse impact
21	Sizewell Sports & Social Club	45	50	+5	Adverse impact
22	Sizewell Village	41	37	-4	Low impact
23	The Studio	42	49	+7	Adverse impact
24	Valley Road North	34	54	+20	Significant adverse impact
25	Valley Road South	34	51	+17	Significant adverse impact

### 7.3 Context

In addition to the initial estimate of noise impact, which is simply based on the excess of the rating level over the background sound level, BS 4142 [1] requires the consideration of context, including the following factors:

- the absolute level of the sound;
- the character and level of the residual sound compared to the character and level of the specific sound; and
- the sensitivity of the receptor and whether they will already incorporate design measures that secure good internal and / or outdoor acoustic conditions.

#### 7.3.1 Absolute level of the sound

The operation of the generators is to provide power for the construction activities on the MDS throughout the 2025 / 2026 period, until mains power is installed on site. As such, the noise emissions due to construction work were considered at the ES [3] stage, and submitted as part of the DCO application. The following hierarchy of controls must be applied to the construction works, secured by Requirement 2 of the DCO:

- Code of Construction Practice (CoCP) [9], which is the overarching mechanism for providing a clear and consistent approach to the control of SZC construction activities on the MDS, and the associated development (AD) sites, to minimise impacts on people and the environment;
- Noise Monitoring and Management Plans (NMMPs), which sit under the CoCP [9] and provide site-specific controls for each work site, i.e. separate NMMPs must be submitted to and approved by East Suffolk Council (ESC) for each separate work site (one for the MDS [10],

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

and one for each AD site). The NMMPs provide site-specific mitigation and monitoring requirements and restate the noise and vibration thresholds that SZC must use best practicable means to comply with. The NMMPs also provide for the Bespoke Mitigation Plan (BMP) process.

- BMPs sit under the NMMPs and provide activity specific controls and mitigations where controls and mitigations where construction activities are expected to exceed the noise and/or vibration thresholds stated in the NMMPs.

The CoCP [9] and MDS NMMP [10] (approved by ESC on 21<sup>st</sup> March 2024) set out the noise thresholds for construction works, replicated in **Table 7.2**.

**Table 7.2 Noise thresholds for construction works**

Period	Threshold	Parameter
Any day 07:00 to 23:00	60	L <sub>Aeq,16 hours</sub> , dB, free field
Night 23:00 to 07:00	45	L <sub>Aeq,8 hours</sub> , dB, free field
Night 23:00 to 07:00	65	L <sub>Amax</sub> , dB, façade

Where it is anticipated that, despite the use of best practicable means (as defined by Section 72 of the Control of Pollution Act 1974 (CoPA) [11]), the construction works will exceed the free-field noise levels set out in the below paragraph, a BMP must be submitted to ESC for approval.

The free-field noise levels that, when exceeded, would trigger the need for a BMP at the MDS are:

- 55dB L<sub>Aeq,16hrs</sub> (daytime between 07:00 and 23:00);
- 50dB L<sub>Aeq,4hrs</sub> (evening between 19:00 and 23:00)<sup>6</sup>; or
- 45dB L<sub>Aeq,8hrs</sub> (night-time between 23:00 and 07:00).

In the context of the requirements set out by the DCO, and the absolute levels reported in **Table 7.1**, the predicted sound levels at the majority of the NSRs are at least 10dB below the threshold for construction works. It is therefore reasonable to assume that the levels at receptors that would not trigger the need for a BMP could be considered to have a low impact, given the context of the DCO requirements based on absolute noise levels.

The following receptors would trigger the need for a BMP based solely on generator use during the evening period:

- R3 – Abbey Road, Leiston
- R14 – Lover’s Lane / Sandy Lane Junction
- R15 – Old Abbey Farm / Care Home
- R24 – Valley Road North
- R25 – Valley Road South

<sup>6</sup> The overlap between the 16-hour daytime period and the 4-hour evening period is immaterial in the context of noise assessments carried out in advance of the works to determine the need for a BMP. The calculations will consider both periods, and predicted exceedance of either period (or the other stated levels) will trigger the need for a BMP.

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

In these instances, a BMP will be required in respect of the generator noise alone, prior to the consideration of other construction plant, and specific mitigation will be required to reduce generator noise levels to a practicable minimum and will be subject to the approval of ESC. Through the application of the project construction controls in this manner, the generator noise levels are highly likely to be lower than the values set out in **Table 7.1**, however, the nature of the mitigation and the exact reduction likely to be achieved cannot be determined at this stage.

7.3.2 Character and level of the residual sound compared to the character and level of the specific sound

DCO construction noise data

Whilst the initial estimate assessment presented in **Section 7.2** uses existing background levels (i.e. as a greenfield site, with no construction works), the generators are proposed to be used as part of the construction works being undertaken in 2025 / 2026.

Calculations of likely construction noise levels were undertaken as part of the DCO submissions, contained within the ES [3], with additional background detail in Appendix 11B. The calculations were undertaken for five phases of work on the Temporary Construction Area (TCA) / Main Construction Area (MCA), with the ACA assessed separately due to slightly different phasing and being geographically distinct. Where appropriate, the cumulative effect of noise from the TCA / MCA and ACA was assessed.

The period covered by the permit for the generators coincides with Phase 1 and the start of Phase 2 of the Project. **Table 7.3** and **Table 7.4** show the predicted construction noise levels for the daytime TCA / MCA activities and ACA activities, taken from Table 11.19 and Table 11.21 of the ES [3] respectively.

**Table 7.3 Predicted construction noise levels, daytime period where TCA / MCA dominate (in isolation or in combination with ACA), free field  $L_{Aeq,16hrs}$  dB**

NSR No.	NSR Name	Phase 1a	Phase 1b/2
1	Abbey Cottage	70	58
2	Abbey Farm	62	48
3	Abbey Road, Leiston	67	50
6	Common Cottages	53	54
8	Eastbridge	54	46
11	Keepers Cottage	70	54
13	Leiston Abbey	60	53
14	Lover's Lane / Sandy Lane Junction	70	54
15	Old Abbey Farm / Care Home	70	64
16	Plantation Cottages	64	48
17	Potter's Farm	61	54
18	Potter's Street	58	50



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

NSR No.	NSR Name	Phase 1a	Phase 1b/2
19	Rosery Cottages	50	48
20	Roundhouse	69	60
22	Sizewell Village	46	44
23	The Studio	66	53

**Table 7.4 Predicted construction noise levels, daytime period where ACA dominates, free field  $L_{Aeq,16hrs}$  dB**

NSR No.	NSR Name	Initial site strip / level	Preparation	Early Years Operations
5	Barley Rise	60	47	42
7	Crown Lodge	65	51	50
9	Grimsey's Lane	53	46	42
10	Heath View	62	56	50
12	King George's Avenue	67	61	53
21	Sizewell Sports & Social Club	63	56	51
24	Valley Road North	62	51	42
25	Valley Road South	60	51	43

A number of the modelled activities included noise contributions from generators that were expected to be associated with the works; the activities where generators were expected were listed in Appendix 11B of the ES [3].

During recent discussions with the EA, it is understood that if it were possible to demonstrate that the proposed generators were not materially contributing to the overall construction noise levels at a receptor, for example by showing that generator noise is at least 10dB below the total level of noise from the rest of the works, notwithstanding that there is nothing in the DCO that requires the generators to be a non-material source, then the EA may accept that the generators do not require any further detailed assessment.

To achieve this, it is necessary to remove the generators included in the calculated ES [3] construction noise levels, so that their noise level can be compared against noise from the non-generator construction noise.

Due to the size of the site, the complexity of the construction phase and the extended duration of the works, the construction noise calculations in the ES [3] considered specific activities, which were made up of groups of individual plant items. Also, the exact locations for the plant were not known in detail or were understood to be so variable so as to make any assumption about a specific plant location redundant or unrepresentative, the groups of plant items were therefore replicated in the model to represent every possible location. As a result, it is not possible to reliably remove the contribution from generators from the original ES [3] calculations.



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

However, the nature of that assumption, i.e. every plant item appeared at every possible source location means that the calculated levels at the receptors are dependent on the plant assumed to make up the whole activity, and not the specific location of one of the plant items that formed part of the activity. It is therefore possible to infer from their contribution to the overall source level for a particular activity, whether the generators would have been a material contributor to the overall construction noise levels at the receptors, as shown in **Table 7.3** or **Table 7.4**.

The sound power levels for each group of plant for each activity, as summarised in Appendix 11B of the ES [3], have been analysed to determine whether the contribution from the generators were within 10dB of the rest of the plant. The outcomes are shown in **Table 7.5**. Only the grouped activities where generators were included are shown.

**Table 7.5 Generator sound levels in ES calculations, L<sub>WA</sub> dB**

Works Reference	Activity	L <sub>WA</sub> dB			Generator difference
		With generators	Without generators	Generator	
P1_01C	Water Management Zone	108.7	108.6	93.4	-15.2
P1_02A	Borrow Pit - excavation	109.5	109.0	99.4	-9.6
P1_04B	Piling	114.1	113.5	105.1	-8.4
P1_05C	Culvert & Embankment construction	117.8	117.7	99.4	-18.3
P1_06A	Haul Road Construction	120.0	119.9	102.4	-17.5
P1_07A	Main Site Office	114.2	114.0	101.2	-12.8
P1_07B	Entrance Plaza	120.2	120.1	102.4	-17.7
P1_08B	Concrete Batching Plant construction	112.2	111.7	102.3	-9.4
P1_10A	Sea Defences - Remove existing	115.3	115.2	99.4	-15.8
P1_10Ci	Sea Defences - Ground Improvement	113.3	113.1	99.4	-13.7
P1_10Cii	Sea Defences - Peat Treatment under	113.6	113.2	102.9	-10.3
P1_10D	Sea Defences - Construction	117.6	117.5	99.4	-18.1
P1_11A	Cut off Wall - Platform	117.6	117.5	99.4	-18.1
P1_11B	Cut off Wall - Construction	115.2	114.2	108.4	-5.8
P1_12B	Marine infrastructure-Superstructure	110.8	109.6	104.8	-4.8
P1_25	Desalination plant operation - Phase 1	105.9	105.7	92.5	-13.2
P2_02A	Borrow Pit - excavation	108.8	108.3	99.4	-8.9

# NOT PROTECTIVELY MARKED

Document Reference Number: 101277766  
Revision 02



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

Works Reference	Activity	LWA dB			Generator difference
		With generators	Without generators	Generator	
P2_06B	Main Access Road	120.9	120.8	102.4	-18.4
P2_07C	Main Site Office - Superstructure	113.5	113.0	103.8	-9.2
P2_12B	Marine infrastructure - Superstructure	110.4	109.8	101.5	-8.3
P2_13A	Contractor's Compounds - Hardstanding	120.1	120.0	102.4	-17.6
P2_14Ai	Accommodation campus - Groundworks	113.8	113.5	102.4	-11.1
P2_14Bi	Accommodation campus - Car Parks	119.1	119.0	102.4	-16.6
P2_14Ci	Accommodation campus - Buildings	113.5	113.0	103.8	-9.2
P2_15A	Within Cut-off Wall - Excavation	118.8	118.4	107.5	-10.9
P2_25	Desal operation Phase 1	105.9	105.7	92.5	-13.2
P2_30	Main Works Yard	110.7	110.3	99.4	-10.9
P3_30	Main Works Yard	113.7	113.2	104.2	-9.0
P3_31	CRF Pipes	114.8	114.3	104.9	-9.4
P3_32	Galleries	116.7	116.6	91.9	-24.7
P3_33	CRF Backfill	111.1	110.6	101.2	-9.4
P3_34	CRF Secondary Backfill	115.1	114.9	101.2	-13.7
P3_35	1.0 Base slab & substructure	114.5	114.3	101.2	-13.1
P3_36	Nuclear Island 1	119.6	119.5	103.4	-16.1
P3_37	Nuclear Island 2	117.2	117.1	101.2	-15.9
P3_38	Nuclear Island 3	116.3	116.1	101.2	-14.9
P3_40	Turbine Hall	116.5	116.4	101.2	-15.2
P3_41	SWBP Walls	115.5	115.3	101.2	-14.1
P3_42	Forebay Base	114.8	114.6	101.2	-13.4
P3_45	Stockpile Main	116.5	116.4	99.4	-17.0
P5_14Ai	Reinstatement Accommodation Campus	115.6	115.5	99.4	-16.1

Sizewell C | 101277766 / 002 | P1 - For Implementation | 04-Jun-2024 | NOT PROTECTIVELY MARKED

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

Works Reference	Activity	LWA dB			Generator difference
		With generators	Without generators	Generator	
P5_14Bi	Reinstatement Accommodation Campus - Car Parks	118.0	117.9	99.4	-18.5

The activities where the assessed generators may be considered to have contributed to the overall sound level for that particular activity are Works Ref P1\_12B *Marine infrastructure – Superstructure* and P1-11B *Cut off wall construction* where the generator sound levels were 4.8dB and 5.8dB lower than the rest of the plant for that activity, respectively. However, both activities will be located on the eastern side of the TCA, away from any residential receptor, and therefore would not have been the cause of the predicted construction noise levels in the ES [3].

For every other activity, the generators modelled are calculated to be at least 8 to 9dB lower than everything else within that group of plant items, and therefore the generators were not a material contributor to the predicted overall construction sound levels at the receptors set out in the ES [3].

On this basis, the predicted construction noise levels shown in **Table 7.3** and **Table 7.4** can be considered to represent the likely noise levels from the construction works, without any material contribution from the generators.

**Screening of generator noise model results vs DCO predicted construction noise levels**

An initial estimate of the noise impact of the proposed generators has been made by comparing the predicted sound levels generated by the proposed generators with the DCO predicted construction noise levels. Where the generators are around 9dB or more below the other construction plant, it is considered that the generators are not contributing to the overall noise level and therefore receptors where this is the case should be screened out of further assessment.

As mentioned above, **Table 7.3** and **Table 7.4** represent the DCO predicted construction noise levels without generators, whilst **Table 6.6** shows the predicted noise levels at receptors due to generator use. These tables are collated below into **Table 7.6**, showing the difference between the two levels.

**Table 7.6 Predicted generator LAeq,T levels vs DCO predicted construction LAeq,T levels**

NSR No.	NSR name	Predicted generator LAeq,T dB	Lowest DCO predicted construction LAeq,T dB	Difference (predicted generator – lowest DCO) dB
1	Abbey Cottages	45	58	-13
2	Abbey Farm	38	48	-10
3	Abbey Road, Leiston	54	50	+4
5	Barley Rise	45	42	+3
6	Common Cottages	46	53	-7
7	Crown Lodge	49	50	-1
8	Eastbridge	34	46	-12
9	Grimsey's Lane	42	42	0
10	Heath View	43	50	-7

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

NSR No.	NSR name	Predicted generator $L_{Aeq,T}$ dB	Lowest DCO predicted construction $L_{Aeq,T}$ dB	Difference (predicted generator – lowest DCO) dB
11	Keepers Cottage	43	54	-11
12	King George's Avenue	48	53	-5
13	Leiston Abbey	43	53	-10
14	Lover's Lane / Sandy Lane Junction	54	54	0
15	Old Abbey Farm / Care Home	51	64	-13
16	Plantation Cottages	38	48	-10
17	Potter's Farm	38	54	-16
18	Potter's Street	38	50	-12
19	Rosery Cottages	39	48	-9
20	Roundhouse	43	60	-17
21	Sizewell Sports & Social Club	50	51	-1
22	Sizewell Village	37	44	-7
23	The Studio	49	53	-4
24	Valley Road North	54	42	+12
25	Valley Road South	51	43	+8

Based on the above, the generators do not materially contribute to the overall lowest predicted DCO construction  $L_{Aeq,T}$  at the following receptors:

- R1 – Abbey Cottages
- R2 – Abbey Farm
- R8 – Eastbridge
- R11 – Keepers Cottage
- R13 – Leiston Abbey
- R15 – Old Abbey Farm / Care Home
- R16 – Plantation Cottages
- R17 – Potter's Farm
- R18 – Potter's Street
- R19 – Rosery Cottages
- R20 – Roundhouse

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

These receptors should therefore be screened out of any further assessment, and the impacts on these properties disregarded in the context of BS 4142 [1]. It should also be noted that it is likely that the other construction plant is likely to have more prominent characteristics compared to generators. As described in **Section 7.1**, the generators are not expected to have a tonal element, but instead be a continuous, consistent broadband sound while other construction plant is likely to include tonal or intermittent elements such as alarms, or impulsive characteristics such as hammers, and therefore more likely to be noticeable.

### 7.3.3 The sensitivity of the receptor and incorporated design measures

#### Sensitivity of receptors

All receptors listed within **Table 5.1** are residential receptors and should all be classed as the same sensitivity.

However, it is understood that Roundhouse (R20) will become vacant in the coming months (during the determination period of this permit application).

Receptor R20 should therefore be screened out of further assessment, and the impacts on these properties disregarded in the context of BS 4142 [1].

#### Incorporated design measures

The noise model described in **Section 4.2** and **Section 6** incorporates all eight noise barriers described within the ES [3], shown in Figure 11.4, of the DCO application, as follows:

- Barrier #1 – 5m above ground;
- Barrier #2 – 3m above ground;
- Barrier #3 – 3m above ground;
- Barrier #4 – 5m high acoustic fence;
- Barrier #5 – 3m above ground;
- Barrier #6 – 3m high earth bund;
- Barrier #7 – 3m high earth bund with a 2m high acoustic fence on top of the ridge (5m total height); and
- Barrier #8 – 5m above ground.

The incorporated design measures have therefore already been included in the initial estimate of impact.

## 7.4 Uncertainty

As described in **Section 4.2** and **Section 6**, a noise model has been created to simulate and assess the predicted sound levels of the operational generators at the nearby NSRs.

Uncertainty is inevitable at this stage, however, the model has been created based on a realistic worst-case scenario by modelling downwind at all receptors, using area sources to model mobile generators, assuming 100% on time where this is not known, and using the loudest generator listed within Appendix C of BS 5228 [8] for the different generator uses in the absence of manufacturer noise specification data. It is likely that on site levels will be lower at the NSRs than those displayed in this report.

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

## 7.5 Summary

### 7.5.1 Establishing rating level

After considering tonality, impulsivity, intermittency, and other characteristics of the specific source, it is not considered appropriate to apply any penalties to the specific source, due to the consistent broadband nature of the source. Therefore, the rating level equals the specific level ( $L_{Ar,Tr} = L_s$ ).

### 7.5.2 Initial estimate of noise impact

The initial estimate of noise impact showed that out of 24no. NSRs, 5no. NSRs are likely to experience adverse effects and 8no. NSRs are likely to experience significant adverse effects based on the operation of the proposed generators in accordance with BS 4142 [1], before considering context.

### 7.5.3 Context – absolute level of the sound

When considering the context in terms of absolute level of the sound and the DCO requirement to work in accordance with the CoCP [9] and produce NMMPs and BMPs where necessary, it is assumed that receptors that would not trigger the need for a BMP can be screened out of further assessment. This would mean receptors R1, R2, R5, R6, R7, R8, R9, R10, R11, R12, R13, R16, R17, R18, R19, R20, R21, R22 and R23 would not require further assessment.

For those receptors where the current predictions suggest that the generator noise levels would trigger the need for a BMP, specific mitigation will be required to reduce generator noise levels to a practicable minimum, as part of the project's construction controls, secured under Requirement 2 of the DCO.

### 7.5.4 Context – character and level of the residual sound compared to the character and level of the specific sound

When considering the character and level of the residual sound compared to the character and level of the specific sound, it is noted that the generators will not be in use on a greenfield site, but instead will be used during the construction on the MDS. To be able to consider this properly, an investigation into the DCO construction predictions has been conducted. This investigation found that whilst some generators had been included in the DCO modelling, these generators were not contributing materially to the overall predicted construction noise levels.

This then allowed a comparison to the predicted generator levels in **Section 6.2** to the DCO predicted construction levels to determine whether the updated generator modelling would mean that generators contribute to the overall DCO predicted construction level at receptors during 2025 / 2026. As the proposed generator period covered a few phases, the lowest DCO predicted construction level has been compared to the generator level. Where the generator level is 9dB or more below the DCO predicted construction level, it is unlikely that the generators have a material influence on the overall construction noise level and receptors where this is the case can be screened out of further assessment.

This would mean receptors R1, R2, R8, R11, R13, R15, R16, R17, R18, R19 and R20 would not require further assessment.

It should also be noted that the residual sound is likely to have more prominent characteristics than the specific sound and therefore the impact may not be as great as that stated in the initial estimate of noise impact.



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

7.5.5 Context – sensitivity of receptors and incorporated design measures

All NSRs considered in the assessment are residential receptors and therefore should all be classed as the same sensitivity. However, it is understood that R20 will become vacant in the coming months (during the determination period of this application). Receptor R20 should therefore be screened out of further assessment.

The noise model described in **Section 4.2** and **Section 6** already incorporates all eight noise barriers described within the ES [3] of the DCO application, and therefore the incorporated design measures have already been included within the initial estimate of impact.

7.5.6 Uncertainty

The model has been created based on a realistic worst-case scenario, by:

- modelling downwind at all receptors;
- using area sources for mobile generators;
- considering percentage on times; and
- using conservative values for the sound power levels.

It is likely that the on-site levels will be lower at NSRs than those displayed in this report.

7.5.7 Estimate of noise impact

21no. NSRs have been screened out of further assessment, as explained in **Section 7.5.3** to **Section 7.5.5**. Four NSRs have not been screened out from assessment after considering context, a summary of the findings for these receptors can be seen in **Table 7.7**.

**Table 7.7 Summary of findings for scoped in receptors**

NSR No.	NSR name	Rating level L <sub>Ar,Tr</sub> dB	Background level L <sub>A90,T</sub> dB	Lowest DCO predicted construction level L <sub>Aeq,T</sub> dB	Initial estimate of impact
3	Abbey Road, Leiston	54	40	50	Significant adverse impact
14	Lover's Lane / Sandy Lane Junction	54	42	54	Significant adverse impact
24	Valley Road North	54	34	42	Significant adverse impact
25	Valley Road South	51	34	43	Significant adverse impact

Whilst representative background sound levels are not available for the construction period, it is likely that, at the time of construction, the predicted sound levels from the proposed generators will have a low impact at R3 and R14, due to the similarity in the absolute sound levels when compared with the predicted construction noise levels. The background noise level during the construction phase is likely to rise from the baseline background level, and whilst the generators will contribute to the overall predicted construction level, it is likely that the proposed generators would result in a lower impact than that currently predicted when assessed in isolation and in accordance with BS 4142 [1], particularly when considering context.



EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

The results of the noise modelling described in **Section 6** show that all receptors listed in **Table 7.7** are predicted to be dominated by the mobile generators in the ACA area, with all other modelled generators contributing a value more than 10dB below this dominant source. As the mobile generator locations are determined, it is likely that the noise modelling can be refined and the rating level  $L_{A,r,T_r}$  reduced, reducing the impact to these receptors.

All proposed activities will follow the hierarchy dictated by Requirement 2 of the DCO, as described in **Section 7.3.1**. As more details become available, all activities will go through a screening process to determine whether a BMP is required, and, where one is required, specific mitigation must be put forward for approval by ESC. Requirement 2 and the use of BMPs is to ensure the impact on nearby human NSRs is as low as practicably possible.

A - APPROVED

EPR/GP3226SQ/A001 REQUEST FOR INFORMATION:  
NOISE – BS 4142:2014 + A1:2019 ASSESSMENT

## 8 CONCLUSIONS

A noise impact assessment has been completed to respond to a request for information from the EA following the submission of a permit application for an installation activity environmental permit, EPR Schedule 1, Section 1.1A(1)(a): Burning of any fuel in an appliance with a rated thermal input of 50 MW or more for the installation of diesel generators within the MDS on 12<sup>th</sup> April 2024.

This assessment has considered the existing background levels measured during a recent round of baseline noise monitoring, and in the context of the operation of the generators during the MDS construction, the DCO predicted construction levels. It has conducted an initial estimate of impact in accordance with BS 4142 [1], showing that out of 24no. NSRs, 5no. NSRs are likely to experience adverse effects and 8no. NSRs are likely to experience significant adverse effects based on the operation of the proposed generators, before considering context.

When considering the context of the absolute level of the sound, it was found that the predicted resultant level at 18no. of the NSRs would not trigger the need for a BMP, and therefore should be screened out of further assessment.

When considering the context of the character and level of the residual sound to the character and level of the specific sound, an investigation has been conducted into the DCO predicted construction noise levels and the impact of the proposed generators on these levels. It was determined that the generators assessed at DCO did not influence the predicted construction levels at receptors, and therefore a comparison of the predicted sound levels likely to be generated by the proposed generators and the DCO construction levels has been conducted. This has found that the predicted construction levels at 11no. NSRs will not be influenced by generators and should be screened out of further assessment. It should also be noted that the character of the residual noise is expected to be more prominent than the character of the specific sound due to its continuous broadband nature, as the residual noise will consist of other construction plant, and therefore the impact is likely to be lower than is set out in this report.

When considering the context of the sensitivity of receptors and incorporated design measures, one NSR will become unoccupied in the coming months and should be discounted from further assessment. The noise model already considered the eight barriers included in the ES [3], and therefore incorporated design measures had already been considered.

The noise model presents a realistic worst-case scenario for the operation of generators, and of the 4no. NSRs not screened out of further assessment, the modelling results show that the predictions are dominated by noise from the mobile generators within the ACA or TCA Rail areas, where exact locations are not yet known, nor are the percentage on times. It is likely that as more details become available, the model can be refined and the rating level  $L_{A,T,r}$  can be reduced at these receptors.

When considering the context of the site and proposals, it is considered that the proposed generators would result in a lower impact than that currently predicted when assessed in isolation and in accordance with BS 4142 [1]. In addition, the site must comply with Requirement 2 of the DCO, complying with the CoCP [9] and producing NMMPs and BMPs where required. The NMMPs and BMPs both require sign off from ESC, with the aim to ensure that the impact on nearby human NSRs is as low as practicably possible.