

Lower Barn Poultry Unit Standby Generators.

Lower Barn poultry unit operations has two standby generators.

Each generator has a thermal input of 750kw.

Generators will not be tested more than 50hrs per annum.

Generators will not be operated more than 500hrs per annum averaged over 3 years, as backup for mains interruption, including testing.