



# Larkshall

Emission point reference	Source	Parameter	Quantity	Unit
A1	Steam Boiler	NO <sub>x</sub>	250	mg/m <sup>3</sup>
A2	Extruder (air lift) via cyclone abatement	Particulate Matter	20	mg/m <sup>3</sup>
A3	Grinder via cyclone abatement	Particulate Matter	10	mg/m <sup>3</sup>
A4	Grinder via cyclone abatement	Particulate Matter	10	mg/m <sup>3</sup>
A5	Dryer via cyclone abatement	Particulate Matter	20	mg/m <sup>3</sup>
A6	Cooler via cyclone abatement	Particulate Matter	20	mg/m <sup>3</sup>