
From: steve raasch <stephenraasch@gmail.com>
Sent: 18 March 2021 09:32
To: Wray, Kate
Subject: Symmonds Farm - EPR/ZP3537MY/V003

Hi Kate

Apologies for the delay, the ventilation on all houses will be high velocity roof extraction with release height greater than 5.5m and efflux velocity 11m/s.

Regards

Steve