

**GGL 7 – Waste Types, Tonnages and Treatment Techniques - GAP Group Limited - Tanker
Kempson Way, Bury St Edmonds, Suffolk, IP32 7AR.****Waste Types**

The only waste types to be accepted are those shown in the table below –

Waste code	Description of waste	State
20 03 04	Septic tank Flood water / surface water sludge	Sludge, Liquid
20 03 06	Waste from sewage cleaning	Sludge, Liquid
16 10 02	Aqueous liquid wastes other than those mentioned in 16 10 01	Sludge, Liquid
20 03 99	Flood water / surface water	Sludge, Liquid

Treatment Capacity

The maximum quantity of waste to be received within 1 week is 350 tonnes.

The maximum quantity of waste to be received within 1 year is 18,250 tonnes.

Note: A maximum of 50 tonnes per day are discharged to the foul sewer for disposal per day.

Storage of Waste

The maximum volume of waste to be stored at any one time in the tank is 100 tonnes.

Normal operations will be 50 tonnes with capacity being increased to up to 100 tonnes for specific events.

The maximum volume of waste to be stored at any one time is 1 tonne from the manual screening process.

Treatment Techniques

The only treatment techniques will be screening via gravity over or through a metal grid.

Treatment via dewatering involved manual screening and the addition of a flocculants to aid settlement of the suspended solids.