


Appendix F – Noise Impact Assessment



ENVIRONMENTAL PERMITTING - NOISE IMPACT ASSESSMENT

BARROW MILL BOILER HOUSE

Kimberly-Clark Limited

2062351-RSKA-RP-002-(02)



RSK Acoustics Limited Reg. in England and Wales No.7102436
www.rskacoustics.com info@rskacoustics.com
+44(0)1928 726006

Registered Office: Spring Lodge, 172 Chester Road, Helsby, WA6 0AR
Bristol | Coventry | Dar Es Salaam | Dubai | Edinburgh
Helsby | Hemel Hempstead | Kingsclere | Leeds | London | Manchester



General notes

Project Name:	Barrow Mill Boiler House
Title:	Environmental Permitting - Noise Impact Assessment
Client:	Kimberly-Clark Limited
Issue Date:	10 April 2026
Report No.	2062351-RSKA-RP-002-(02)

Revision:	Description:	Author(s):	Reviewer:	Date:
01	First Issue	Kate Mann	Daniel Clare	09 April 2026
02	Minor comments addressed	Kate Mann	Daniel Clare	10 April 2026

Author(s): Kate Mann, MIOA
Senior Acoustic Consultant

Technical reviewer: Daniel Clare, MIOA
Managing Director – RSK Acoustics

Signature: 

Signature: 

Date: 10 April 2026

Date: 10 April 2026

RSK Acoustics Ltd (RSKA) has prepared this report for the sole use of the client, showing reasonable skill and care, for the intended purposes as stated in the agreement under which this work was completed. The report may not be relied upon by any other party without the express agreement of the client and RSKA. No other warranty, expressed or implied, is made as to the professional advice included in this report.

Where any data supplied by the client or from other sources have been used, it has been assumed that the information is correct. No responsibility can be accepted by RSKA for inaccuracies in the data supplied by any other party. The conclusions and recommendations in this report are based on the assumption that all relevant information has been supplied by those bodies from whom it was requested.

No part of this report may be copied or duplicated without the express permission of RSKA and the party for whom it was prepared.

Where field investigations have been carried out, these have been restricted to a level of detail required to achieve the stated objectives of the work.

This work has been undertaken in accordance with the quality management system of RSK Acoustics Ltd.



Contents

1	Introduction	4
1.1	Instruction	4
1.2	Overview of Site Operations	4
1.3	Site Location and Context.....	4
2	Policy, Standards and Guidance	7
3	Noise Survey	9
3.1	Survey Methodology	9
3.2	Survey Equipment	10
3.3	Weather Conditions	10
3.4	Survey Observations	12
3.5	Results.....	12
4	Noise Impact Assessment Methodology	15
4.1	Source Data.....	15
4.2	Modelling Methodology	15
4.3	Acoustic Corrections.....	17
4.4	Predicted Noise Levels	17
5	BS 4142 Assessment	20
5.1	Acoustic Corrections Applied	20
5.2	Boiler House Assessment.....	20
5.3	Whole Site Assessment (Existing Site and Boiler House)	21
5.4	Assessment Context.....	23
5.5	Assessment Summary	23
6	Best Available Techniques (BAT).....	24
7	Uncertainty	26
8	Summary	27
	Appendix A – Glossary.....	28
	Appendix B – Noise Survey Photographs.....	29
	Appendix C – Noise Survey Results	31
	Appendix D – Existing Site - Source Measurements	32
	Appendix E – Boiler House - Building Envelope Specifications.....	35



1 Introduction

1.1 Instruction

RSK Acoustics (RSKA) has been instructed by Kimberly-Clark Limited (KC) to undertake a noise impact assessment to inform a permit variation application for a new dual fuel (hydrogen and natural gas) boiler plant room at the existing Kimberly Clark Barrow Mill in in Barrow-in-Furness, Cumbria (LA14 4QS).

The staff preparing this document are members of the Institute of Acoustics (IOA) who have undertaken Diploma in Acoustics and Noise Control, and therefore are competent to undertake this study.

A glossary of acoustic terminology relevant to the acoustic investigation is appended to this document.

1.2 Overview of Site Operations

KC use the site to manufacture tissue products for consumer and professional businesses. The plant manufactures tissue on two tissue paper machines (TM5 and TM3), and the products can be produced from imported virgin fibre or recycled fibre which is processed in the site de-inking facility. The tissue is currently dried using heat from natural gas and steam from the existing boiler plant, housed in the HPBH. Reels of tissue are converted into rolled or folded products in the converting department and packaged before being palletised for storage and subsequent distribution.

1.3 Site Location and Context

1.3.1 Site location

The Barrow Mill site is centred on approximate National Grid reference 319574E, 472750N. An aerial image of the site is shown below:



Figure 1 Aerial view of the site



The area immediately bounding the site presently comprising the following uses and noise sensitive receptors:

- **Northern boundary** – agricultural land with industrial and commercial businesses beyond;
- **Eastern boundary** – the A590 immediately adjacent with industrial and commercial businesses, agricultural land and residential properties beyond;
- **Southern boundary** – industrial and commercial units including a building merchant and agricultural land; and,
- **Western boundary** – agricultural land and a railway line with the Walney Channel and Walney Aerodrome beyond.

Figure 2 shows the location of the site in relation to the nearest noise sensitive receptors to the site.




Figure 2 Site location

The nearest noise sensitive receptors to the site are residential properties to the east/south-east of the site, including properties located along Bank Lane, Parrock Green, Middlefield/Whinsfield Avenue, Long Croft and Keppleway Drive. The intervening ground largely comprises soft ground (fields/ agricultural land) as well as the A590.

1.3.2 Proposed development

The proposed development consists of the installation of replacement boilers, chimney stacks and associated pipework / infrastructure at the existing Barrow Mill site.

The existing boilers are located in the High Pressure Boiler House (HPBH). There are currently three boilers in the HPBH; two boilers are required for routine operation with the third used as a standby. The existing Low Pressure Boiler House (LPBH) lies adjacent (east) of the HPBH. The LPBH houses three boilers that have all been decommissioned.



As part of Kimberly Clark's sustainability strategy, the proposed development includes the provision of three new boilers with full 100% hydrogen firing capability. The boilers will have dual fuel capability to allow use of either hydrogen or natural gas as a fuel. The new boilers will be located within the existing LPBH. As with the existing boilers, two are required for routine operation with the third used as a standby. As part of the proposals, the existing chimney stacks will be replaced with new 20m high stacks (above ground level), and alterations to the building façade will be undertaken to facilitate the construction and ongoing maintenance of the new boiler plant. A new transformer will be housed in an electrical room in the proposed LPBH.

Three new pressure regulating and metering stations (PRMS) will also be installed (one for hydrogen and two for natural gas) along the grass bank on east of the site. The existing PRMS (located in the vicinity of the existing boiler house) at the site will be decommissioned as part of the works.

Hydrogen for the new boilers will be supplied by the local PEM electrolyser sited on land approximately 400 metres south of the site (approved previously under B09/2022/0869). The proposed development therefore marks the next important step for Kimberly Clark in reducing the amount of natural gas used in its production process.



2 Policy, Standards and Guidance

Document	Summary
Planning policy	
National Planning Policy Framework (NPPF) 2025	The NPPF sets out the Government's planning policies for England and how these are expected to be applied. The NPPF includes statements relating to noise and the requirement to take it into account during the planning process.
Noise Policy Statement for England (NPSE) 2010	The NPSE sets out the long-term vision of Government noise policy: to promote good health and a good quality of life through the effective management of noise within the context of Government policy on sustainable development.
Standards and guidance	
Commission Implementing Decision - establishing the best available techniques (BAT) conclusions, under Directive 2010/75/EU of the European Parliament and of the Council, for the production of pulp, paper and board (2014/687/EU), September 2014	BAT 17 provides guidance on BAT for reducing the emissions of noise from pulp and paper manufacturing.
BS 4142:2014+A1:2019 <i>'Methods for rating and assessing industrial and commercial sound'</i>	BS 4142 provides a method for rating industrial and commercial sound and a method for assessing resulting impacts upon people. The method is applicable to fixed plant installations, sound from industrial and manufacturing process and other associated activities. The rating method takes into account specific source characteristics, such as tonality, impulsivity and intermittency. The impact assessment procedure described in BS 4142 is based on the comparison of the rating sound level with the background sound level prevailing at the assessment locations. The methodology set out within the standard is not intended to be used to assess the extent of an impact at indoor locations. However, internal sound levels may be taken into account by considering any acoustic attenuation measures such as façade treatment or screening when discussing the context of the assessment result. The determination of noise amounting to a nuisance is beyond the scope of the standard.
BS 7445-1:2003 <i>'Description and measurement of environmental noise'</i>	BS 7445 defines the basic quantities to be used for the description of noise in community environments and describes basic procedures for the determination of these quantities.
BS EN IEC 60942:2018 <i>'Electroacoustics – Sound calibrators'</i>	BS EN IEC 60942 specifies the performance requirements for sound calibrators.
BS EN 61672-1:2013 <i>'Electroacoustics – Sound level meters'</i>	BS EN 61672-1 provides electroacoustic performance specifications for sound measuring instruments.
BS ISO 9613-2:2024 <i>'Acoustics – Attenuation of sound during propagation outdoors'</i>	Part two of ISO 9613 specifies an engineering method for calculating the attenuation of sound during propagation outdoors to enable the prediction of environmental noise at a distance from a variety of sources.
Environment Agency (EA),	This guidance replaces the withdrawn Environment Agency Horizontal Guidance for Noise (H3) parts 1 and 2, and



Document	Summary
Noise and Vibration Management: Environmental Permits, 2022	SEPA's Guidance on the control of noise at PPC installations. The purpose of the Noise and Vibration Management Guidance is to provide supplementary information including guidance on regulation and permitting, a description of the principles of noise measurement and prediction; and the control of noise by design, by operational and management techniques and abatement technologies. The Noise and Vibration Management Guidance specifies to follow the methodology in accordance with BS 4142 with consideration to the off-site noise monitoring survey and source assessment.
Environment Agency (EA), Method implementation document (MID) for BS 4142, 2023	This MID supplements BS 4142:2014+A1:2019 Method for rating and assessing industrial and commercial sound (BS 4142), and should be followed when applying to the EA for new environmental permits or permit variation.
World Health Organisation (WHO) Guidelines for Community Noise, 1999	The Guidelines for Community noise was published as a response to a need for action together with a generic need for improvements in legislation at a national level. Although not legislation, this document provides general guidance and guidelines which have been set for different health effects, using the lowest noise level that produces an adverse health effect in specific human environments.
WHO 'Night Noise Guidelines for Europe' (NNG), 2009	The NNG aims to present the conclusions of the WHO working group responsible for preparing guidelines for exposure to noise during the night. This document forms an extension to the WHO Guidelines for Community Noise.

Table 1 *Planning policies, standards and guidance*



3 Noise Survey

3.1 Survey Methodology

Noise surveys have been undertaken to define the sound levels at the nearest noise sensitive receptors to the Barrow Mill site to both quantify the existing noise emissions generated from the site.

Noise measurements were undertaken between Sunday 25 and Wednesday 28 December 2022 during the Christmas shutdown period as the Barrow Mill site is typically operational 24 hours a day. This allowed for background sound levels in absence of the site to be measured.

Attended noise monitoring was also undertaken on Wednesday 10 and Thursday 11 May 2023 while the site was operational to provide further context of the existing noise levels at the receptors. Measurements were undertaken during the night-time as the 24 hour operation of the site and proposed boiler house, and night-time levels representing the greatest potential for impacts due to the other noise sources in the areas being reduced.

The measurement locations are summarised in Table 2 and presented graphically in Figure 3. Photographs of the monitoring locations are presented in Appendix B.




Figure 3 Monitoring locations



Ref.	Survey Date	Measurement Type	Approx. coordinates	Description
UL1	December 2022	Unattended	562647N, 174029E	Unattended noise logger installed in free-field conditions approximately 1.5m above ground level. Installed to monitor background sound levels during the Christmas site shutdown.
AL1	May 2023	Attended	319783N, 472398E	Attended noise measurement undertaken in representative free-field conditions approximately 1.5m above ground level. Installed to monitor site levels at a location representative of the nearest noise sensitive receptors located in the vicinity of Middlefield road.
AL2			320317N, 472394E	Attended noise measurement undertaken in representative free-field conditions approximately 1.5m above ground level. Installed to monitor site levels at a location representative of noise sensitive receptors located at the eastern end of Bank Lane.

Table 2 Monitoring locations

3.2 Survey Equipment

The noise measurements were undertaken using the following equipment:

Survey Equipment	Type	Serial number	Calibration date expiry
Sound level meter	01dB FUSION	14598	30/05/2022
Acoustic calibrator	Rion NC-74	34857331	31/03/2022
Sound level meter	SVAN 971	72618	08/08/2022
Acoustic calibrator	Rion NC-74	34167506	27/06/2022

Table 3 Monitoring equipment

The sound level meters conformed to the Class 1 requirements of BS EN 61672-1:2013. The calibrators used conformed to the Class 1 requirements of BS EN IEC 60942:2018. The equipment used had a calibration history that is traceable to a certified calibration institution. Calibration certificates are available on request. The calibration of the sound level meters were field checked prior to commencing measurements and prior to removing the equipment from site upon completion; no significant calibration drift was observed i.e., within a +/- 0.5 dB tolerance.

3.3 Weather Conditions

Weather information for the background noise measurements was obtained through a nearby third-party weather station (Wunderground ref. IBARRO18) to determine conditions throughout the unattended survey duration. The weather information has been summarised in Figure 4 below. Detailed hourly weather information can be provided upon request. Noise levels measured during adverse weather conditions on Sunday 25 December until 2am on Monday 26 December 2022 have been excluded from the assessment.

For the remainder of the measurement period, wind speeds were noted to be less than 5 m/s in a predominantly northerly wind direction with no significant precipitation during the night-time periods. Therefore, weather conditions were generally considered conducive to noise monitoring.






Figure 4 Weather conditions

Weather conditions were noted during the attended noise survey in May 2023 and were clear and dry with wind speeds of less than 5 m/s, therefore weather conditions were considered conducive to noise monitoring.



3.4 Survey Observations

During the noise survey, prominent noise sources were noted to be steady state noise from the existing Barrow Mill site, road traffic noise from the A590 and regular vehicle movements on Bank Lane. In absence of the KC Barrow Mill site operations, the noise environment comprised road traffic noise and noise from a builders merchants and other industrial/commercial units located along Bank Lane and the A590.

3.5 Results

3.5.1 Unattended noise measurements – UL1 (December 2022)

The noise monitoring data measured at UL1 is presented below. A tabulated summary is presented in Appendix C.






Figure 5 UL1 noise survey results



The methodology detailed in BS 4142: 2014+A1: 2019 provides an example of statistical analysis to determine the typical background sound level ($L_{A90,15min}$). The following analysis adopts the methodologies applied within the aforementioned standard for UL 1.




Figure 6 Statistical analysis of background sound levels – UL 1

Based on Figure 6, 'BS 4142:2014+A1:2019 Technical Note (March 2020 Version 1.0) and professional judgment, an existing background sound level of **37 dB $L_{A90,15min}$** during the night-time has been derived.

3.5.2 Attended noise measurements (May 2023)

Night-time measurements were undertaken in May 2023 at AL1 and AL2 while the Barrow Mill site was operational. A summary of the attended noise monitoring levels is presented below:

Date	Time	$L_{Aeq,15min}$ (dB)	$L_{AFmax,15min}$ (dB)	$L_{A90,15min}$ (dB)
Thursday 11/05/2023	00:40	52	67	50
	00:55	52	68	50
	01:10	52	55	50
	01:25	53	68	51

Table 4 AL1 noise monitoring data

Date	Time	$L_{Aeq,15min}$ (dB)	$L_{AFmax,15min}$ (dB)	$L_{A90,15min}$ (dB)
Wednesday 10/05/2023	23:30	43	61	41
	23:45	47	68	41
Thursday 11/05/2023	00:00	46	66	42
	00:15	44	61	42

Table 5 AL2 noise monitoring data

As per Section 3.4, the noise environment was dominated by steady-state noise, particularly during the night-time when road traffic noise was reduced and the existing Barrow Mill site became more prominent. Additionally, due to the 24-hour operations of the site, and night-time levels representing the greatest potential for impacts, attended night-time only measurements were considered to be appropriate. On this basis, the data presented above is judged to be representative of the noise levels experienced at these locations while the existing site is operational.



4 Noise Impact Assessment Methodology

4.1 Source Data

The noise emission data for the new boiler plant is presented below. The assessment has been undertaken on the basis that two of the boilers (and associated stacks) will be in use under normal operating conditions, with the third used as a standby. It is assumed all other plant items associated with the proposed boiler house have the potential operate simultaneously under normal conditions.

Quantity	Octave band centre frequency (Hz) - L _p dB								L _{WA} dB
	63	125	250	500	1k	2k	4k	8k	
2	86	89	88	78	66	61	63	58	82

Table 6 Noise emission data – boilers

Quantity	Octave band centre frequency (Hz) - L _p dB								L _{WA} dB
	63	125	250	500	1k	2k	4k	8k	
2	72	108	107	105	103	100	100	96	93

Table 7 Noise emission data – stacks

Quantity	Octave band centre frequency (Hz) - L _p dB								L _{WA} dB
	63	125	250	500	1k	2k	4k	8k	
1	72	77	72	72	63	55	50	43	71

Table 8 Noise emission data - transformer

Quantity	Octave band centre frequency (Hz) - L _p dB								L _{WA} dB
	63	125	250	500	1k	2k	4k	8k	
1	-	-	-	56	65	76	79	77	82

Table 9 Noise emission data – hydrogen PRMS

Quantity	Octave band centre frequency (Hz) - L _p dB								L _{WA} dB
	63	125	250	500	1k	2k	4k	8k	
2	-	-	-	53	63	73	82	74	84

Table 10 Noise emission data – natural gas PRMS

For the existing site, source levels were determined through an attended noise survey across the site in May 2023¹ undertaken to inform a report prepared by RSK Acoustics for submission to the EA. Details of the measurements are presented in Appendix D.

4.2 Modelling Methodology

A number of proprietary and well proven software packages are available that can be programmed to conform to recognised source noise calculations and propagation calculations. Unless otherwise indicated all noise predictions presented in this report have been carried out using SoundPLAN v9.1.

¹ RSK Acoustics - 2060428-RSKA-RP-001(01) – June 2023



International Standard: ISO 9613-2: 2024: 'Acoustics - Attenuation of sound during propagation outdoors - Part 2: Engineering method for the prediction of sound pressure levels outdoors' enables the prediction of noise levels in the community from sources of known sound emission.

The noise prediction method described in this part of the standard is general and is suitable for a wide range of engineering applications where the noise level outdoors is of interest. The noise source(s) may be moving or stationary and the method considers the following major mechanisms of noise attenuation:

- Geometrical divergence (also known as distance loss or geometric damping);
- Atmospheric absorption;
- Ground effect;
- Reflection from surfaces; and
- Screening by obstructions, barriers and buildings.

The method predicts noise levels under metrological conditions favourable to noise propagation from the sound source to the receiver, such as downwind propagation, or equivalently, propagation under a moderate ground-based temperature inversion as commonly occurs at night.

An overview of the modelling parameters is given in Table 11.

Item	Setting
Algorithm	BS ISO 9613-2: 2024
Ground absorption	Ground absorption has been set based on local conditions as derived from aerial imagery and the noise surveys. Acoustically hard (assumed 0 coefficient) – roads, water, pavements and hard standing areas; Acoustically soft (assumed 1 coefficient) – grassed areas, vegetation
Meteorological conditions	10 degrees Celsius; 70% humidity; and Wind from source to receiver.
Receptor height	Ground Floor level set at 1.5m above external ground level. First Floor level set at 4m above external ground level.
Site layout	Site layout as per drawings: 3001954-AME-BM-ZZ-DR-PL-6052 P1 – Barrow Mill Steam Generation Boilers Replacement Site Location Plan as Proposed 3001954-AME-BM-ZZ-DR-PL-6054 P1 LPBH Elevations as Proposed 3001954-AME-BM-ZZ-DR-CV-6022 P2 Retaining Wall GA & Sections
Source modelling	See Section 4.1 and Appendix D. The stacks were modelled as an omni-directional point source at 20m above ground level. The boiler house was modelled as a 3D object with an internal reverberant sound pressure level calculated based on the noise data provided by Cannon Bono and Ameresco, the number of each of the sources, the geometry and finishes of each room. For the main boiler house area this was calculated to be 70 dBA, and for the transformer room this was calculated to be 62 dBA. The internal finishes are acoustically reflective: concrete floor with an average absorption coefficient of 0.02, and steel cladding with an average absorption



Item	Setting
	coefficient of 0.10. Spectral data for the building envelope is presented in Appendix E. Areas of the existing brick building are being retained, modelled as single leaf brick meeting 45 R_w dB. The remainder of the boiler house as per site layout plans comprises a cladding and roof system meeting 26 R_w dB and 25 R_w dB respectively with louvred openings (modelled as fully transmissive areas), and roller shutter doors and double doors meeting 18 R_w dB. The hydrogen PMRS is modelled as a 3D object (3.3m L x 16.5m W x 2.4m H) - 72 dBA at 1m (accounting for a 10 dB reduction due to a GRP enclosure). The natural gas PMRS are modelled a 3D object (4.9m L x 2.5m W x 2.5m H) - 74 dBA at 1m (accounting for a 10 dB reduction due to a GRP enclosure).
Terrain	LiDAR DTM from Defra with a 1-metre resolution has been imported into the model.

Table 11 Modelling parameters

4.3 Acoustic Corrections

According to BS 4142:2014+A1:2019: 'Methods for rating and assessing industrial and commercial sound', where certain features of the specific sound level can increase the significance of impact of a sound level, a character correction through objective and/or subjective methods is applied to provide a rating level. The characteristics of a sound that are likely to cause an increase in the significance of impact are tonality, impulsivity, intermittency or where the specific sound is readily distinctive (such as a whine, hiss, screech, non-tonal hum, rattle or rasp) against the residual acoustic environment.

4.4 Predicted Noise Levels

4.4.1 Specific sound level - boiler house

The specific sound level for the boiler house plant at each of the nearest noise sensitive receptors has been calculated as per Section 4.2, and are presented below in Figure 7 and Table 12.






Figure 7 Predicted specific sound levels (boiler house)

On this basis, the specific sound levels used for the assessment of the boiler house are presented below in Table 12. These are the nearest noise sensitive receptors to the site and therefore have the potential to be the worst affected by the proposed boiler house plant.

Noise sensitive receptor	Specific sound level, $L_{Aeq,15min}$ (dB)
Bank Lane Farm	34
Middlefield	37
Parrock Green	35
Long Croft	33
Keppleway Drive	24

Table 12 Specific sound levels

4.4.2 Specific sound level - whole site (existing site and boiler house)

The specific noise levels used for the assessment of the whole existing site and the proposed boiler house plant are presented below in Table 13.

Noise sensitive receptor	Specific sound level, $L_{Aeq,15min}$ (dB)
Bank Lane Farm	47
Middlefield	49
Parrock Green	48
Long Croft	43



Noise sensitive receptor	Specific sound level, $L_{Aeq,15min}$ (dB)
Kepplewray Drive	38

Table 13 Specific sound levels – whole site



5 BS 4142 Assessment

5.1 Acoustic Corrections Applied

Taking the acoustic features referenced above in Section 4.3 and predicted levels (Section 4.4) into consideration, the application of rating penalties is as follows:

- **Tonality** – From analysis of the frequency data predicted at the nearest noise sensitive receptors, it is considered unnecessary to apply a tonal correction at any of the receptors;
- **Impulsivity** - The character of the sound from the site is generally constant, with no rapid change in the level or character of noise. It is therefore considered unnecessary to apply an impulsive correction at any of the receptors; and,
- **Intermittency** – The site typically operates 24/7 therefore does not have identifiable on/off conditions. It is therefore considered unnecessary to apply an intermittency correction at any of the receptors.
- **Other sound characteristics** - The proposed boiler house plant is unlikely to be readily distinguishable from the existing residual acoustic environment in terms of overall level and character. For the assessment of the whole site, a 3 dB penalty has been applied to two of the receptors to correct the specific noise level to account for industrial noise impacts where the sound is neither impulsive or tonal but where it is audible against the residual sound level in accordance with EA guidance.

5.2 Boiler House Assessment

Prior to context, Table 14 presents the measured specific and rating sound levels, alongside background sound levels and difference between background and rating levels during the night-time (23:00-07:00) for the proposed boiler house plant.

As per BS 4142, the significance of sound of an industrial nature depends upon both the margin by which the rating level of the specific sound source exceeds the background sound level and the context in which the sound occurs. Typically, the greater this difference, the greater the magnitude of impact.



Results	Noise sensitive receptor location					Comments
	Bank Lane Farm	Middlefield Road	Parrock Green	Long Croft	Keppleway Drive	
Specific sound level, $L_{Aeq,15min}$ (dB)	34	37	35	33	24	Section 4.4.1 as determined through calculation (Section 4.2)
Character corrections	0	0	0	0	0	Section 5.1
Rating level, $L_{Ar,15min}$ (dB)	34	37	35	33	24	
Ambient sound level, $L_{Aeq,15min}$ (dB)	52	52	52	52	44	Section 3.5.2 - inclusive of the existing KC Barrow Mill site
Residual sound level, $L_{Aeq,15min}$ (dB)	43	43	43	43	43	Section 3.5.1 - excludes the existing KC Barrow Mill site
Background sound level, $L_{A90,15min}$ (dB)	37	37	37	37	37	Section 3.5.1 - excludes the existing KC Barrow Mill site
Excess of rating over background level (dB)	-3	0	-2	-4	-13	

Table 14 BS 4142 assessment – night-time (proposed boiler house plant only)

At all receptors, the initial assessment of impacts from the proposed boiler house shows that the rating levels do not exceed the existing background sound level during the night-time. This is an indication of low impact, depending on the context.

5.3 Whole Site Assessment (Existing Site and Boiler House)

To provide further context, Table 15 presents the measured specific and rating sound levels, alongside background sound levels and difference between background and rating levels during the night-time (23:00-07:00) for the existing site and the proposed boiler house plant.

As per BS 4142, the significance of sound of an industrial nature depends upon both the margin by which the rating level of the specific sound source exceeds the background sound level and the context in which the sound occurs. Typically, the greater this difference, the greater the magnitude of impact.



Results	Noise sensitive receptor location					Comments
	Bank Lane Farm	Middlefield Road	Parrock Green	Long Croft	Keppleway Drive	
Specific sound level, $L_{Aeq,15min}$ (dB)	47	49	48	43	38	Section 4.4.2 as determined through existing measurement source data and calculation (Section 4.2)
Character corrections	3	3	3	0	0	Section 5.1 - +3 dB applied to Bank Lane Farm and Middlefield Road to account for industrial noise likely to be audible against the residual sound level
Rating level, $L_{Ar,15min}$ (dB)	50	52	51	43	38	
Ambient sound level, $L_{Aeq,15min}$ (dB)	52	52	52	52	44	Section 3.5.2 - inclusive of the existing KC Barrow Mill site
Residual sound level, $L_{Aeq,15min}$ (dB)	43	43	43	43	43	Section 3.5.1 - excludes the existing KC Barrow Mill site
Background sound level, $L_{A90,15min}$ (dB)	37	37	37	37	37	Section 3.5.1 - excludes the existing KC Barrow Mill site
Excess of rating over background level (dB)	+13	+15	+14	+6	+1	

Table 15 BS 4142 assessment – night-time (whole site)

A difference of 10 dB or more can be an indication of significant adverse impact, depending on the context. A difference of around +5 dB is likely to be an indication of adverse impact depending on the context.



5.4 Assessment Context

The Barrow Mill site has been operational for over 55 years and therefore is considered to form part of the existing environment. Additionally, Barrow-in-Furness is a port town with a significant amount of industry both historically and presently, including BAE Systems and other engineering and manufacturing companies, therefore the noise from the site is not out of character for the area. In line with EA guidance, long-standing industry and other industries in the area makes the area inherently less sensitive to sources of industrial noise.

It is acknowledged that the proposed boiler plant will have the potential to be operational 24 hours a day, including during the night-time which is considered to be a more sensitive time period. On this basis the assessment has been undertaken for night-time hours when measured background sound levels are reduced to account for this. Additionally, the existing site is already operational 24 hours a day.

The predicted noise levels indicate that the proposed boiler house plant is unlikely to be distinguishable from the existing residual acoustic environment in terms of overall level and character, particularly given the existing industrial, commercial and transportation noise sources audible at the receptor locations. This is theoretically shown when you compare the noise levels predicted from the proposed plant in isolation, and the existing site operations (see Appendix D), where boiler house plant noise is greater than 10 dB lower than existing site noise.

5.5 Assessment Summary

At the most affected noise sensitive receptors to the site, noise from the proposed boiler plant is unlikely to be distinguishable or detectable within the context of the existing acoustic environment. This is an indication of a low impact in line with BS 4142 and EA guidance for noise and vibration management: environment permits. Notwithstanding this, appropriate BAT measures should still be maintained (see Section 6).



6 Best Available Techniques (BAT)

The following embedded mitigation measures are proposed to ensure noise levels from the proposed boiler house plant are minimised as far as practicable, and in line with EA guidance for noise and vibration management: environment permits, and the BAT-C (BAT 17) guidance document:

Noise source	Mitigation implemented	Contribution to off-site receptors ^[1]	Relevant BAT technique (BAT 17)	BAT Implemented – Yes/No?	Additional actions to be taken to meet BAT and timescales
Boilers	Enclosed in the boiler house building comprising brick, cladding, roller shutter doors and double glazing. The minimum specification required by the building envelope is presented in Appendix E.	Low	C. Operational and management techniques in buildings containing noisy equipment D. Enclosing noisy equipment and units G. Soundproofing of buildings	Yes	No further action
Transformer	- An inspection and maintenance of equipment to prevent failures. - All doors to be closed when access is not required by operations.			Yes	No further action
Boiler stacks	Silencers meeting a minimum broadband reduction of 17 dBA to be fitted to the boiler stacks.	Low	H. Noise abatement E. Use of low-noise equipment and noise-reducers on equipment and ducts.	Yes	No further action
PRMS units	- Located behind the grass bank of the site boundary. - An inspection and maintenance of equipment to prevent failures. - Enclosed in a GRP enclosure achieving a minimum broadband reduction of 10 dBA.	Low	B. Strategic planning of the location of equipment, units and buildings C. Operational and management techniques in buildings containing noisy equipment D. Enclosing noisy equipment and units	Yes	No further action
Notes:					



Noise source	Mitigation implemented	Contribution to off-site receptors ^[1]	Relevant BAT technique (BAT 17)	BAT Implemented – Yes/No?	Additional actions to be taken to meet BAT and timescales
^[1] Contribution to off-site receptors based on predicted noise levels (see Section 4.4.1). The contributions are categorised as follows: 'low' – indistinguishable off-site, 'medium' – just perceptible off-site and 'high' – clearly perceptible off-site					

Table 16 *BAT summary*

The above measures are considered to be the best available techniques (BAT) for the site to prevent, or where that is not practicable to minimise noise from the proposed boiler house.



7 Uncertainty

BS 4142:2014+A1: 2019 requires that the assessment considers the level of uncertainty in the data and associated calculations. Consideration of the uncertainty can enable a more informed decision regarding the likely significance of impact, within the context of assessment. It is accepted that uncertainty may arise from all levels of measurement and assessment and reasonably practicable steps have been made at all stages with the aim of reducing uncertainty.

Specific sound level propagation for the proposed boiler house and wider site has been calculated in accordance with the requirements of BS ISO 9613-2:2024 which is the widely accepted procedure for the calculation of sound propagation, including favorable wind conditions from source to receiver. Source data for the boiler plant and PMRS (including frequency data) was provided by the project team. The transformer broadband level was provided by the project team, with frequency data assumed based on a transformer of a similar size.

The noise survey was short-term in duration which may introduce some uncertainty, however survey observations confirmed that the dominant noise sources at the monitoring locations were steady-state noise from the existing Barrow Mill site, other local industry in the area, and road traffic noise. This is reflected in the measured data at AL1 and AL2 which is relatively consistent between measurements. Additionally, to limit uncertainty related to the survey duration, the lowest $L_{A90,15min}$ at each monitoring location was used to inform the assessment.

The following measures were also taken during the noise surveys to limit uncertainty:

- The survey and assessment have been undertaken by suitability qualified acousticians who are members of the Institute of Acoustics (IOA);
- Although the noise survey was undertaken in 2022, there are no additional significant sources of noise in the local area based on an observational site visit in November 2025 and review of aerial imagery. The dominant noise sources were industrial noise associated with local industry and road traffic noise from the A590 which is still the case;
- It should be considered that the measurements were undertaken during a period where road traffic noise and other local noise sources may have been reduced due to the Christmas bank holidays. As the noise environment is influenced by road traffic noise (including from the A590) and other industrial premises, 37 dB $L_{A90,15min}$ may be lower than during normal conditions. This background sound level has also been taken to be representative of all receptors. In reality, the background sound level is likely to be higher with proximity to the A590 and industrial/commercial premises located along the A590, therefore 37 dB $L_{A90,15min}$ represents a more onerous criterion for receptors located closer to the A590.
- Use of monitoring equipment in accordance with Section 5 of BS 4142: 2014+A1: 2019, using Class 1 instrumentation; and,
- Measurement procedures followed in general accordance with Section 6 of BS 4142: 2014+A1: 2019 with all precautions taken to minimise interference whilst maintaining the security of both personnel and monitoring equipment. Weather conditions were monitored throughout the duration of the survey to ensure weather conditions were conducive to noise monitoring.

Overall, based on the above, uncertainty related to the survey data is not expected to have any significance to the outcome of the assessment.



8 Summary

RSK Acoustics has been instructed by Kimberly-Clark Limited (KC) to undertake a noise impact assessment to inform a permit variation for a new dual fuel (hydrogen and natural gas) boiler plant room at the existing Kimberly Clark Barrow Mill in Barrow-in-Furness, Cumbria.

The noise assessment includes consideration of background and residual sound levels, and specific sound levels from the proposed plant including relevant corrections, based on the methodology as described within BS 4142:2014+A1:2019. The proposals incorporate the relevant BAT techniques, and as a result, accounting for the context of the acoustic environment in line with B4142 and EA guidance, the proposed boiler house is unlikely to result in adverse effects at the nearest noise sensitive receptors, with no changes to the existing noise environment anticipated.



Appendix A – Glossary

Term	Definition
Ambient sound	The total sound at a given place, usually a composite of sounds from many sources near and far.
Background sound, $L_{A90,T}$	A-weighted sound pressure level that is exceeded by the residual sound at the assessment location for 90% of a given time interval.
dB	Decibel. Scale for expressing sound pressure level. It is defined as 20 times the logarithm of the ratio between the root mean square pressure of the sound field and a reference pressure i.e. 2×10^{-5} Pascal.
dB(A)	A-weighted decibel. This provides a measure of the overall level of sound across the audible spectrum with a frequency weighting to compensate for the varying sensitivity of the human ear to sound at different frequencies. Example sound levels include: 140 dB(A) Threshold of pain 120 dB(A) Threshold of feeling 100 dB(A) Loud nightclub 80 dB(A) Traffic at busy roadside 60 dB(A) Normal speech level at 1m 40 dB(A) Quiet office 20 dB(A) Broadcasting studio 0 dB(A) Median hearing threshold (1000 Hz)
Frequency	The repetition rate of a sound wave. The subjective equivalent in music is pitch. The unit of frequency is the Hertz (Hz), which is identical to cycles per second. A thousand hertz is often denoted as kHz, e.g. 2 kHz = 2000 Hz. Human hearing ranges approximately from 20 Hz to 20kHz.
$L_{Aeq,T}$	This is defined as the notional steady sound level over a stated period of time (T), would contain the same amount of acoustical energy as the A-weighted fluctuating sound measured over that period.
Rating level	Specific sound level of a source plus any adjustment for the characteristic features of the sound.
Residual sound	Ambient sound remaining at the assessment location when the specific sound source is suppressed to such a degree that it does not contribute to the ambient sound.
Sound absorption	Process whereby sound energy is converted in to heat. Sound absorption properties is expressed as the sound absorption coefficient α or the sound absorption class (A-E).
Sound insulation	The reduction or attenuation of airborne sound by a solid element between source and receiver.
Specific sound	Sound pressure level produced by the source being assessed at the assessment location.

Table A 1 Glossary



Appendix B – Noise Survey Photographs



Figure B.1 UL1





Figure B.2 AL1



Figure B.3 AL2



Appendix C – Noise Survey Results

Date	Time	Measured noise levels (dB)		
		$L_{Aeq,T}$	$L_{AFmax,T}$	$L_{A90,T}$
Monday 26/12/2022	00:00-07:00	55	85	45
	07:00-23:00	58	83	51
	23:00-07:00	45	69	38
Tuesday 27/12/2022	07:00-23:00	51	87	43
	23:00-07:00	51	87	43
	07:00-13:00	60	93	45

Table C.1 Noise monitoring data – UL1



Appendix D – Existing Site - Source Measurements

To quantify the noise emissions generated from the existing Barrow Mill site, a collection of short-term source measurements were undertaken across the site in May 2023. This comprised external boundary measurements and internal/external sample measurements of specific plant items and processes.

The measurement data and monitoring locations are presented below.

Monitoring Location	Ref:	Distance (m)	Duration of measurement	Sound Pressure Level ($L_{Aeq,T}$ dB)
Left of the compressor house (Area 3)	1	1.5m from shutters	1min	81
	2	3m " "	1min	81
	3	5m " "	1min	82
	4	8m " "	1min	81
	5	12m " "	1min	81
	6	20m " "	1min	75
	7	30m " "	1min	72
	8	40m " "	1min	70
West side of site (between Area 1 and 4)	9	1m from shutters & door	1min	77
	10	5m " "	1 min	78
	11	10m " "	1 min	78
	12	20m " "	1 min	76
	13	30m " "	1 min	73
	14	40m " "	1 min	72
West side of site (along Area 4)	15	10m from new cladding	1 min	78
	16	20m " "	1 min	75
	17	30m " "	1 min	72
	18	40m " "	1 min	71
Mezzanine above waste heat transfer area including mist remover scrubber and fan, and hood exhaust (Area 3)	19	1m from fan	1 min	88
	20	1m from fan	1 min	86
	21	1m from fan	1 min	88
	22	1m from fan	1 min	87
	23	3m from fan	1 min	85
	24	5m from fan	1 min	82
Mezzanine above dryer building including wet dust scrubber and fan (Area 3)	25	1m from fan	1 min	86
	26	1m from fan	1 min	86
	27	1m from fan	1 min	86
TM3	28	1m from PM3 façade	1 min	89
	29	1m from PM3 façade	1 min	84
	30	1m from PM3 façade	1 min	82
	31	1m from PM3 façade	1 min	80
	32	1m from PM3 façade	1 min	82



Monitoring Location	Ref:	Distance (m)	Duration of measurement	Sound Pressure Level ($L_{Aeq,T}$ dB)
	33	1m from PM3 façade	1 min	76
Pulper Building (Area 1)	34	1m from fan	1 min	85
Broke Tower (Area1)	35	1m from fan	1 min	75
Area between boiler house and Area 4	36	N/A	1 min	76
Site boundary	B1	N/A	15 min	69
	B2	N/A	15 min	69

Table D.1 Source measurements (existing site)



Figure D.1 Source measurement locations (existing site)



The specific sound levels used for the assessment for the existing site are presented below

Noise sensitive receptor	Specific sound level, $L_{Aeq,15min}$ (dB)
Bank Lane Farm	47
Middlefield	49
Parrock Green	48
Long Croft	43
Keppleway Drive	38

Table D.2 Specific sound levels (whole site existing)



Appendix E – Boiler House - Building Envelope Specifications

The building envelope of the boiler house comprises the following minimum specification:

Item	Octave band centre frequency (Hz) - R_w dB								R_w dB
	63	125	250	500	1k	2k	4k	8k	
Kingspan QuadCore AWP-S panel	14	19	21	25	21	34	47	53	26
Kingspan QuadCore Lo-Pitch Roof panels	20	18	20	24	20	29	39	47	25
Louvres	-	-	-	-	-	-	-	-	-
Single leaf brick 125mm	30	36	37	40	46	54	57	59	45
Roller shutter doors	2	7	10	15	17	20	20	22	18
Double glazing 4 / 8 / 4mm	14	18	17	24	35	41	35	35	29
Steel door single leaf with seal, T30	22	22	28	28	24	23	23	23	25
Double swing door system	9	9	15	17	17	19	19	19	18

Table E.1 Sound reduction index - octave band data



