

Milnes, Connor

From: steve raasch <stephenraasch@gmail.com>
Sent: 07 June 2022 06:46
To: Stephen, Andrew; PSC Land
Subject: EPR/JP3709BQ/V002

Hi Andrew

Can confirm the efflux velocity of the roof fans for both existing and new house of 11m/s, as per the pre app.

Regards

Steve