

Mr Clive Saul  
Leeds City Council  
Department of Planning  
The Leonardo Building (2) Rossington  
Street  
Leeds  
West Yorkshire  
LS2 8HD

**Our ref:** RA/2011/119957/04-L01  
**Your ref:** 11/03705  
**Date:** 19 October 2012

Dear Mr Saul

**ENERGY RECOVERY FACILITY (INCINERATION OF WASTE AND ENERGY GENERATION), ASSOCIATED INFRASTRUCTURE AND IMPROVEMENTS TO ACCESS AND BRIDGE. SKELTON GRANGE ROAD, STOURTON, LEEDS**

Thank you for your consultation.

It is our understanding from viewing Drawing SG3/16 that the works to the existing bridge will not impede flood water in any way. I.e. the soffit levels etc will remain the same. The finer details of the works to the bridge (including methodology) and the works within 8 metres of both banks of the River Aire will need to be considered by the Environment Agency as part of the Water Resources Act 1991 and Yorkshire Land Drainage Byelaws application in due course.

In addition to the above, our previous comments relating to flood risk remain applicable.

**Advice to applicant**

Under the terms of the Water Resources Act 1991, and the Yorkshire Land Drainage Byelaws, the prior written consent of the Environment Agency is required for any proposed works or structures, in, under, over or within 8 metres of the top of the bank of the River Aire, designated a 'main river'.

**Advice to applicant**

The Environment Agency has issued a series of Pollution Prevention Guidelines (PPG). Works should be carried out with due consideration to PPG 5 - Guidance for working in and around water.

If you have any questions regarding these comments please contact me using the details below.

Environment Agency  
Lateral 8 City Walk, LEEDS, LS11 9AT.  
Customer services line: 03708 506 506  
[www.environment-agency.gov.uk](http://www.environment-agency.gov.uk)  
Cont/d..

Yours sincerely

**Mr Zulfiqar Ali**  
**Planning Officer**

Direct dial 01133954567

Direct fax 01132134609

Direct e-mail [zulfiqar.ali@environment-agency.gov.uk](mailto:zulfiqar.ali@environment-agency.gov.uk)