

Access Consultation Comments – Development Control

Date Received:	16/07/2012
Date Completed:	16/07/2012
Date Returned:	16/07/2012
Objection:	Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>
Access Section:	Anup Sharma
DC Area:	MIN
DC Case Officer:	Clive Saul

Reference No.: P/11/03705/FU/MIN mk4

Address:
 Skelton Grange Road
 Stourton, Leeds

Brief Description of the Proposal:
 Energy recovery facility (incineration of waste and energy generation), associated infrastructure and improvements to access and bridge

Comments:

The applicants have stated in a letter dated 16th July 2012

In response to the comments made by Rachel Smalley dated 3rd May 2012 regarding access issues I can confirm that the removable bollards used to prevent coaches or other vehicles driving into the pedestrianised plaza to the front of the ERF building would be at least 1000mm high and contrast visually with the background against which they are to be seen, in accordance with BS8300:2009 5.7.1.2. The removable bollards would also incorporate a band, 150mm high, towards their top edge which again contrasts with the surface of the bollard. This can be addressed in a suitably worded condition, if necessary.

With the above in mind and assuming the matter will be dealt with by condition I have no objection.

Signed Off	Anup Sharma
Date:	16/07/2012