


NOTES
 Drawing for indication only. Reproduced with the permission of the controller of H.M.S.O. Crown copyright licence No. 100022432. This drawing is copyright and property of Oaktree Environmental Ltd.

REVISION HISTORY			
Rev:	Date:	Init:	Description:
-	26.02.25	JH	Initial drawing
A	09.12.25	JH	Amendment
B	18.12.25	JH	Layout amendment

- KEY:**
- Permit boundary
 - Waste storage areas
 - Storage areas
 - Non-waste fuel, fluids
 - Temporary storage/sorting areas
 - Covered areas
 - Concrete areas
 - Waste recycling/ storage buildings (impermeable concrete floor)
 - Office/welfare
 - Out of hours plant storage
 - 300mm thick solid concrete wall
 - Quarantine area
 - 🔥 Firefighting equipment/extinguishers (indicative locations)
 - 🔔 Fire alarms (indicative locations)
 - 🧴 Spill kits (indicative locations)
 - 🛑 Plant shut off
 - 🧯 Hose reel
 - 🚰 Mains Water
 - 🚰 Designated smoking area
 - Access route for emergency services
 - H Fire hydrant
 - 🚰 Fire assembly points
 - 📹 Pan, tilt & zone cameras with 360 50cm coverage
 - INT Interceptor
 - ➡ Surface water fall direction
 - Foul drainage
 - ||||| ACO drain
 - Bore hole
 - P Pump
 - Firewater containment boom



Waste Storage Area Details - PILE SIZES BASED ON AREA OF STOCKPILE ON SITE PLAN NOT LENGTH X WIDTH												
Plan Ref	Description	EWCC code/s	Processed / unprocessed	Containment	Max Width (m)	Max Length (m)	Height (m)	Max area (m ²)	Conversion factor used	Volume (m ³)	Tonnage (approx.)	Storage duration
AREA 1	Mixed HCl waste reception, tipping and sorting area	17 09 04, 19 12 12, 20 03 01, 20 03 07	Unprocessed	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	21	7	3	147	0.75	331	165	< 24 hours
AREA 2	Plastic	15 01 02, 15 01 10, 20 03 01, 02 01 04, 20 01 39, 19 12 04	Partially processed (sorted by hand or grab from waste in AREA 1 or 5)	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	21	8	3	168	0.75	378	189	< 7 days
AREA 3	Wood	17 02 01, 19 12 07,	Partially processed (sorted by hand or grab from waste in AREA 1 or 5)	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	8.5	5	3	43	0.75	96	48	< 7 days
AREA 4	Stone / concrete / hardcore	17 01 07	Partially processed (sorted by hand or grab from waste in AREA 1 or 5)	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	8.5	5	3	43	0.75	96	48	< 7 days
AREA 5	Mixed HCl waste reception, tipping and sorting area	17 09 04, 19 12 12, 20 03 01, 20 03 07	Unprocessed	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	21.5	6	3	129	0.75	290	145	< 7 days
AREA 6	Light General C&D Waste	17 09 03, 19 12 01	Partially processed (sorted by hand or grab from waste in AREA 1 or 5)	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	11.5	5	3	58	0.75	129	65	< 7 days
AREA 7	Wood	17 02 01, 19 12 07,	Partially processed (sorted by hand or grab from waste in AREA 1 or 5)	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	8.5	5	3	43	0.75	96	48	< 7 days
AREA 8	Mixed scrap metal	17 04 07, 19 12 02, 19 12 03	Partially processed (sorted by hand or grab from waste in AREA 1 or 5)	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	8.5	5	3	43	0.75	96	48	< 7 days
AREA 9	Plasterboard	17 08 02	Partially processed (sorted by hand or grab from waste in AREA 1 or 5)	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	8.5	5	3	43	0.75	96	48	< 7 days
AREA 10	Plastic Pipes & Rigid Plastics	17 02 03	Partially processed	Free standing inside a 3-sided storage bay. Height of firewall measures 4.0m	8.5	5	3	43	0.75	96	48	< 7 days

TITLE:
 SITE LAYOUT & FIRE PLAN

CLIENT:
 Kenny Services Limited

PROJECT/SITE:
 Walkers Yard, Groby Road, Manchester M34 5HT

SCALE @ A2: 1:500 **CLIENT NO:** 0477 **JOB NO:** 001

DRAWING NO: GRO-477-03 **REV:** B **STATUS:** Issued

DATE: 18.12.25 **DRAWN:** JH **CHECKED:** CP

