Refuse Skips
Surface water from refuse skip area to drain into kerb drain units and will flow through Interceptor 1 prior to attenuation tank and then outfall to Anglian Water surface water sewer.
Proposed Concrete Service Yard
Designated Vehicle Washing Area
Runoff from vehicle washing area can contain high levels of pollutants such as; Detergents, Oil and fuel, Suspended solids, Grease, and Antifreez. Surface water runoff from wash down area only must discharge directly to the foul sewer.
Interceptor 1
SPEL Puraceptor P2501CSC
2.7mB x 16.7m Long
Surface Water Attenuation Tank
42m long x 15m wide x 2m deep
>> NEW 600Ø SW >>
>> NEW 450Ø SW >>
>> NEW 150Ø FW >>
>> NEW 150Ø FW >>
>> NEW 150Ø F