

Biomass Boilers

Make and Boiler Model – Jutsen Flex 900 Nominal heat output 900Kwh

Number of boilers 2 Total heat output 1800Kwh

Combined Thermal input 1894Kwh (947Kw each)

Back up LPG boilers

Exhaust stack heights 10m

Adjacent building heights 9 m

Farm Centre Grid Reference 499415,263919

Exhaust stack Grid References

499328,263907 and 499324,263906

Biomass fuel – Approved biomass, Straw

Approx storage 200 tonnes, estimated annual use 1800 tonnes

Boiler ash will be securely stored before being sent offsite as waste or spread with litter under exemption.

No receptors within 50m.

Boilers are eligible for RHI, certificate submitted.