



Technical Assessment & BAT Techniques

The upgrading of Waste4Generation's permitted operation to an installation requires the site to upgrade the operating techniques and treatment process to strive to achieve Best Available Techniques (BAT) in both treatment process, operations and procedures.

BAT Assessment

As part of our application, the site has undertaken an external BAT assessment (attached), which demonstrates how we comply with each BAT technique applicable to our site.

In conclusion the assessment found Waste4Generation and the proposed upgrades to installation to be compliant with BAT BREF conclusions (please see attached assessment).

Abatement Techniques

With the upgrades to the site, Waste4Generation have upgraded our abatement techniques to treat odours throughout the site.

We use two BAT designated abatement techniques on-site for odour treatment, Wet Scrubbing and Adsorption.

Wet-Scrubbing

The centralised odour abatement system utilises wet scrubbing of off gases & displaced air to remove potential odours. Due to the design of the centralised odour abatement system, it can utilise different chemical additions to optimise the scrubbing required.

Treated effluent (chemically dosed prior to entering the system) is pumped over the packing media within the abatement system, creating a trickle filter. The off gases pass through the packing media as the treated effluent trickles through the media, removing any odours prior to release. The effluent prior to the ozone/nano bubble treatment has been pH corrected (and has the potential for peroxide/sodium hypochlorite dosing) subject to requirements, to facilitate the removal of odour from both the off-gases and the effluent. Once treated the off gases are released into the atmosphere, where it is continually monitored and optimised. The off gases have already been primarily treated via a carbon scrubber to optimise removal efficiency.

This centralised odour abatement system takes the place of the previous methane stripper located on-site, and as such we have replaced this emission point within our odour management plan and will be monitoring this point as per BAT requirements (and those listed within the permit for the methane stripper).

The centralised odour abatement system pulls air from the head space and treats displaced air from these three activities:


1. Feedstock storage / processing tanks

2. Warehouse processes
3. Tanker discharges

The abatement system for activities 1 & 2 are pulled through carbon scrubbers prior to treatment at the odour abatement system. Off gases / displaced air are pulled into the odour abatement system by extraction, then blown up through the treatment tower and media packing by an integrated blow at the base of the unit. The gas then passes through the media whilst treated effluent containing ozone, sodium hypochlorite, chemical correction and peroxide (where applicable, and introduced into the effluent prior to the abatement system) is introduced at the top of the tower and trickles down through the media, coming into contact with the off gases / displaced air to treat potential odours.

Once the treated off gases / displaced air are dispersed at the top of the tower to atmosphere. Due to the centralised release of the odours from the top of the tower, it can be monitored constantly, and adjustments can be made to reduce / increase treatment where required.

The below schematic details the precise control in which the centralised odour abatement system showing how the treated effluent to be trickled through the packing media can be adjusted and dosed accordingly depending on the odour requirements of site.



FE Plant & Equipment			
FE Plant no	Description	Specification	Comments
FEP1	Final effluent pump	10m ³ /hr Auto pump	Supplier: Auto Pump
FEP2	Nano bubble pump	TBD	
FEP3	Methane scrubber blower		
FEP4	Odour extraction tower		
FEP5	Peroxide dosing pump	Nano bubble/active peroxidic pump	Supplier: Watson & Howe
FEP6	pH dosing pump	Water soluble/peroxidic pump	Supplier: Watson & Howe
FEP7	Odour scrubber submersible pump	20m ³ /hr	Supplier: whilper pumps
FE1	FE pump pressure instrument	0-10 bar 40-20MA	Supplier: RS Components
FE2	Nano unit pump pressure instrument	0-10 bar 40-20MA	Supplier: RS Components
FE3	Nano re-circulation pump pressure instrument	0-10 bar 40-20MA	Supplier: RS Components
FEP14	Ceramic filter	6m ³ /hr	Supplier: OXYFUSION
FEP15	Nano bubble unit		Supplier: OXYFUSION
FEP16	Nano bubble re-circulation pump		

Tank Capacities			
Item no	Description	Specification	Comments
1	Polishing tank A	10 m ³	
2	Polishing tank B	7 m ³	
3	Polishing tank C	7 m ³	
4	FE2 Nano bubble Ozone unit	10 m ³	
27	Odour scrubber	1m ³	
29	Drain pumping station	1m ³	

Valve Schedule			
Valve no	Description	Specification	Comments
FEV1	Ceramic filter valve	TBD	
FEV2	Submersible pump valve		
FEV3	Odour scrubber valve		
FEV4	Nano bubble outlet valve		
FEV5	Nano bubble re-circulation valve		
FEV6	Nano bubble unit feed valve		
FEV7	Nano bubble tank inlet valve		
FEV8	Re-circulation pump valve		
FEV9	Polishing tank A outlet valve		
FEV10	Polishing tank B outlet valve		
FEV11	Polishing tank A outlet valve		
FEV12	FE Dose inlet valve		
FEV13	Nano re-circulation inlet valve		
FEV14	Polishing tank A outlet valve		
FEV15	Polishing tank B inlet valve		
FEV16	Polishing tank B outlet valve		
FEV17	Polishing tank C inlet valve		
FEV18	Polishing tank C outlet valve		
FEV19	Caustic isolation valve		
FEV20	Peroxide isolation valve		
FEV21	Nano bubble tank inlet valve		
FENRV1	Submersible pump NRV		
FENRV2	Final Effluent pump NRV		
FENRV3	Nano bubble pump NRV		
FENRV4	Re-circulation pump NRV		
OCV1	Odour control valve 1	Warehouse odour extraction	
OCV2	Odour control valve 2	Tanker odour extraction	
OCV3	Odour control valve 3	Feedstock odour extraction	
OCV4	Odour control valve 4	Odour extraction blower	



Both the addition of nano-bubble treated water (highly oxygenated water) as well as ozonated water (O₃) are highly efficient treatment method for odours, effluents containing ammonia, sulphides etc as well as removing other contaminants.

The nano bubble (& attached ozone) unit has the below capabilities, which can be adjusted to be tailored to the site's requirements:

Nano-Bubble Oxygen & Ozone Delivery	
O ₂ Delivery Rate	15m ³ /hour liquid flow rate (10 litres per minute) provides 800 g/hour (@93% transfer) and 640 g/hour oxygen (@80% gas transfer)
Ozone Delivery Rate	30 g/hour based at 15m ³ /hour
Ozone Specification	5-14% Ozone by Weight (Oxygen Fed)
Nano Bubble Initial Spec	Oxy 15 with Ozone Atlas 30

The monitoring program detailed within the odour management plan ensures that the operation and optimisation of the abatement system.

Adsorption


There are to be 7 carbon scrubbers proposed to be implemented throughout site to best manage potential odours. These carbon scrubbers (filters) are used to treat the off gases from tankers and tanks. Each carbon scrubber has a 2m³ capacity and is dedicated to a process.

The activated carbon volume in each vessel is between 250 – 500 kg. Daily checks will monitor the performance of the carbon, and as soon as an odour becomes detectable, the carbon shall be changed.

The carbon scrubber is designed for the low flows and low concentrations of VOCs and H₂S produced onsite. The below table details the carbon scrubbers on site and their capacities:

Scrubber No.	Scrubber Description	Description & Process	Scrubber Specification
H ₂ S Scrubber 1	CHP H ₂ S Scrubber	Scrubber prior to the CHP engine ensures that levels of hydrogen sulphide are below 150 ppm, protecting the engine from damage.	2m ³ Scrubber Capacity. 2" inlet & 2" outlet. Scrubber Height 2.5 m. Discharge Point via an additional 2" vent – height at discharge is 4.5 m
H ₂ S Scrubber 2	ABP / MBT Displaced Air Scrubber	Treats the displaced air from the ABP / MBT holding tanks, the maximum pump rate is 20 m ³ /hour into one or both of the tanks.	2m ³ Scrubber Capacity. 2" inlet & 2" outlet. Scrubber Height 2.5 m. Discharge Point via an additional 2" vent – height at discharge is 4.5 m
H ₂ S Scrubber 3	DAF (1) Break Tank	Treats the displaced air from the DAF 1 break tank, which has a maximum pump rate of 20m ³ /hour into one or both tanks.	2m ³ Scrubber Capacity. 2" inlet & 2" outlet. Scrubber Height 2.5 m. Discharge Point via an additional 2" vent – height at discharge is 4.5 m
H ₂ S Scrubber 4	RT 1 & R1	Treats the displaced air from RT1 & R1.	2m ³ Scrubber Capacity. 2" inlet & 2" outlet. Scrubber Height 2.5 m. Discharge Point via an additional 2" vent – height at discharge is 4.5 m
H ₂ S Scrubber 5	Feedstock Tanks, White, Gold & Grey	The displaced air will be treated via a carbon scrubber. The displaced air is pulled via the extraction blower to the odour control unit.	2m ³ Scrubber Capacity. 2" inlet & 2" outlet. Scrubber Height 2.5 m. Discharge Point via an additional 2" vent – height at discharge is 4.5 m
H ₂ S Scrubber 6 & 7	Complex waste & warehouse	Treated via carbon scrubber and odour treatment system	2m ³ Scrubber Capacity. 2" inlet & 2" outlet. Scrubber Height 2.5 m. Discharge Point via an additional 2" vent – height at discharge is 4.5 m

The below shows the carbon scrubber locations on site as well as the centralised odour abatement system and how the processes connect on site.



Assessment of Energy Usage / Efficiency

Please see below break-down of energy usage and efficiency onsite.

The power requirement on site will be supplied by the power produce from our CHP unit. The source of the biogas used is produced by the processing of the waste streams. Optimising the removal rates will maximise the yield of the gas produced. Process optimisation of the temperature, pH, retention times and mixing will provide the maximum gas yield at a targeted CH₄ % of 70% methane.

Waste4Generation Ltd will look to invest in the most efficient pumps and mixers. These are the main uses of power on site for mixing and transfer purposes. These procedures have already been optimised to achieved process requirements as efficiently as possible. However, where efficiency savings are identified they will be implemented.

Waste4Generation Ltd have identified energy efficiency in reducing heat loss throughout the process and will invest in insulation measures where losses are identified. The heat for the process will also be provided by the CHP unit on site.

Pumping Stations

The on-site pumping station functions include:

- Return spillages and wash down water to RT2 for reprocessing (PS1)
- Discharge excessive rainwater to drain (PS1)
- Final effluent cleaning and sludges returned to RT2 for reprocessing (PS1)
- Pumping screened influent to DAF1 for processing (PS2)
- Pumping processed FOG & Complex waste for processing (PS2)

Pumping Stations								
Equipment	Process	Power Rating	Model Code	Location	Hours Run	Daily kWh	Targeted Efficiency	Specification
PS 1 Pump 1	Onsite pumping station pump return to RT2	0.75	JS-650-230V	Pumping station 1	4	3	1.5	Improvement in acceptance procedures to reduce spillages 20m ³ /h pump capacity.
PS 1 Pump 2	Onsite pumping station pump return to RT2	0.75	JS-650-230V	Pumping station 1	4	3	1.5	Improvement in acceptance procedures to reduce spillages 20m ³ /h pump capacity.
PS2 Pump 1	Drum screen & compactor treated effluent reception pumping station to DAF 1.	0.75	JS-650-230V	Pumping station 2	4	3	1.5	Improvement in acceptance procedures to reduce spillages 20m ³ /h pump capacity.
PS2 Pump 2	Drum screen & compactor treated effluent reception pumping station to DAF 1.	0.75	JS-650-230V	Pumping station 2	4	3	1.5	Improvement in acceptance procedures to reduce spillages 20m ³ /h pump capacity.

Heating Process

The onsite CHP will provide the process heat requirement for site. The anaerobic digestion process requires an operating temperature of between 36-40°C. The engine heats the process water via the engine's heat exchanger to 80-90°C and held in the 80°C hot water tank. The 80°C tank heats the 50°C tank, with the heated process water heating the influent waste stream via a heat exchanger to 36-40°C. The reason to only heat with 50°C process water is to protect the biology of the reactors. The liquid digestate passes through a recovery heat exchanger to pre-heat the influent waste stream from approximately 5-15°C to 20-30°C, this optimises heat recovery of the system utilising free available heat.

Process Efficiency - Heating Process							
Equipment	Process	Power Rating	Model Code	Location	Hours Run Daily	Daily kWh	Comments
CHP HW pump	Hot Water System	4		Inside CHP	24	96	CHP daily electrical production (150kWh engine) 3,600 kW.
Boiler HW Water Pump	Hot Water	4	N/A	Behind Main		0	
50°C water pump	Hot Water System	4	N/A	Behind Main Break Tank	24	96	
Boiler Water Circulation pump	Hot Water System	1.1	N/A	On top of boiler		0	N/A

Reception Screening

The drum and compactor screen protects the process and help achieve our final effluent consent by removing potential coarse solids from waste streams. The recovered solids comprise a predominant organic fraction that can be added to the feedstock blend, to increase the % dry matter of the blend. This has a substantial impact on the quality of the product whilst also reducing the transportation of non-digestible material (water) to an AD facility, which has no gas production potential which will then subsequently need to be removed from the facility.

Process Efficiency - Reception Screening						
Equipment	Process	Power Rating (kWh)	Model Code	Location	Hours Run daily	Daily kWh
Drum Screen Motor	Drum Screen	0.55	N/A	Drum Screen	2	1.1
Compactor Screen motor	Compactor Screen	0.75	N/A	Compactor Screen	2	1.5
Compactor Screen Screw	Compactor Screen	5.5	N/A	Compactor Screen	2	11
RT1 Pump	Transferring from RT1 to compactor screen / to top end processes	7.5	RMGB621RC D1L	Outside left-hand side of RT1 bund	2	15

Feedstock Process

The feedstock process allows Waste4Generation to make an optimum feedstock blend for the AD process of a partner AD plant. This is done by separating the organic and liquid fractions to achieve the ideal %DM for processing whilst suitable to be loaded on and off the tanker. The composition of the blend ensures that there are no inhibitory components (for instance high concentrations of sulphates, chlorides etc), whilst looking to achieve the ideal CNP ratio. Waste4Generation then add any nutrients and trace metals that has been identified as deficient at the receiving site. High quality products can be added where required to achieve the targeted COD requirement for the blend. Mixing is key to ensure a homogenous load.

Process Efficiency - Feedstock Process							
Equipment	Process	Power Rating	Model Code	Location	Hours run daily	Daily kWh	Targeted efficiency
White tank mixer	Feedstock homogenisation	15			6	90	45
Feedstock Pump	Feedstock mixing/transfer pump	7.5	RMGB64 1R2CD1D	Front righthand side of main bund	6	45	22.5

Final Effluent

The final effluent pumps transfer the analysed treated effluent to the sewer at a controlled rate within our discharge volume parameters. Both the flow rate and the volumes are recorded via the SCADA system.

Process Efficiency - Final Effluent								
Equipment	Process	Power Rating (kWh)	Model Code	Location	Hours run daily	Daily kWh usage	Targeted Efficiency Savings	Specification
Final Effluent Pump	Final Effluent System	2.2	RLCB571 R2CD1D	Next to final polishing tank	6	13.2	6	Adjust process to use the tanks overflow under gravity to discharge to sewer.
Polishing Pump	Pumping material from large DAF to polishing tanks	2.2	RDCA551 R2CD1L	Bund pumping station far right pump	6	13.2	6	Adjust process to use the tanks overflow under gravity to discharge to polishing tanks.

RT2 Reception

The RT2 reception and DAF (1) store the incoming waste. Additional feedstock additions may be produced through settlement within the RT2 tank itself which is regularly emptied to allow the settled sludge to be removed. The DAF removes the finer solids and fats, oils & greases from the waste which is also used to supplement our feedstocks. The treated waste influents are then processed via the AD facility.

Process Efficiency - RT2 Reception Process								
Equipment	Process	Power Rating	Model Code	Location	Hours Run Daily	Daily kWh	Targeted Efficiency	Specification
RT2 DAF 1 pump	Transferring from RT2 to small DAF	4	RLCR591R2CD1L	Inside bund behind RT2	4	16		
DAF 1 scraper motor	DAF Sludge removal	0.12	SK1S163/31dh-iec63-63s/4-Nord-230/400v	Top of DAF unit	4	0.48		
DAF 1 White water pump	White water production	5.5	Edur LBU404C120L		4	22		17m ³ /hr Liquid at 6 bar @ 1.73/hr airflow rate
DAF 1 transfer pump	Transferring material from small DAF break tank to ABP/MBT or polishing tanks	4	RLCB591R2CD1N	Inside of bund located on the front far left	4	16		20m ³ /hr
Drum screen motor	Solid removal	0.5			4	2	1.6	Change in feedstock
Drum screen break tank pump	Pumping forwards from drum screen break tank to reactors	4	RLCR591R2CD1L	Bund pumping station, first pump from the left	4	16	12.8	Change in feedstock 20m ³ /hr pump capacity

AD Process

The AD process converts the COD within the waste streams into biogas which is used as a fuel for the onsite combined heat and power (CHP) unit to produce both the heat and power requirements for the facility. Any additional power is exported to the grid to supplement the UK national grid's renewable generation targets. The liquid digestate (effluent) produced is then pumped to the waste treatment facility for final process prior to discharge via our consented discharge. This remove the requirement of the digestate to be tankered off of site, reducing the site's carbon footprint.

Process Efficiency - AD Process								
Equipment	Process	Power Rating	Model Code	Location	Hours run daily	Daily kWh	Targeted efficiency	Specification
Reactor feed pump	Feed pump from MBT to reactors/drum screen	3	RMCB581R2CD1D	Middle pump in bund pumping station	6	18		20m3/hr
R3 recirculation pump	R3 recirculation pump	4	RLCB591R2CD1L	Next to R3	4	16	16	Stop use when AD fully optimised 20m3/hr pump capacity
Recirculation pump	Recirculation from main break tank to reactors/drum screen	5.5	RLCB591RCD1D	Second from the left in the bund pumping station	26	143	35.75	Change to a more efficient pump 20m3/hr pump capacity

Wastewater Treatment Process

This process treats the liquid effluent via nano bubble & flash aeration, to remove any residual COD to achieve FE discharge consented limits. The DAF (2) unit removes any carried over biomass and solids from the AD process to achieve the suspended solids discharge limit (<1000 mg/L). The effluent is also chemically treated for odour control and trace metal removal.

Process Efficiency - Wastewater Treatment Process								
Equipment	Process	Power Rating	Model Code	Location	Hours Run Daily	Daily kWh	Targeted Efficiency Savings	Specification
R1 feed pump	Feed pump to R1 from main break tank	4	RMCS581R7CF1D	Forth pump from the left in the bund pumping station	6	24	12	Pump efficiency 10m3 pump capacity.
FE DAF 2 White water pump.	Final effluent processing	4		Behind R6	6	24		
FE DAF 2 paddle motor	Final effluent processing	0.5		On top of the DAF	6	3		



Warehouse Storage

Storage in the warehouse allows the following:

- Segregation of waste streams.
- Accept waste streams in emergency from one of our clients (additional storage capacity).
- Reserve products, waste and feedstock due to supply and demand issues.
- Additional storage capacity due to unforeseen, process issues, extreme weather or haulage issues.
- Ability to service our clients within their permit's conditions.

Process Efficiency - Warehouse Storage			
Equipment	Power Rating	Hours run daily	Daily kWh usage
Feedstock storage tank	4.5	4	18
Mixer			
Product storage tank	4.5	4	18
Mixer			
Waste storage tank	4.5	4	18
Mixer			

Still 5 Treatment Process

This dedicated process directly diverts a waste stream that is currently disposed of to landfill and generating renewable electricity from it.

Process Efficiency - Still 5 Treatment Process			
Equipment	Power Rating (kWh)	Hours Run Daily	Daily kWh usage
HW pump	2	24	48
Mixer 1	3	4	12
Mixer 2	3	4	12
Mixer 3	3	4	12



Total Energy Usage & Efficiency Reduction

To achieve our efficiency targets, Waste4Generation will continue to improve our standard operating procedures. In addition, look to replace pumps and mixers with the most efficient alternative.

Additionally, by ensuring that the equipment is maintained and serviced to run allows the equipment to operate at its most efficient. There are planned upgrades to the insulation on the heating & pipework systems to minimise heat loss.

Continual training of the staff and up-skilling of operators, whilst reinforcing the importance of optimisation of the process and energy usage.

The above processes will be in place and optimised within 6 months of the upgrade works being completed, with a review after implementation of upgrades as well as annually following.

		Targeted Efficiency Savings
Total kWh capacity	143	141
Total kWh daily usage	963	822
Daily kW production	3600	3600
Parasitic Load %	27%	23%

Monitoring Frequencies

As per BAT 8 & BAT 34, the following monitoring will occur onsite regarding Odour:

<i>Monitoring Frequencies – BAT 8 & BAT 34</i>	
H ₂ S – Odour Abatement Plant Stack (BAT 8)	Six Monthly (as per BAT 34)
NH ₃ – Odour Abatement Plant Stack (BAT 8)	Six Monthly (as per BAT 34)
Odour Concentration	Odour monitoring carried out every six months (as per BAT 34)

As per BAT 38, the following monitoring is undertaken on site regarding Process:

<i>Monitoring Frequencies – BAT 38</i>



Gas Pressure, Gas Production, Gas Volume, Gas Quality & Temperature	Continuous Monitoring (recorded on SCADA)
Odour at site boundary, Gas readings, & visual checks on appearance of digesters	Daily Process Monitoring
FOS/TAC on digesters	Weekly
pH, COD, dry matter on digesters	Daily
Feedstock dry matter	Daily with buffer tank tested daily as well as all loads out.
pH, FOS/TAC/ Dry matter/ Volatile Acid Speciation / Trace Elements / BOD/ COD/ Salinity of Digesters	Monthly

As per Schedule 3 the following emissions are monitored:

Table S3:1 Point Source Emissions to Air	
A1 (CHP Engine)	Oxides of Nitrogen, Sulphur Dioxide, Carbon Monoxide & Total VOCs monitored annually
A2 (Emergency Flare)	Oxides of Nitrogen, Carbon Monoxide & Total VOCs – Monitoring taken after 10%-year operation.
A3 (Auxiliary Boiler)	No parameter set
Pressure Relief Valves	No parameter set – Record of Operating Hours
Vents from Tanks	No parameter set
Methane Scrubber	No parameter set

Raw Materials Inventory & Annual Throughput

The below form is utilised to determine annual usage and capacities. In 2022, the AD plant and processes were being re-commissioned and therefore the usage was not realistic of usage for the plant in full operation and usage forwards at capacity. (Please find attached inventory for 2022). The information gathered below will be evaluated annually and tracked to determine if proposed



reductions have occurred. Company management to review and determine potential reductions for the following year.

Energy Consumption by Source	Delivered Energy	Energy Exported	Energy Flow Information
Electricity	Electric supplied 2022/3	~	~
Gas	N/A	N/A	N/A
Conventional Liquid Fuels	Heating Fuel		Stop after upgrades completed
Solid Fuels	N/A	N/A	N/A
Waste	Quarterly/annual waste returns	~	~

Raw Materials Usage & Efficiency Techniques

Some of the processes such as heating will require the pumps to be operating continuously initially. However, efficiency savings can be made via insulation to prevent heat losses. After this, additional optimisation may be possible to reduce the energy consumption by placing the heat pumping system on an on/off basis.

Correct blending and allocation of waste within the system will allow us to reduce the mixing requirements on site reducing energy consumption.

Energy Usage Reduction Plan (KPI)					
No.	Activity	Energy Consumption in mWh/annum	kWh/Tonne waste processed	Target Reduction %	Annual Improvement
1	Process heating	64			0.0
2	Waste reception screening	29			0.0
3	Feedstock process	351	54,750	50	175.5
4	AD process	13	15,600	25	3.3
5	Final effluent process	20			0.0
6	FOG & Complex waste process	34	7,800		0.0
7	Onsite Pumping stations	4		50	2.0
8	Still 5 Process	21	540	25	5.3
9	Tank farm storage	14		50	7.0
	<i>Total</i>	<i>550</i>	<i>78690</i>	<i>35</i>	<i>193.0</i>

Raw Material Storage Arrangements

Wastes, products, feedstock & fuels each have their own acceptance and composition procedures and specifications as well as their own dedicated storage tanks. The tank levels are monitored by the SCADA system.



Digestate Storage & Capacity

N/A – no digestate storage on site – liquid digestate from the digesters is discharged to sewers via trade effluent consent.

List of Proposed EWC Codes & Justification

As part of this permit variation/application, Waste4Generation are applying for the addition of 4 additional EWC codes to our permit.

<i>EWC Codes to be Added to Permit</i>	
19 07 03	19 12 12
16 01 15	16 03 06

Please see attached document for justification of EWC codes detailing the suitability of these waste codes for treatment & processing at Waste4Generation's Corby facility.

Description of Proposed Waste Handling

Liquid wastes are accepted via tanker and unloaded with our own hoses. Hoses are fit for purpose & inspected prior to use. The waste is accepted into an enclosed tank the material is then transferred or processed via our enclosed pumping system. The feedstock is removed from its designated storage tank via our hose and pumped onto the tanker for delivery to the designated facility. The processed liquid digestate effluent is discharged via an enclosed system to the drain.

Solid wastes are accepted and stored in the solids bay. Then transferred via telehandler and bucket for processing by macerator and pump to an enclosed feedstock processing tank.

Review of Waste Minimisation

We do not produce any waste from site, all screened waste or settled sludges are used within our feedstock. We can achieve this due to the restrictions on the types of waste received, which is all organic and free of contaminants.