


PRELIMINARY
SUBJECT TO DETAIL DESIGN
CONFIRMATION



© 2021 RPS Group
Notes
1. This drawing has been prepared in accordance with the scope of RPS's appointment with its client and is subject to the terms and conditions of that appointment. RPS accepts no liability for any use of this document other than by its client and only for the purposes for which it was prepared and provided.
2. If received electronically it is the recipient's responsibility to print to correct scale. Only written dimensions should be used.

- NOTES**
- GENERAL**
 - All units in t/h.
 - Ambient Design Conditions: 15 C, 60% RH, 1013 mbar, Plant at: 100% Load
 - Normal flow consumptions are prorated to 24h if not continuous.
 - The balance is calculated for 1 x boiler & 1 x Steam Turbine configuration
 - Black numbers show normal flows. Blue italic numbers indicate upset / startup conditions which are not coincident. All figures are preliminary.
 - TOWN / FIRE FIGHTING WATER**
 - Town water is supplied at the relevant Terminal Point
 - A fire fighting dedicated water tank will be provided
 - Fire protection water is consumed in case of fire.
 - Fire fighting water is supplied through town water Terminal Point
 - Fire water demand figure is preliminary
 - Used fire fighting water flows shall be collected to the oily drains basin.
 - BOILER START UP & DEMINERALIZED WATER CONSUMPTION**
 - Boiler starting requires about 6.3 h
 - Total demineralized water consumption during boiler start up around 155 t
 - DEMINERALIZED WATER**
 - Demi Water Plant overall efficiency is considered equal to 75%.
 - Demi Water Treatment plant is featured as two (2x100%) trains with CB & AB & MB with a nominal production capacity of 2.5 t/h
 - Two (2) demi water storage tanks with capacity of 100 m³ each, are included.
 - SANITARY / POTABLE / DOMESTIC WATER**
 - Sanitary water consumption has been considered for 120 people with a normal allowance of 150l / person / day.
 - Potable water for human consumption will be supplied by bottles.
 - MISCELLANEOUS CONSUMPTIONS**
 - Demineralized water consumption to: Chemicals dilution, Aux Cooling Make up, Air Cooled Condenser washing, Fin Fan Cooler washing, etc.
 - Boiler Blowdowns are cooled to 85 C with quenching water and further with Aux Cooling Water System of the plant
 - EFFLUENTS**
 - It is assumed that 100% of service water goes to oily drain network.
 - Effluents downstream neutralization basin will be sent to Flue Gas Desulfurization Treatment (FGT) and Boilers Bottom Ash Handling process
 - During boiler start up a higher blowdown flow than steady state operation is expected with maximum instantaneous rate of 60,9 t/h. A portion of this flow is lost in the atmosphere as high pressure / high temperature flashing water and the rest is cooled down initially to 85 and further to 35 C and routed to the clean water basin and from there is consumed to various consumers.

LEGEND

- RAW & FIRE FIGHTING WATER
- DEMI & CONDENSATE WATER
- INDUSTRIAL EFFLUENTS
- EFFLUENTS WITH OIL & SLUDGE
- SEWAGES
- NEUTRALIZED WASTE WATER

Design Basis Conditions: Boiler at 100% load with ambient temperatures of 15C

Rev	Description	By	CB	Date

RPS MAKING COMPLEX EASY

20 Western Avenue, Milton Park, Abingdon, Oxfordshire, OX14 4SH
T: +44(0)1235 821 888 E: rps@rpsgroup.com

Client -
Project Corby Energy from Waste Facility
Title Water Balance Diagram

Status FINAL Drawn By JM PM/Checked By TH
Project Number JER9793 Scale @ A3 Date Created DEC 2022

Figure Number - Rev -
rpsgroup.com