



**NOTES**

1. FOR DRAINAGE SCHEDULES SEE DRAWING 82598-DRAIN-EX-103.
2. FOR DRAINAGE STANDARD DETAILS SEE DRAWING 82598-DRAIN-EX-104, 82598-DRAIN-EX-105 AND 82598-DRAIN-EX-106.
3. SURFACE WATER DRAINAGE IS BASED ON AN EQUIVALENT SYPHON WITH AN EQUAL MAXIMUM FLOW RATE.
4. FINISHED LEVELS ARE AS PAPA DRAWINGS 82598-ARCH-EX-100 & 101.
5. PIPES UP TO AND INCLUDING 300mm ARE VITRIFIED CLAY. PIPES WITH A DIAMETER GREATER THAN 300mm ARE CONCRETE.

THIS DRAWING HAS BEEN UPDATED TO 'AS-BUILT' STATUS FROM 'CONSTRUCTION STATUS' AND HAS INCLUDED ANY INFORMATION WHICH HAS BEEN PROVIDED BY THE CONTRACTOR TO SUIT MINOR VARIATIONS ON DESIGN CHANGES DURING CONSTRUCTION. THIS HAS BEEN DONE TO THE BEST OF OUR KNOWLEDGE AND MAY NOT REFLECT FULLY ANY CHANGES OR VARIATIONS WHICH HAVE NOT BEEN NOTIFIED TO THE ENGINEER BY THE CONTRACTOR.

**AS BUILT**

KEY	
	SURFACE WATER DRAINAGE
	FOUL WATER DRAINAGE
	FOUL WATER DRAINAGE REUSED
	SLOT DRAIN
	EXISTING SURFACE WATER DRAINAGE REUSED
	FOUR WATER DRAINAGE REUSED
	FLOOR GULLY
	YARD GULLY
	DRAINAGE BY OTHERS
	VENT PIPE FROM PUMPING STATION
	SOIL VENT PIPE
	RAINWATER PIPE
	ROAD GULLY
	LINEAR DRAINAGE CHANNEL
	PACKAGE PUMPING STATION
	HDPE RISING MAIN
	SURFACE WATER DRAINAGE CONSTRUCTED AT A LATER STAGE

Rev	Description	Rev By	M	E	P	F	Issue Date

Status of Drawing				
<b>AS BUILT</b>				
Engineer	Drawn	Date	Checked	Date
MS	LW	10.03.11	TEB	10.03.11

Contract Name	
<b>TELECITY POWERGATE 2</b>	
Drawing Title	
<b>DRAINAGE LAYOUT</b>	

This document has been prepared in accordance with the scope of Scott Wilson's appointment with its client and is subject to the terms of that appointment. Scott Wilson accepts no liability for any use of this document other than by its client and only for the purposes for which it was prepared and provided. City written dimensions shall be used. © URS Scott Wilson Ltd 2011

**URS Scott Wilson Ltd**  
 Royal Court  
 Basil Close, Chesterfield  
 Derbyshire, S41 7SL  
 Telephone (01246) 209221  
 Fax (01246) 209229  
 www.urs-scottwilson.com



**SPiE Matthew Hall**

7-14 Great Dover Street London SE1 4YR  
 tel +44 (0)20 7089 7350 fax +44 (0)20 7089 7351 www.spieatthewhall.com

Drawing No. **82598-DRAIN-EX-101**

Rev. **1.500**  
 Scale  
 Cad Ref: