

# UK BUSINESS - RISK PROFILE SEPT 2020

- The gas recovered upon completion of Phase 1 of the UK F-gas project, including the Barton retrofit, provides sufficient stock to reach 2025 based upon the previous 12 months reported leakages.
- All the remaining high GWP F-gas systems with the exception of the spirals at Spalding and Cumberland can be retrofitted with lower GWP F-gas.
- The risk profile has been prioritised to reflect serviceability and volumetric risk.

Salads	Spalding - F1
Meals	Wigan
Pizza/Bread	Nantwich



**Amber 1:**  
Failed systems and systems at imminent risk of failure.  
Supported by banked stock or retrofit

Meals	Sutton Bridge (Part 2)
Salads	Bo'ness (Carriden)
Meals	London



**Amber 2:**  
Dilapidated systems.  
Supported by banked gas stock or retrofit

Desserts	Newark
Pizza/Bread	Harrow
Meals	Spalding - Soups & Sauces



**Amber 3:**  
Serviceable systems with large volumes of high GWP gas.  
Supported by banked gas stock or retrofit (excepting spirals)

Salads	Bourne
Pizza/Bread	Crewe
Desserts	Devizes
Meals	SDC
Pizza/Bread	Holbeach
Desserts	Highbridge
Desserts	Leicester
Salads	Bo'ness (Bridgeness)
Salads	Sutton Bridge
Meals	Boston



**Amber 4:**  
Serviceable systems with low volumes of high GWP gas.  
Supported by banked gas stock or retrofit

Meals	Spalding (Cerberus)
Pizza/Bread	Barton
Salads	Tilmanstone
Salads	Spalding - Deli



No intervention necessary and/or 2030 compliant low GWP gas