




### Report for the Periodic Monitoring of Emissions to Air

#### Part 1: Executive Summary

Permit Number:	EPR/BN6137IK/V004
Operator:	Saputo Dairy UK
Installation:	Boiler 3

Test Report:	ALL108654/24/PR-1
Monitoring Dates:	22/10/2024
Client / Organisation:	Mr Stuart Carhart
Address:	Veolia
	Davidstow Creamery
	Davidstow
	Cornwall
Date of Report:	28/10/2024
Report Approved By:	Phillip Ruck <i>BSc</i>
MCERTS Number/Level/Technical Endorsement	MM 11 1117 Level 2, TE1, TE2, TE3, TE4
Designation:	Stack Emissions Co-ordinator
Signed:	 Phillip Ruck
Reviewed:	 Robert Lethbridge

## Contents

### Part 1 Executive summary

<b>Page number</b>	<b>Description</b>
1	Executive Summary
2 - 3	Contents
4	Monitoring objectives
5 – 8	Monitoring results
9	Process status
10	Operating information
11	Monitoring deviations

## Part 2 – Supporting information

Page number	Description
N/A	Appendix 1
N/A	Sampling personnel
N/A	Method specification
N/A	Equipment Checklist
N/A	Appendix 2
N/A	Boiler 3 stack details including gas measurements (29 pages)
N/A	Appendix 3 (Uncertainty)
N/A	Appendix 4 (Instrumental analyser details)
N/A	Appendix 5 (Annual calibration details & analysis data retained at permanent laboratory)

### Monitoring objectives

At the request of Mr Stuart Carhart of Veolia, Anchem Laboratories Limited has carried out an “emissions to atmosphere” monitoring regime in the exhaust ductwork of the boiler 3 process stack at Saputo Dairy UK in Davidstow. This monitoring regime has been undertaken for internal process control purposes only.

Emission point	Reference number	Substance to be monitored	Special requirements
Boiler 3	108654/1-4	Oxides of Nitrogen Sulphur dioxide Carbon Monoxide Oxygen	40 Minute Sampling

**Monitoring results**

<b>Emission Point</b>	Boiler 3			
<b>Sample Number</b>	108654/1			
<b>Substance to be Monitored</b>	Sulphur Dioxide	Oxides of Nitrogen	Carbon Monoxide	Oxygen
<b>Emission Limit Value</b>	1000	1000	N/A	N/A
<b>Periodic Monitoring Result</b>	3.1	125.0	8.4	8.1
<b>Uncertainty</b>	±0.8	±2.9	±0.9	±0.2
<b>Units</b>	mg/Nm <sup>3</sup>			
<b>Reference Conditions</b>	273K, 101.3kPa, 3% oxygen & dry gas			
<b>Date of Sampling</b>	22/10/2024			
<b>Start/End Time</b>	11:10 – 11:52			
<b>Average Volumetric flow @ reference conditions / m<sup>3</sup>/hr</b>	1026			
<b>Standard Reference Method</b>	CEN/TS 17021	BS EN 14792	BS EN 15058	BS EN 14791
<b>Technical Procedure Reference</b>	ANC/S/29			ANC/S/26
<b>Accreditation Status</b>	MCERTS			
<b>Process Status (Load/Feedstock)</b>	See Process Status (page 9)			

**Monitoring results continued**

<b>Emission Point</b>	Boiler 3			
<b>Sample Number</b>	108654/2			
<b>Substance to be Monitored</b>	Sulphur Dioxide	Oxides of Nitrogen	Carbon Monoxide	Oxygen
<b>Emission Limit Value</b>	1000	1000	N/A	N/A
<b>Periodic Monitoring Result</b>	12.1	141	3.3	6.8
<b>Uncertainty</b>	±1.0	±3.0	±0.8	±0.2
<b>Units</b>	mg/Nm <sup>3</sup>			
<b>Reference Conditions</b>	273K, 101.3kPa, 3% oxygen & dry gas			
<b>Date of Sampling</b>	22/10/2024			
<b>Start/End Time</b>	12:02 – 12:44			
<b>Average Volumetric flow @ reference conditions / m<sup>3</sup>/hr</b>	1324			
<b>Standard Reference Method</b>	CEN/TS 17021	BS EN 14792	BS EN 15058	BS EN 14791
<b>Technical Procedure Reference</b>	ANC/S/29			ANC/S/26
<b>Accreditation Status</b>	MCERTS			
<b>Process Status (Load/Feedstock)</b>	See Process Status (page 9)			

**Monitoring results continued**

<b>Emission Point</b>	Boiler 3			
<b>Sample Number</b>	108654/3			
<b>Substance to be Monitored</b>	Sulphur Dioxide	Oxides of Nitrogen	Carbon Monoxide	Oxygen
<b>Emission Limit Value</b>	1000	1000	N/A	N/A
<b>Periodic Monitoring Result</b>	12.8	157.8	2.8	5.6
<b>Uncertainty</b>	±1.0	±3.1	±0.7	±0.2
<b>Units</b>	mg/Nm <sup>3</sup>			
<b>Reference Conditions</b>	273K, 101.3kPa, 3% oxygen & dry gas			
<b>Date of Sampling</b>	22/10/2024			
<b>Start/End Time</b>	12:55 – 13:37			
<b>Average Volumetric flow @ reference conditions / m<sup>3</sup>/hr</b>	1737			
<b>Standard Reference Method</b>	CEN/TS 17021	BS EN 14792	BS EN 15058	BS EN 14791
<b>Technical Procedure Reference</b>	ANC/S/29			ANC/S/26
<b>Accreditation Status</b>	MCERTS			
<b>Process Status (Load/Feedstock)</b>	See Process Status (page 9)			

**Monitoring results continued**

<b>Emission Point</b>	Boiler 3			
<b>Sample Number</b>	108654/4			
<b>Substance to be Monitored</b>	Sulphur Dioxide	Oxides of Nitrogen	Carbon Monoxide	Oxygen
<b>Emission Limit Value</b>	1000	1000	N/A	N/A
<b>Periodic Monitoring Result</b>	12.7	159.5	3.3	3.9
<b>Uncertainty</b>	±0.9	±2.8	±0.6	±0.1
<b>Units</b>	mg/Nm <sup>3</sup>			
<b>Reference Conditions</b>	273K, 101.3kPa, 3% oxygen & dry gas			
<b>Date of Sampling</b>	22/10/2024			
<b>Start/End Time</b>	13:40 – 14:20			
<b>Average Volumetric flow @ reference conditions / m<sup>3</sup>/hr</b>	2309			
<b>Standard Reference Method</b>	CEN/TS 17021	BS EN 14792	BS EN 15058	BS EN 14791
<b>Technical Procedure Reference</b>	ANC/S/29			ANC/S/26
<b>Accreditation Status</b>	MCERTS			
<b>Process Status (Load/Feedstock)</b>	See Process Status (page 9)			

## Process status

With regards to the monitoring carried out on the Boiler 3 Exhaust, the process ran in a continuous state during sampling with no unusual occurrences reported by the operators.

108654/1 – 25% Process Load

108654/2 – 50% Process Load

108654/3 – 75% Process Load

108654/4 – 100% Process Load

## Operating information

<b>Nature of process (continuous or batch)</b>	Continuous in nature
<b>What part of the batch was sampled or whole batch (if applicable)</b>	N/A
<b>What fuel was used (if applicable)</b>	N/A
<b>What feedstock was used during the monitoring (if applicable)</b>	Boiler 1 utilises Kerosene as fuel
<b>“Normal” load, throughput or continuous rating of plant</b>	Continuous
<b>What type of abatement system and whether operating</b>	N/A
<b>The periodic monitoring result and the results from the operators CEMS</b>	There are no CEMs fitted for the purpose of monitoring emissions to air.

**Monitoring Deviations:**

**Why any substance(s) in the monitoring objectives were not monitored.**

N/A

**Why any substance(s) were not monitored in accordance with the monitoring method and any other issues relevant to the monitoring results.**

Velocity recorded during Run 1 was less 5Pa as required by the method.

**Part 2: Supporting information**

# APPENDIX 1

**Sampling personnel**

Name	Function*	MCERTS number	MCERTS level	Technical endorsements
P Ruck	Team Leader	MM 11 1117	Level 2	TE1, TE2, TE3, TE4
L Liguz	Emissions Analyst	MM 24 1851	Trainee	-

**Method specifications**

Substance	Standard reference method	Anchem technical procedure
Velocity	ISO 16911	ANC/S/36
Oxides of nitrogen	BS EN 14792	ANC/S/29
Carbon Monoxide	BS EN 15058	ANC/S/29
Sulphur dioxide	CEN/TS 17021	ANC/S/29
Oxygen	BS EN 14789	ANC/S/26
Moisture	BS EN 14790	ANC/S/11

### Equipment checklist

Please see relevant appendices and site-specific protocol associated with monitoring campaign for equipment utilised during monitoring & checklist.

# APPENDIX 2

**Boiler 3**

**(29 Pages)**

**Stack diagram**


<b>Stack Dimension (m)</b>	0.63m
<b>Homogeneity test previously carried out (yes/no)</b>	No
<b>Is the gas stream homogeneous? (yes/no/unknown)</b>	Unknown

### Combustion Gas Monitoring Summary

Sample Number	108654/1
Date	22/10/2024
Customer name	Saputo Dairy
Site location	Davidstow
Emission point	Boiler 3
Emission point dimension (m)	0.62m
Emission point C.S.A. (m <sup>2</sup> )	0.3019
Team leader	Phil Ruck
Analyst(s)	Louie Liguz
Average Ambient pressure (mb)	994
Average Ambient temperature (°C)	13
Instrument number	A/S545 (PG-350)
Probe length (m)	1.0m
Timer	A/S685
Homogeneity test previously conducted? (Yes/No)	No
Is the gas stream homogeneous? (Yes/No/Unknown)	Unknown
Test start time	11:10:00
Test end time	11:52:00
Volumetric flow @ reference conditions (m <sup>3</sup> /hour)	1040

### Reference conditions

Temperature (K)	273
Pressure (kPa)	101.3
Moisture	Dry
Oxygen (%)	3

**Carbon Monoxide**

Average concentration CO (mg/m <sup>3</sup> )	8.4
Maximum concentration CO (mg/m <sup>3</sup> )	10.4
Minimum concentration CO (mg/m <sup>3</sup> )	7.2
Mass Emission CO (Kg/hour)	0.01
% Uncertainty of measurement	10.6
Uncertainty Concentration mg/m <sup>3</sup>	0.9

**Oxides of Nitrogen (as NO<sub>2</sub>)**

Average concentration NOx (mg/m <sup>3</sup> )	125.0
Maximum concentration NOx (mg/m <sup>3</sup> )	126.5
Minimum concentration NOx (mg/m <sup>3</sup> )	123.6
Mass Emission NOx (Kg/hour)	0.13
% Uncertainty of measurement	2.3
Uncertainty Concentration mg/m <sup>3</sup>	2.9

**Sulphur Dioxide**

Average concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	3.1
Maximum concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	23.0
Minimum concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	0.0
Mass Emission SO <sub>2</sub> (Kg/hour)	0.00
% Uncertainty of measurement	24.7
Uncertainty Concentration mg/m <sup>3</sup>	0.8

**Oxygen**

Average concentration O <sub>2</sub> (% vol)	8.1
Maximum concentration O <sub>2</sub> (% vol)	8.2
Minimum concentration O <sub>2</sub> (% Vol)	7.9
% Uncertainty of measurement	3.0
Uncertainty Concentration % vol	0.2

Customer	Saputo Dairy		
Emission Point	Boiler 3		
Date	22/10/2024		
Sample No	108654/1		

Pre test				
ANALYTE	CO	NO	SO <sub>2</sub>	O <sub>2</sub>
Zero through analyser (ppm)	0	0	0	0
Span Through analyser (ppm)	101.2	145.5	144.0	6.1
Zero through analyser (ppm)	0.2	0.0	0.6	-0.01
Zero Through line (ppm)	0.20	0.00	0.20	0.01
Span Through line (ppm)	101.2	145.2	143.1	6.1
Residence Time (seconds)	42.0	45.0	48.0	42.0
System T90 (seconds)	62	62	83	56
T90 Value (ppm)	91.1	131.0	129.6	5.5
Initial leak test	0.0	0.2	0.6	0.0
Post test				
ANALYTE	CO	NO	SO <sub>2</sub>	O <sub>2</sub>
Zero Through Analyser	0.00	0.00	0.10	0.02
Span Through Analyser (ppm)	101.4	144.70	145.20	6.13
Span Drift (%)	0.2	0.3	1.5	0.5
Zero Drift (%)	0.2	0.0	0.1	0.2

Oxygen cylinder grade/reference	VC1978130 6.10%
Nitrogen Monoxide cylinder grade/reference	VC12997 145.5ppm
Sulphur Dioxide cylinder grade/reference	VC12997 144.0ppm
Carbon Monoxide cylinder grade/reference	VC12997 101.2ppm


#### Gas conditioning Temperature Validation

Temperature @ Start of Test (°C)	N/A
Temperature During Test (°C)	N/A
Temperature @ End of Test (°C)	N/A
Temperature of Heated Line (°C)	120
Temperature of PD-100 oven (°C)	100

#### Stratification Data

Point	CO ppm	NO ppm	SO <sub>2</sub> ppm	O <sub>2</sub> % vol
1	4.75	43.40	0.10	7.99
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

Combustion Gas concentrations measured on the Boiler 3, at Saputo Dairy, Davidstow  
 on the 22/10/2024  
 Sample No: 108654/1



Combustion Gas concentrations measured on the Boiler 3, at Saputo Dairy, Davidstow  
 on the 22/10/2024  
 Sample No: 108654/1

Concentration	CO mg/m <sup>3</sup>	30 Minute Rolling Mean	NOx mg/m <sup>3</sup>	30 Minute Rolling Mean	SO2 mg/m <sup>3</sup>	30 Minute Rolling Mean	O <sub>2</sub> %vol
Minimum	7.2	8.3	123.6	124.6	0.0	1.0	7.9
Maximum	10.4	8.4	126.5	125.3	23.0	4.4	8.2
Average	8.4	8.3	125.0	124.9	3.1	2.2	8.1

**EN ISO 16911 S-Type Pitot Summary Page**

Customer	Saputo Dairy UK
Site	Davidstow
Emission Point	Boiler 3
Date Measured	22-Oct-24
Sample Number	108654/1
X-Sectional Area	0.302
DH@	52.56
DY <sub>d</sub>	N/A
Average sqrt DP (mmH <sub>2</sub> O)	0.569
Average % Oxygen	8.1
Average % Carbon Dioxide	9.0
Average % Carbon Monoxide	0.0
Average % Nitrogen	82.9
Barometric Pressure (mb)	994
Duct Static Pressure (mmH <sub>2</sub> O)	-10.00
Absolute Stack Gas Pressure (KPa)	99.3
Average Stack Gas Temperature (K)	435
Moisture % (estimated)	10.00
Velocity in Stack (m/s)	2.4
Volumetric Flow at Stack Conditions (m <sup>3</sup> /sec)	0.71
Volumetric Flow at Stack Conditions (m <sup>3</sup> /hour)	2560.45
Volumetric flow rate STP, Wet (m <sup>3</sup> /sec)	0.44
Volumetric flow rate at STP, Wet (m <sup>3</sup> /hour)	1575.12
Volumetric flow rate STP, Dry (m <sup>3</sup> /sec)	0.39
Volumetric flow rate at STP, Dry (m <sup>3</sup> /hour)	1417.61
Volumetric flow rate at reference conditions (m <sup>3</sup> /sec)	0.28
Volumetric flow rate at reference conditions (m <sup>3</sup> /hour)	1025.87
% Uncertainty of Measurement	5.3

Client	Saputo Dairy UK
Site	Davidstow
Emission Point	Boiler 3
Date	22/10/2024
Sample Number	108654/1
Probe Operator	LL
Console Operator	PR

DGM Inlet (°C)	25
DGM Outlet (°C)	25
Mean Temp (°C)	25
Bar Pressure (mb)	994
Moisture (%)	8.92
Dimension (m)	0.62
Stack C.S.A (m <sup>2</sup> )	0.3019

Gas Flow	Out
Port Nipple (cm)	60
Console No.	A/S694
Pitot No.	A/S849
Tape Measure	A/S544
Timer	A/S685
Barometer No.	A/S543

### Traverse Line 1

### Traverse Line

### Traverse Line 3

### Traverse Line

Field Performance Criteria	OK?		
Pitch $\leq \pm 10^\circ$	N/A	Is Negative Flow Present?	No
Swirl $\leq \pm 15^\circ$	Yes	Minimum Velocity $> 5\text{pa}$	No
Stack Internal Area	Yes	Ratio of gas Velocities $< 3:1$	Yes
Field Repeatability	N/A		
Static Pressure Check	Yes		

## Flow Characteristics Meet Requirements of EN ISO 16911?

Number of Sample Points
4

### Combustion Gas Monitoring Summary

Sample Number	108654/2
Date	22/10/2024
Customer name	Saputo Dairy
Site location	Davidstow
Emission point	Boiler 3
Emission point dimension (m)	0.62m
Emission point C.S.A. (m <sup>2</sup> )	0.3019
Team leader	Phil Ruck
Analyst(s)	Louie Liguz
Average Ambient pressure (mb)	994
Average Ambient temperature (°C)	14
Instrument number	A/S545 (PG-350)
Probe length (m)	1.0m
Timer	A/S685
Homogeneity test previously conducted? (Yes/No)	No
Is the gas stream homogeneous? (Yes/No/Unknown)	Unknown
Test start time	12:02:00
Test end time	12:44:00
Volumetric flow @ reference conditions (m <sup>3</sup> /hour)	1367

### Reference conditions

Temperature (K)	273
Pressure (kPa)	101.3
Moisture	Dry
Oxygen (%)	3

**Carbon Monoxide**

Average concentration CO (mg/m <sup>3</sup> )	3.3
Maximum concentration CO (mg/m <sup>3</sup> )	4.0
Minimum concentration CO (mg/m <sup>3</sup> )	2.7
Mass Emission CO (Kg/hour)	0.00
% Uncertainty of measurement	23.0
Uncertainty Concentration mg/m <sup>3</sup>	0.8

**Oxides of Nitrogen (as NO<sub>2</sub>)**

Average concentration NOx (mg/m <sup>3</sup> )	141.0
Maximum concentration NOx (mg/m <sup>3</sup> )	150.9
Minimum concentration NOx (mg/m <sup>3</sup> )	139.7
Mass Emission NOx (Kg/hour)	0.19
% Uncertainty of measurement	2.1
Uncertainty Concentration mg/m <sup>3</sup>	3.0

**Sulphur Dioxide**

Average concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	12.1
Maximum concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	31.9
Minimum concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	10.0
Mass Emission SO <sub>2</sub> (Kg/hour)	0.02
% Uncertainty of measurement	8.4
Uncertainty Concentration mg/m <sup>3</sup>	1.0

**Oxygen**

Average concentration O <sub>2</sub> (% vol)	6.8
Maximum concentration O <sub>2</sub> (% vol)	6.9
Minimum concentration O <sub>2</sub> (% Vol)	6.7
% Uncertainty of measurement	3.1
Uncertainty Concentration % vol	0.2

Customer	Saputo Dairy		
Emission Point	Boiler 3		
Date	22/10/2024		
Sample No	108654/2		

Pre test				
ANALYTE	CO	NO	SO <sub>2</sub>	O <sub>2</sub>
Zero through analyser (ppm)	0	0	0	0
Span Through analyser (ppm)	101.2	145.5	144.0	6.1
Zero through analyser (ppm)	0.2	0.0	0.6	-0.01
Zero Through line (ppm)	0.20	0.00	0.20	0.01
Span Through line (ppm)	101.2	145.2	143.1	6.1
Residence Time (seconds)	0.0	0.0	0.1	0.0
System T90 (seconds)	101	145	145	6
T90 Value (ppm)	91.1	131.0	129.6	5.5
Initial leak test	0.0	0.2	0.6	0.0
Post test				
ANALYTE	CO	NO	SO <sub>2</sub>	O <sub>2</sub>
Zero Through Analyser	0.00	0.00	0.10	0.02
Span Through Analyser (ppm)	101.4	144.70	145.20	6.13
Span Drift (%)	0.2	0.3	1.5	0.5
Zero Drift (%)	0.2	0.0	0.1	0.2

Oxygen cylinder grade/reference	VC1978130 6.10%
Nitrogen Monoxide cylinder grade/reference	VC12997 145.5ppm
Sulphur Dioxide cylinder grade/reference	VC12997 144.0ppm
Carbon Monoxide cylinder grade/reference	VC12997 101.2ppm


#### Gas conditioning Temperature Validation

Temperature @ Start of Test (°C)	N/A
Temperature During Test (°C)	N/A
Temperature @ End of Test (°C)	N/A
Temperature of Heated Line (°C)	120
Temperature of PD-100 oven (°C)	100

#### Stratification Data

Point	CO ppm	NO ppm	SO <sub>2</sub> ppm	O <sub>2</sub> % vol
1	2.29	53.96	3.15	6.88
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

Combustion Gas concentrations measured on the Boiler 3, at Saputo Dairy, Davidstow  
on the 22/10/2024  
Sample No: 108654/2



Combustion Gas concentrations measured on the Boiler 3, at Saputo Dairy, Davidstow  
 on the 22/10/2024  
 Sample No: 108654/2

Concentration	CO mg/m <sup>3</sup>	30 Minute Rolling Mean	NOx mg/m <sup>3</sup>	30 Minute Rolling Mean	SO2 mg/m <sup>3</sup>	30 Minute Rolling Mean	O <sub>2</sub> %vol
Minimum	2.7	3.2	139.7	140.9	10.0	11.9	6.7
Maximum	4.0	3.4	150.9	141.2	31.9	12.4	6.9
Average	3.3	3.3	141.0	141.0	12.1	12.2	6.8

**EN ISO 16911 S-Type Pitot Summary Page**

Customer	Saputo Dairy UK
Site	Davidstow
Emission Point	Boiler 3
Date Measured	22-Oct-24
Sample Number	108654/2
X-Sectional Area	0.302
DH@	52.56
DY <sub>d</sub>	N/A
Average sqrt DP (mmH <sub>2</sub> O)	0.687
Average % Oxygen	6.8
Average % Carbon Dioxide	9.9
Average % Carbon Monoxide	0.0
Average % Nitrogen	83.3
Barometric Pressure (mb)	994
Duct Static Pressure (mmH <sub>2</sub> O)	-10.00
Absolute Stack Gas Pressure (KPa)	99.3
Average Stack Gas Temperature (K)	454
Moisture % (estimated)	10.00
Velocity in Stack (m/s)	2.9
Volumetric Flow at Stack Conditions (m <sup>3</sup> /sec)	0.88
Volumetric Flow at Stack Conditions (m <sup>3</sup> /hour)	3158.17
Volumetric flow rate STP, Wet (m <sup>3</sup> /sec)	0.52
Volumetric flow rate at STP, Wet (m <sup>3</sup> /hour)	1860.82
Volumetric flow rate STP, Dry (m <sup>3</sup> /sec)	0.47
Volumetric flow rate at STP, Dry (m <sup>3</sup> /hour)	1674.73
Volumetric flow rate at reference conditions (m <sup>3</sup> /sec)	0.37
Volumetric flow rate at reference conditions (m <sup>3</sup> /hour)	1323.75
% Uncertainty of Measurement	5.3

Client	Saputo Dairy UK
Site	Davidstow
Emission Point	Boiler 3
Date	22/10/2024
Sample Number	108654/2
Probe Operator	LL
Console Operator	PR

DGM Inlet (°C)	25
DGM Outlet (°C)	25
Mean Temp (°C)	25
Bar Pressure (mb)	994
Moisture (%)	9.69
Dimension (m)	0.62
Stack C.S.A (m <sup>2</sup> )	0.3019

Gas Flow	Out
Port Nipple (cm)	60
Console No.	A/S694
Pitot No.	A/S849
Tape Measure	A/S544
Timer	A/S685
Barometer No.	A/S543

### Traverse Line 1

### Traverse Line

### Traverse Line 3

### Traverse Line

Field Performance Criteria	OK?		
Pitch $\leq \pm 10^\circ$	N/A	Is Negative Flow Present?	No
Swirl $\leq \pm 15^\circ$	Yes	Minimum Velocity $> 5\text{pa}$	Yes
Stack Internal Area	Yes	Ratio of gas Velocities $< 3:1$	Yes
Field Repeatability	N/A		
Static Pressure Check	Yes		

Flow Characteristics Meet Requirements of EN ISO 16911?	
	Yes

Number of Sample Points
4

## Combustion Gas Monitoring Summary

Sample Number	108654/3
Date	22/10/2024
Customer name	Saputo Dairy
Site location	Davidstow
Emission point	Boiler 3
Emission point dimension (m)	0.62m
Emission point C.S.A. (m <sup>2</sup> )	0.3019
Team leader	Phil Ruck
Analyst(s)	Louie Liguz
Average Ambient pressure (mb)	994
Average Ambient temperature (°C)	14.5
Instrument number	A/S545 (PG-350)
Probe length (m)	1.0m
Timer	A/S685
Homogeneity test previously conducted? (Yes/No)	No
Is the gas stream homogeneous? (Yes/No/Unknown)	Unknown
Test start time	12:55:00
Test end time	13:37:00
Volumetric flow @ reference conditions (m <sup>3</sup> /hour)	1806

## Reference conditions

Temperature (K)	273
Pressure (kPa)	101.3
Moisture	Dry
Oxygen (%)	3

**Carbon Monoxide**

Average concentration CO (mg/m <sup>3</sup> )	2.8
Maximum concentration CO (mg/m <sup>3</sup> )	3.6
Minimum concentration CO (mg/m <sup>3</sup> )	2.1
Mass Emission CO (Kg/hour)	0.01
% Uncertainty of measurement	24.3
Uncertainty Concentration mg/m <sup>3</sup>	0.7

**Oxides of Nitrogen (as NO<sub>2</sub>)**

Average concentration NOx (mg/m <sup>3</sup> )	157.8
Maximum concentration NOx (mg/m <sup>3</sup> )	159.6
Minimum concentration NOx (mg/m <sup>3</sup> )	156.4
Mass Emission NOx (Kg/hour)	0.28
% Uncertainty of measurement	2.0
Uncertainty Concentration mg/m <sup>3</sup>	3.1

**Sulphur Dioxide**

Average concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	12.8
Maximum concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	20.4
Minimum concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	10.4
Mass Emission SO <sub>2</sub> (Kg/hour)	0.02
% Uncertainty of measurement	7.5
Uncertainty Concentration mg/m <sup>3</sup>	1.0

**Oxygen**

Average concentration O <sub>2</sub> (% vol)	5.6
Maximum concentration O <sub>2</sub> (% vol)	5.8
Minimum concentration O <sub>2</sub> (% Vol)	5.5
% Uncertainty of measurement	3.2
Uncertainty Concentration % vol	0.2

Customer	Saputo Dairy			
Emission Point	Boiler 3			
Date	22/10/2024			
Sample No	108654/3			

Pre test				
ANALYTE	CO	NO	SO <sub>2</sub>	O <sub>2</sub>
Zero through analyser (ppm)	0	0	0	0
Span Through analyser (ppm)	101.2	145.5	144.0	6.1
Zero through analyser (ppm)	0.2	0.0	0.6	-0.01
Zero Through line (ppm)	0.20	0.00	0.20	0.01
Span Through line (ppm)	101.2	145.2	143.1	6.1
Residence Time (seconds)	0.0	0.0	0.1	0.0
System T90 (seconds)	101	145	145	6
T90 Value (ppm)	91.1	131.0	129.6	5.5
Initial leak test	0.0	0.2	0.6	0.0
Post test				
ANALYTE	CO	NO	SO <sub>2</sub>	O <sub>2</sub>
Zero Through Analyser	0.00	0.00	0.10	0.02
Span Through Analyser (ppm)	101.4	144.70	145.20	6.13
Span Drift (%)	0.2	0.3	1.5	0.5
Zero Drift (%)	0.2	0.0	0.1	0.2

Oxygen cylinder grade/reference	VC1978130 6.10%
Nitrogen Monoxide cylinder grade/reference	VC12997 145.5ppm
Sulphur Dioxide cylinder grade/reference	VC12997 144.0ppm
Carbon Monoxide cylinder grade/reference	VC12997 101.2ppm


#### Gas conditioning Temperature Validation

Temperature @ Start of Test (°C)	N/A
Temperature During Test (°C)	N/A
Temperature @ End of Test (°C)	N/A
Temperature of Heated Line (°C)	120
Temperature of PD-100 oven (°C)	100

#### Stratification Data

Point	CO ppm	NO ppm	SO <sub>2</sub> ppm	O <sub>2</sub> % vol
1	2.03	65.53	3.25	5.66
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

Combustion Gas concentrations measured on the Boiler 3, at Saputo Dairy, Davidstow  
 on the 22/10/2024  
 Sample No: 108654/3



Combustion Gas concentrations measured on the Boiler 3, at Saputo Dairy, Davidstow  
 on the 22/10/2024  
 Sample No: 108654/3

Concentration	CO mg/m <sup>3</sup>	30 Minute Rolling Mean	NOx mg/m <sup>3</sup>	30 Minute Rolling Mean	SO2 mg/m <sup>3</sup>	30 Minute Rolling Mean	O <sub>2</sub> %vol
Minimum	2.1	2.8	156.4	157.6	10.4	12.3	5.5
Maximum	3.6	2.9	159.6	157.9	20.4	13.0	5.8
Average	2.8	2.8	157.8	157.7	12.8	12.7	5.6

**EN ISO 16911 S-Type Pitot Summary Page**

Customer	Saputo Dairy UK
Site	Davidstow
Emission Point	Boiler 3
Date Measured	22-Oct-24
Sample Number	108654/3
X-Sectional Area	0.302
DH@	52.56
DY <sub>d</sub>	N/A
Average sqrt DP (mmH <sub>2</sub> O)	0.846
Average % Oxygen	5.6
Average % Carbon Dioxide	10.8
Average % Carbon Monoxide	0.0
Average % Nitrogen	83.6
Barometric Pressure (mb)	994
Duct Static Pressure (mmH <sub>2</sub> O)	-10.00
Absolute Stack Gas Pressure (KPa)	99.3
Average Stack Gas Temperature (K)	467
Moisture % (estimated)	10.00
Velocity in Stack (m/s)	3.6
Volumetric Flow at Stack Conditions (m <sup>3</sup> /sec)	1.10
Volumetric Flow at Stack Conditions (m <sup>3</sup> /hour)	3943.65
Volumetric flow rate STP, Wet (m <sup>3</sup> /sec)	0.63
Volumetric flow rate at STP, Wet (m <sup>3</sup> /hour)	2260.57
Volumetric flow rate STP, Dry (m <sup>3</sup> /sec)	0.57
Volumetric flow rate at STP, Dry (m <sup>3</sup> /hour)	2034.51
Volumetric flow rate at reference conditions (m <sup>3</sup> /sec)	0.48
Volumetric flow rate at reference conditions (m <sup>3</sup> /hour)	1737.06
% Uncertainty of Measurement	5.3

Client	Saputo Dairy UK
Site	Davidstow
Emission Point	Boiler 3
Date	22/10/2024
Sample Number	108654/3
Probe Operator	LL
Console Operator	PR

DGM Inlet (°C)	25
DGM Outlet (°C)	25
Mean Temp (°C)	25
Bar Pressure (mb)	994
Moisture (%)	10.10
Dimension (m)	0.62
Stack C.S.A (m <sup>2</sup> )	0.3019

Gas Flow	Out
Port Nipple (cm)	60
Console No.	A/S694
Pitot No.	A/S849
Tape Measure	A/S544
Timer	A/S685
Barometer No.	A/S543

### Traverse Line 1

### Traverse Line

### Traverse Line 3

### Traverse Line

Field Performance Criteria	OK?		
Pitch $\leq \pm 10^\circ$	N/A	Is Negative Flow Present?	No
Swirl $\leq \pm 15^\circ$	Yes	Minimum Velocity $> 5\text{pa}$	Yes
Stack Internal Area	Yes	Ratio of gas Velocities $< 3:1$	Yes
Field Repeatability	N/A		
Static Pressure Check	Yes		

Flow Characteristics Meet Requirements of EN ISO 16911?	
	Yes

Number of Sample Points
4

**Carbon Monoxide**

Average concentration CO (mg/m <sup>3</sup> )	3.3
Maximum concentration CO (mg/m <sup>3</sup> )	3.8
Minimum concentration CO (mg/m <sup>3</sup> )	2.5
Mass Emission CO (Kg/hour)	0.01
% Uncertainty of measurement	19.0
Uncertainty Concentration mg/m <sup>3</sup>	0.6

**Oxides of Nitrogen (as NO<sub>2</sub>)**

Average concentration NOx (mg/m <sup>3</sup> )	159.5
Maximum concentration NOx (mg/m <sup>3</sup> )	166.7
Minimum concentration NOx (mg/m <sup>3</sup> )	157.8
Mass Emission NOx (Kg/hour)	0.37
% Uncertainty of measurement	1.8
Uncertainty Concentration mg/m <sup>3</sup>	2.8

**Sulphur Dioxide**

Average concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	12.7
Maximum concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	29.0
Minimum concentration SO <sub>2</sub> (mg/m <sup>3</sup> )	11.0
Mass Emission SO <sub>2</sub> (Kg/hour)	0.03
% Uncertainty of measurement	6.8
Uncertainty Concentration mg/m <sup>3</sup>	0.9

**Oxygen**

Average concentration O <sub>2</sub> (% vol)	3.9
Maximum concentration O <sub>2</sub> (% vol)	4.0
Minimum concentration O <sub>2</sub> (% Vol)	3.8
% Uncertainty of measurement	3.6
Uncertainty Concentration % vol	0.1

### Combustion Gas Monitoring Summary

Sample Number	108654/4
Date	22/10/2024
Customer name	Saputo Dairy
Site location	Davidstow
Emission point	Boiler 3
Emission point dimension (m)	0.62m
Emission point C.S.A. (m <sup>2</sup> )	0.3019
Team leader	Phil Ruck
Analyst(s)	Louie Liguz
Average Ambient pressure (mb)	994
Average Ambient temperature (°C)	14.5
Instrument number	A/S545 (PG-350)
Probe length (m)	1.0m
Timer	A/S685
Homogeneity test previously conducted? (Yes/No)	No
Is the gas stream homogeneous? (Yes/No/Unknown)	Unknown
Test start time	13:40:00
Test end time	14:20:00
Volumetric flow @ reference conditions (m <sup>3</sup> /hour)	2309

### Reference conditions

Temperature (K)	273
Pressure (kPa)	101.3
Moisture	Dry
Oxygen (%)	3

Customer	Saputo Dairy		
Emission Point	Boiler 3		
Date	22/10/2024		
Sample No	108654/4		

Pre test				
ANALYTE	CO	NO	SO <sub>2</sub>	O <sub>2</sub>
Zero through analyser (ppm)	0	0	0	0
Span Through analyser (ppm)	101.2	145.5	144.0	6.1
Zero through analyser (ppm)	0.2	0.0	0.6	-0.01
Zero Through line (ppm)	0.20	0.00	0.20	0.01
Span Through line (ppm)	101.2	145.2	143.1	6.1
Residence Time (seconds)	42.0	45.0	48.0	42.0
System T90 (seconds)	62	62	83	56
T90 Value (ppm)	91.1	131.0	129.6	5.5
Initial leak test	0.0	0.2	0.6	0.0
Post test				
ANALYTE	CO	NO	SO <sub>2</sub>	O <sub>2</sub>
Zero Through Analyser	0.00	0.00	0.10	0.02
Span Through Analyser (ppm)	101.4	144.70	145.20	6.13
Span Drift (%)	0.2	0.3	1.5	0.5
Zero Drift (%)	0.2	0.0	0.1	0.2

Oxygen cylinder grade/reference	VC1978130 6.10%
Nitrogen Monoxide cylinder grade/reference	VC12997 145.5ppm
Sulphur Dioxide cylinder grade/reference	VC12997 144.0ppm
Carbon Monoxide cylinder grade/reference	VC12997 101.2ppm


#### Gas conditioning Temperature Validation

Temperature @ Start of Test (°C)	N/A
Temperature During Test (°C)	N/A
Temperature @ End of Test (°C)	N/A
Temperature of Heated Line (°C)	120
Temperature of PD-100 oven (°C)	100

#### Stratification Data

Point	CO ppm	NO ppm	SO <sub>2</sub> ppm	O <sub>2</sub> % vol
1	2.42	73.66	4.00	3.96
2				
3				
4				
5				
6				
7				
8				
9				
10				
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				

Combustion Gas concentrations measured on the Boiler 3, at Saputo Dairy, Davidstow  
 on the 22/10/2024  
 Sample No: 108654/4



Combustion Gas concentrations measured on the Boiler 3, at Saputo Dairy, Davidstow  
 on the 22/10/2024  
 Sample No: 108654/4

Concentration	CO mg/m <sup>3</sup>	30 Minute Rolling Mean	NOx mg/m <sup>3</sup>	30 Minute Rolling Mean	SO2 mg/m <sup>3</sup>	30 Minute Rolling Mean	O <sub>2</sub> %vol
Minimum	2.5	3.3	157.8	159.3	11.0	12.3	3.8
Maximum	3.8	3.3	166.7	159.5	29.0	12.8	4.0
Average	3.3	3.3	159.5	159.4	12.7	12.7	3.9

**EN ISO 16911 S-Type Pitot Summary Page**

Customer	Saputo Dairy UK
Site	Davidstow
Emission Point	Boiler 3
Date Measured	22-Oct-24
Sample Number	108654/4
X-Sectional Area	0.302
DH@	52.56
DY <sub>d</sub>	N/A
Average sqrt DP (mmH <sub>2</sub> O)	1.024
Average % Oxygen	3.9
Average % Carbon Dioxide	12.0
Average % Carbon Monoxide	0.0
Average % Nitrogen	84.1
Barometric Pressure (mb)	994
Duct Static Pressure (mmH <sub>2</sub> O)	-12.50
Absolute Stack Gas Pressure (KPa)	99.3
Average Stack Gas Temperature (K)	476
Moisture % (estimated)	10.00
Velocity in Stack (m/s)	4.4
Volumetric Flow at Stack Conditions (m <sup>3</sup> /sec)	1.34
Volumetric Flow at Stack Conditions (m <sup>3</sup> /hour)	4811.75
Volumetric flow rate STP, Wet (m <sup>3</sup> /sec)	0.75
Volumetric flow rate at STP, Wet (m <sup>3</sup> /hour)	2703.91
Volumetric flow rate STP, Dry (m <sup>3</sup> /sec)	0.68
Volumetric flow rate at STP, Dry (m <sup>3</sup> /hour)	2433.52
Volumetric flow rate at reference conditions (m <sup>3</sup> /sec)	0.64
Volumetric flow rate at reference conditions (m <sup>3</sup> /hour)	2308.60
% Uncertainty of Measurement	5.3

Client	Saputo Dairy UK
Site	Davidstow
Emission Point	Boiler 3
Date	22/10/2024
Sample Number	108654/4
Probe Operator	LL
Console Operator	PR

DGM Inlet (°C)	25
DGM Outlet (°C)	25
Mean Temp (°C)	25
Bar Pressure (mb)	994
Moisture (%)	10.10
Dimension (m)	0.62
Stack C.S.A (m <sup>2</sup> )	0.3019

Gas Flow	Out
Port Nipple (cm)	60
Console No.	A/S694
Pitot No.	A/S849
Tape Measure	A/S544
Timer	A/S685
Barometer No.	A/S543

### Traverse Line 1

### Traverse Line

### Traverse Line 3

### Traverse Line

Field Performance Criteria	OK?		
Pitch $\leq \pm 10^\circ$	N/A	Is Negative Flow Present?	No
Swirl $\leq \pm 15^\circ$	Yes	Minimum Velocity $> 5\text{pa}$	Yes
Stack Internal Area	Yes	Ratio of gas Velocities $< 3:1$	Yes
Field Repeatability	N/A		
Static Pressure Check	Yes		

## Flow Characteristics Meet Requirements of EN ISO 16911?

Number of Sample Points
4

# APPENDIX 3

**(Uncertainty)**

**(20 Pages)**

# Uncertainty Budget for Oxides of nitrogen



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/1

<b>Measured NOx concentration (mg/m<sup>3</sup>)</b>	124.97	<b>Calibration Value (mg/m<sup>3</sup>)</b>	298.28
<b>ELV</b>	1000	<b>Scale used (mg/m<sup>3</sup>)</b>	512.50

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	33	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.04	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.08	≤±2.0% Range	u <sub>rs</sub>	0.01
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.06
Zero Drift (During Measurement)	0.00	% full scale	u <sub>0dr</sub>	0.43
Span Drift (During Measurement)	0.34	% full scale		
Losses in the Line (Leak)	0.21	<2% of value	u <sub>leak</sub>	0.15
Sensitivity to Atmospheric Pressure	0.1	<1.5% of the certification range	u <sub>apres</sub>	0.00
Sensitivity to Sample Gas Flow	0.1	<1.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	1.53	<3.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	0.04	<3.0% of the certification range		
Sensitivity to Electric Voltage	-0.23	<2.0% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity (Interferents)	0.00	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.3	<2% of value	u <sub>calib</sub>	0.94
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	1.04			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	2.09			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	2.92			
<b>Expanded Uncertainty (% ELV)</b>	<b>0.29</b>			
<b>Expanded uncertainty (mg/m<sup>3</sup>)</b>	<b>2.92</b>			
<b>Expanded uncertainty (% Value)</b>	<b>2.33</b>			
<b>Requirement in standard is for uncertainty to be &lt; ±10% at ELV at standard conditions</b>				

# Uncertainty Budget for Carbon monoxide



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/1

<b>Measured CO concentration (mg/m<sup>3</sup>)</b>	8.41	<b>Calibration Value (mg/m<sup>3</sup>)</b>	126.50
<b>ELV</b>	N/A	<b>Scale used (mg/m<sup>3</sup>)</b>	250.00

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	28	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.16	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.35	≤±2.0% Range	u <sub>rs</sub>	0.03
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.03
Zero Drift (During Measurement)	0.20	% full scale	u <sub>0dr</sub>	0.30
Span Drift (During Measurement)	0.20	% full scale		
Losses in the Line (Leak)	0.00	<2% of value	u <sub>leak</sub>	0.00
Sensitivity to Atmospheric Pressure	0.22	<1.5% of the certification range	u <sub>apres</sub>	0.00
Sensitivity to Sample Gas Flow	0.1	<1.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	2	<3.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	-0.2	<3.0% of the certification range		
Sensitivity to Electric Voltage	-0.35	<2.0% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity (Interferents)	0.53	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.7	<2% of value	u <sub>calib</sub>	0.08
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	0.32			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	0.64			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	0.89			
<b>Expanded Uncertainty (% ELV)</b>	<b>N/A</b>			
<b>Expanded uncertainty (mg/m<sup>3</sup>)</b>	<b>0.89</b>			
<b>Expanded uncertainty (% Value)</b>	<b>10.56</b>			
Requirement in standard is for uncertainty to be < ±6% at ELV at standard conditions				

# Uncertainty Budget for Sulphur dioxide



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/1

<b>Measured SO<sub>2</sub> concentration (mg/m<sup>3</sup>)</b>	3.14	<b>Calibration Value (mg/m<sup>3</sup>)</b>	411.84
<b>ELV</b>	1000	<b>Scale used (mg/m<sup>3</sup>)</b>	572.00

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	60	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.09	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.12	≤±2.0% Range	u <sub>rs</sub>	0.01
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.07
Zero Drift (During Measurement)	0.07	% full scale	u <sub>0dr</sub>	0.27
Span Drift (During Measurement)	1.47	% full scale		
Losses in the Line (Leak)	0.63	<5% of value	u <sub>leak</sub>	0.01
Sensitivity to Atmospheric Pressure	N/A	N/A	u <sub>apres</sub>	N/A
Sensitivity to Sample Gas Flow	0.3	<2.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	2.4	<5.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	2.1	<5.0% of the certification range		
Sensitivity to Electric Voltage	1.00	<0.10% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity @ Reference (Interferents)	-1.82	<4% of the certification range	u <sub>int</sub>	0.00
Cross Sensitivity @ Zero (Interferents)	-0.48	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.8	<2% of value	u <sub>calib</sub>	0.03
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	0.28			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	0.56			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	0.78			
Expanded Uncertainty (% ELV)	0.08			
Expanded uncertainty (mg/m <sup>3</sup> )	0.78			
Expanded uncertainty (% Value)	24.73			
Requirement in standard is for uncertainty to be <±20% at ELV at standard conditions				

## Uncertainty Budget for Oxygen



# Anchem LABORATORIES LIMITED

<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/1

<b>Measured oxygen concentration (% Vol)</b>	8.10	<b>Calibration Value (% Vol)</b>	6.10
<b>ELV</b>	N/A	<b>Scale used (% Vol)</b>	25.00

**ISO 16911 S-Type Pitot Uncertainty**

Client	Saputo Dairy UK		
Site	Davidstow		
Emission Point	Boiler 3		
Date	22/10/2024		
Sample Number	108654/1		

Uncertainty	Estimated Value %	Measured Value %	sqr est	sqr meas
<b>Equipment Sources</b>				
Master System Velocity Measurements		1	0	1
Master System Air Density Measurement		0.15	0	0.0225
Tape Measure		2	0	4
Dual Incline Manometer		0.05	0	0.0025
Thermocouples		1	0	1
Sensitivity to Atmospheric Pressure	2		4	0
Sensitivity to Ambient Temperature	2		4	0
<b>Site Sources</b>				
Stack Internal Area		2.60014E-06	0	6.76073E-12
Uncertainty in Flow Measurement Device Calibration	1		1	0
Uncertainty in Differential Pressure Device Calibration	1		1	0
Time	0		0	0
S-Type Reference/Stagnation Check		0.00	0	0
Repeatability at single point			0	0
Swirl/Pitch Meter Position	2		4	0
Temperature on site			0	0
Pressure on Site			0	0
Humidity on Site	0		0	0
<b>Laboratory Sources</b>				
Uncertainty due to Calibration	2		4	0
Repeatability (hPa)		0.66	0	0.4356
Repeatability (m/s)		0.14		
Linearity		0.15	0	0.0225
Measurement of Duct Diameter		0.67	0	0.4489
Effect of Swirl Angle (Clockwise)		0.16	0	0.0256
Effect of Swirl Angle (Anti-clockwise)		1.82	0	3.3124
Sum of squares			28.27	
		<b>Total Uncertainty</b>	<b>5.3</b>	

# Uncertainty Budget for Oxides of nitrogen



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/2

<b>Measured NOx concentration (mg/m<sup>3</sup>)</b>	141.00	<b>Calibration Value (mg/m<sup>3</sup>)</b>	298.28
<b>ELV</b>	1000	<b>Scale used (mg/m<sup>3</sup>)</b>	512.50

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	33	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.04	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.08	≤±2.0% Range	u <sub>rs</sub>	0.01
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.06
Zero Drift (During Measurement)	0.00	% full scale	u <sub>odr</sub>	0.48
Span Drift (During Measurement)	0.34	% full scale		
Losses in the Line (Leak)	0.21	<2% of value	u <sub>leak</sub>	0.17
Sensitivity to Atmospheric Pressure	0.1	<1.5% of the certification range	u <sub>apres</sub>	0.00
Sensitivity to Sample Gas Flow	0.1	<1.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	1.53	<3.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	0.04	<3.0% of the certification range		
Sensitivity to Electric Voltage	-0.23	<2.0% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity (Interferents)	0.00	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.3	<2% of value	u <sub>calib</sub>	1.06
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	1.18			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	2.35			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	2.99			
<b>Expanded Uncertainty (% ELV)</b>	<b>0.30</b>			
<b>Expanded uncertainty (mg/m<sup>3</sup>)</b>	<b>2.99</b>			
<b>Expanded uncertainty (% Value)</b>	<b>2.12</b>			
<b>Requirement in standard is for uncertainty to be &lt; ±10% at ELV at standard conditions</b>				

# Uncertainty Budget for Carbon monoxide



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/2

<b>Measured CO concentration (mg/m<sup>3</sup>)</b>	3.28	<b>Calibration Value (mg/m<sup>3</sup>)</b>	126.50
<b>ELV</b>	N/A	<b>Scale used (mg/m<sup>3</sup>)</b>	250.00

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	28	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.16	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.35	≤±2.0% Range	u <sub>rs</sub>	0.03
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.03
Zero Drift (During Measurement)	0.20	% full scale	u <sub>0dr</sub>	0.29
Span Drift (During Measurement)	0.20	% full scale		
Losses in the Line (Leak)	0.00	<2% of value	u <sub>leak</sub>	0.00
Sensitivity to Atmospheric Pressure	0.22	<1.5% of the certification range	u <sub>apres</sub>	0.00
Sensitivity to Sample Gas Flow	0.1	<1.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	2	<3.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	-0.2	<3.0% of the certification range		
Sensitivity to Electric Voltage	-0.35	<2.0% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity (Interferents)	0.53	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.7	<2% of value	u <sub>calib</sub>	0.03
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	0.30			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	0.59			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	0.75			
<b>Expanded Uncertainty (% ELV)</b>	<b>N/A</b>			
<b>Expanded uncertainty (mg/m<sup>3</sup>)</b>	<b>0.75</b>			
<b>Expanded uncertainty (% Value)</b>	<b>22.98</b>			
Requirement in standard is for uncertainty to be < ±6% at ELV at standard conditions				

# Uncertainty Budget for Sulphur dioxide



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/2

<b>Measured SO<sub>2</sub> concentration (mg/m<sup>3</sup>)</b>	12.12	<b>Calibration Value (mg/m<sup>3</sup>)</b>	411.84
<b>ELV</b>	1000	<b>Scale used (mg/m<sup>3</sup>)</b>	572.00

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	60	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.09	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.12	≤±2.0% Range	u <sub>rs</sub>	0.01
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.07
Zero Drift (During Measurement)	0.07	% full scale	u <sub>0dr</sub>	0.37
Span Drift (During Measurement)	1.47	% full scale		
Losses in the Line (Leak)	0.63	<5% of value	u <sub>leak</sub>	0.04
Sensitivity to Atmospheric Pressure	N/A	N/A	u <sub>apres</sub>	N/A
Sensitivity to Sample Gas Flow	0.3	<2.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	2.4	<5.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	2.1	<5.0% of the certification range		
Sensitivity to Electric Voltage	1.00	<0.10% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity @ Reference (Interferents)	-1.82	<4% of the certification range	u <sub>int</sub>	0.00
Cross Sensitivity @ Zero (Interferents)	-0.48	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.8	<2% of value	u <sub>calib</sub>	0.13
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	0.40			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	0.80			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	1.02			
Expanded Uncertainty (% ELV)	0.10			
Expanded uncertainty (mg/m <sup>3</sup> )	1.02			
Expanded uncertainty (% Value)	8.42			
Requirement in standard is for uncertainty to be <±20% at ELV at standard conditions				

## Uncertainty Budget for Oxygen



# Anchem LABORATORIES LIMITED

<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/2

<b>Measured oxygen concentration (% Vol)</b>	6.80	<b>Calibration Value (% Vol)</b>	6.10
<b>ELV</b>	N/A	<b>Scale used (% Vol)</b>	25.00

**ISO 16911 S-Type Pitot Uncertainty**

Client	Saputo Dairy UK		
Site	Davidstow		
Emission Point	Boiler 3		
Date	22/10/2024		
Sample Number	108654/2		

Uncertainty	Estimated Value %	Measured Value %	sqr est	sqr meas
<b>Equipment Sources</b>				
Master System Velocity Measurements		1	0	1
Master System Air Density Measurement		0.15	0	0.0225
Tape Measure		2	0	4
Dual Incline Manometer		0.05	0	0.0025
Thermocouples		1	0	1
Sensitivity to Atmospheric Pressure	2		4	0
Sensitivity to Ambient Temperature	2		4	0
<b>Site Sources</b>				
Stack Internal Area		2.60014E-06	0	6.76073E-12
Uncertainty in Flow Measurement Device Calibration	1		1	0
Uncertainty in Differential Pressure Device Calibration	1		1	0
Time	0		0	0
S-Type Reference/Stagnation Check		0.00	0	0
Repeatability at single point			0	0
Swirl/Pitch Meter Position	2		4	0
Temperature on site			0	0
Pressure on Site			0	0
Humidity on Site	0		0	0
<b>Laboratory Sources</b>				
Uncertainty due to Calibration	2		4	0
Repeatability (hPa)		0.66	0	0.4356
Repeatability (m/s)		0.14		
Linearity		0.15	0	0.0225
Measurement of Duct Diameter		0.67	0	0.4489
Effect of Swirl Angle (Clockwise)		0.16	0	0.0256
Effect of Swirl Angle (Anti-clockwise)		1.82	0	3.3124
Sum of squares			28.27	
		<b>Total Uncertainty</b>	<b>5.3</b>	

<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/3

<b>Measured NOx concentration (mg/m<sup>3</sup>)</b>	157.79	<b>Calibration Value (mg/m<sup>3</sup>)</b>	298.28
<b>ELV</b>	1000	<b>Scale used (mg/m<sup>3</sup>)</b>	512.50

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	33	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.04	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.08	≤±2.0% Range	u <sub>rs</sub>	0.01
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.06
Zero Drift (During Measurement)	0.00	% full scale	u <sub>0dr</sub>	0.54
Span Drift (During Measurement)	0.34	% full scale		
Losses in the Line (Leak)	0.21	<2% of value	u <sub>leak</sub>	0.19
Sensitivity to Atmospheric Pressure	0.1	<1.5% of the certification range	u <sub>apres</sub>	0.00
Sensitivity to Sample Gas Flow	0.1	<1.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	1.53	<3.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	0.04	<3.0% of the certification range		
Sensitivity to Electric Voltage	-0.23	<2.0% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity (Interferents)	0.00	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.3	<2% of value	u <sub>calib</sub>	1.18
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	1.32			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	2.63			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	3.08			
<b>Expanded Uncertainty (% ELV)</b>	<b>0.31</b>			
<b>Expanded uncertainty (mg/m<sup>3</sup>)</b>	<b>3.08</b>			
<b>Expanded uncertainty (% Value)</b>	<b>1.95</b>			
<b>Requirement in standard is for uncertainty to be &lt; ±10% at ELV at standard conditions</b>				

# Uncertainty Budget for Carbon monoxide



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/3

<b>Measured CO concentration (mg/m<sup>3</sup>)</b>	2.85	<b>Calibration Value (mg/m<sup>3</sup>)</b>	126.50
<b>ELV</b>	N/A	<b>Scale used (mg/m<sup>3</sup>)</b>	250.00

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	28	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.16	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.35	≤±2.0% Range	u <sub>rs</sub>	0.03
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.03
Zero Drift (During Measurement)	0.20	% full scale	u <sub>0dr</sub>	0.29
Span Drift (During Measurement)	0.20	% full scale		
Losses in the Line (Leak)	0.00	<2% of value	u <sub>leak</sub>	0.00
Sensitivity to Atmospheric Pressure	0.22	<1.5% of the certification range	u <sub>apres</sub>	0.00
Sensitivity to Sample Gas Flow	0.1	<1.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	2	<3.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	-0.2	<3.0% of the certification range		
Sensitivity to Electric Voltage	-0.35	<2.0% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity (Interferents)	0.53	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.7	<2% of value	u <sub>calib</sub>	0.03
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	0.30			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	0.59			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	0.69			
<b>Expanded Uncertainty (% ELV)</b>	<b>N/A</b>			
<b>Expanded uncertainty (mg/m<sup>3</sup>)</b>	<b>0.69</b>			
<b>Expanded uncertainty (% Value)</b>	<b>24.32</b>			
Requirement in standard is for uncertainty to be < ±6% at ELV at standard conditions				

# Uncertainty Budget for Sulphur dioxide



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/3

<b>Measured SO<sub>2</sub> concentration (mg/m<sup>3</sup>)</b>	12.85	<b>Calibration Value (mg/m<sup>3</sup>)</b>	411.84
<b>ELV</b>	1000	<b>Scale used (mg/m<sup>3</sup>)</b>	572.00

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	60	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	42			
Number of Readings in Measurements	168			
Standard dev Repeat @ Zero	0.09	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.12	≤±2.0% Range	u <sub>rs</sub>	0.01
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.07
Zero Drift (During Measurement)	0.07	% full scale	u <sub>0dr</sub>	0.38
Span Drift (During Measurement)	1.47	% full scale		
Losses in the Line (Leak)	0.63	<5% of value	u <sub>leak</sub>	0.05
Sensitivity to Atmospheric Pressure	N/A	N/A	u <sub>apres</sub>	N/A
Sensitivity to Sample Gas Flow	0.3	<2.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	2.4	<5.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	2.1	<5.0% of the certification range		
Sensitivity to Electric Voltage	1.00	<0.10% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity @ Reference (Interferents)	-1.82	<4% of the certification range	u <sub>int</sub>	0.00
Cross Sensitivity @ Zero (Interferents)	-0.48	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.8	<2% of value	u <sub>calib</sub>	0.13
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	0.41			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	0.83			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	0.97			
Expanded Uncertainty (% ELV)	0.10			
Expanded uncertainty (mg/m <sup>3</sup> )	0.97			
Expanded uncertainty (% Value)	7.53			
Requirement in standard is for uncertainty to be <±20% at ELV at standard conditions				

## Uncertainty Budget for Oxygen



# Anchem LABORATORIES LIMITED

<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/3

<b>Measured oxygen concentration (% Vol)</b>	5.62	<b>Calibration Value (% Vol)</b>	6.10
<b>ELV</b>	N/A	<b>Scale used (% Vol)</b>	25.00

**ISO 16911 S-Type Pitot Uncertainty**

Client	Saputo Dairy UK		
Site	Davidstow		
Emission Point	Boiler 3		
Date	22/10/2024		
Sample Number	108654/3		

Uncertainty	Estimated Value %	Measured Value %	sqr est	sqr meas
<b>Equipment Sources</b>				
Master System Velocity Measurements		1	0	1
Master System Air Density Measurement		0.15	0	0.0225
Tape Measure		2	0	4
Dual Incline Manometer		0.05	0	0.0025
Thermocouples		1	0	1
Sensitivity to Atmospheric Pressure	2		4	0
Sensitivity to Ambient Temperature	2		4	0
<b>Site Sources</b>				
Stack Internal Area		2.60014E-06	0	6.76073E-12
Uncertainty in Flow Measurement Device Calibration	1		1	0
Uncertainty in Differential Pressure Device Calibration	1		1	0
Time	0		0	0
S-Type Reference/Stagnation Check		0.00	0	0
Repeatability at single point			0	0
Swirl/Pitch Meter Position	2		4	0
Temperature on site			0	0
Pressure on Site			0	0
Humidity on Site	0		0	0
<b>Laboratory Sources</b>				
Uncertainty due to Calibration	2		4	0
Repeatability (hPa)		0.66	0	0.4356
Repeatability (m/s)		0.14		
Linearity		0.15	0	0.0225
Measurement of Duct Diameter		0.67	0	0.4489
Effect of Swirl Angle (Clockwise)		0.16	0	0.0256
Effect of Swirl Angle (Anti-clockwise)		1.82	0	3.3124
Sum of squares			28.27	
		<b>Total Uncertainty</b>	<b>5.3</b>	

# Uncertainty Budget for Oxides of nitrogen



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/4

<b>Measured NOx concentration (mg/m<sup>3</sup>)</b>	159.47	<b>Calibration Value (mg/m<sup>3</sup>)</b>	298.28
<b>ELV</b>	1000	<b>Scale used (mg/m<sup>3</sup>)</b>	512.50

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	33	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	40			
Number of Readings in Measurements	160			
Standard dev Repeat @ Zero	0.04	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.08	≤±2.0% Range	u <sub>rs</sub>	0.01
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.06
Zero Drift (During Measurement)	0.00	% full scale	u <sub>0dr</sub>	0.54
Span Drift (During Measurement)	0.34	% full scale		
Losses in the Line (Leak)	0.21	<2% of value	u <sub>leak</sub>	0.19
Sensitivity to Atmospheric Pressure	0.1	<1.5% of the certification range	u <sub>apres</sub>	0.00
Sensitivity to Sample Gas Flow	0.1	<1.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	1.53	<3.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	0.04	<3.0% of the certification range		
Sensitivity to Electric Voltage	-0.23	<2.0% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity (Interferents)	0.00	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.3	<2% of value	u <sub>calib</sub>	1.20
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	1.33			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	2.66			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	2.80			
<b>Expanded Uncertainty (% ELV)</b>	<b>0.28</b>			
<b>Expanded uncertainty (mg/m<sup>3</sup>)</b>	<b>2.80</b>			
<b>Expanded uncertainty (% Value)</b>	<b>1.75</b>			
<b>Requirement in standard is for uncertainty to be &lt; ±10% at ELV at standard conditions</b>				

# Uncertainty Budget for Carbon monoxide



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/4

<b>Measured CO concentration (mg/m<sup>3</sup>)</b>	3.29	<b>Calibration Value (mg/m<sup>3</sup>)</b>	126.50
<b>ELV</b>	N/A	<b>Scale used (mg/m<sup>3</sup>)</b>	250.00

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	28	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	40			
Number of Readings in Measurements	160			
Standard dev Repeat @ Zero	0.16	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.35	≤±2.0% Range	u <sub>rs</sub>	0.03
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.03
Zero Drift (During Measurement)	0.20	% full scale	u <sub>0dr</sub>	0.29
Span Drift (During Measurement)	0.20	% full scale		
Losses in the Line (Leak)	0.00	<2% of value	u <sub>leak</sub>	0.00
Sensitivity to Atmospheric Pressure	0.22	<1.5% of the certification range	u <sub>apres</sub>	0.00
Sensitivity to Sample Gas Flow	0.1	<1.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	2	<3.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	-0.2	<3.0% of the certification range		
Sensitivity to Electric Voltage	-0.35	<2.0% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity (Interferents)	0.53	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.7	<2% of value	u <sub>calib</sub>	0.03
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	0.30			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	0.59			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	0.62			
<b>Expanded Uncertainty (% ELV)</b>	<b>N/A</b>			
<b>Expanded uncertainty (mg/m<sup>3</sup>)</b>	<b>0.62</b>			
<b>Expanded uncertainty (% Value)</b>	<b>18.96</b>			
Requirement in standard is for uncertainty to be < ±6% at ELV at standard conditions				

# Uncertainty Budget for Sulphur dioxide



<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/4

<b>Measured SO<sub>2</sub> concentration (mg/m<sup>3</sup>)</b>	12.70	<b>Calibration Value (mg/m<sup>3</sup>)</b>	411.84
<b>ELV</b>	1000	<b>Scale used (mg/m<sup>3</sup>)</b>	572.00

<b>Performance Characteristic</b>		<b>Specification</b>	<b>Uncertainty</b>	
Response Time (seconds)	60	<200s		
Logger Sampling Interval (seconds)	15			
Measurement Period (minutes)	40			
Number of Readings in Measurements	160			
Standard dev Repeat @ Zero	0.09	≤±1.0% Range	u <sub>r0</sub>	N/A
Standard dev Repeat @ Span	0.12	≤±2.0% Range	u <sub>rs</sub>	0.01
Deviation from Linearity (±)	0.02	≤±2.0% Range	u <sub>fit</sub>	0.07
Zero Drift (During Measurement)	0.07	% full scale	u <sub>0dr</sub>	0.38
Span Drift (During Measurement)	1.47	% full scale		
Losses in the Line (Leak)	0.63	<5% of value	u <sub>leak</sub>	0.05
Sensitivity to Atmospheric Pressure	N/A	N/A	u <sub>apres</sub>	N/A
Sensitivity to Sample Gas Flow	0.3	<2.0% of the certification range	u <sub>spres</sub>	0.00
Sensitivity to Ambient Temp @ Span	2.4	<5.0% of the certification range	u <sub>temp</sub>	0.00
Sensitivity to Ambient Temp @ Zero	2.1	<5.0% of the certification range		
Sensitivity to Electric Voltage	1.00	<0.10% of the certification range	u <sub>volt</sub>	0.00
Cross Sensitivity @ Reference (Interferents)	-1.82	<4% of the certification range	u <sub>int</sub>	0.00
Cross Sensitivity @ Zero (Interferents)	-0.48	<4% of the certification range	u <sub>int</sub>	0.00
Uncertainty of calibration gas	1.8	<2% of value	u <sub>calib</sub>	0.13
Uncertainty in Factor	0.00		u <sub>f</sub>	0.00
<b>Measurement Uncertainty</b>				
Combined Uncertainty (mg/m <sup>3</sup> )	0.41			
Coverage Factor k	2			
Expanded uncertainty (mg/m <sup>3</sup> )	0.82			
Expanded uncertainty to std conditions (mg/m <sup>3</sup> )	0.86			
Expanded Uncertainty (% ELV)	0.09			
Expanded uncertainty (mg/m <sup>3</sup> )	0.86			
Expanded uncertainty (% Value)	6.79			
Requirement in standard is for uncertainty to be <±20% at ELV at standard conditions				

## Uncertainty Budget for Oxygen



# Anchem Laboratories Limited

<b>Client</b>	Saputo Dairy	<b>Date</b>	22/10/2024
<b>Emission Point ID</b>	Boiler 3	<b>Sample Number</b>	108654/4

<b>Measured oxygen concentration (% Vol)</b>	3.87	<b>Calibration Value (% Vol)</b>	6.10
<b>ELV</b>	N/A	<b>Scale used (% Vol)</b>	25.00

**ISO 16911 S-Type Pitot Uncertainty**

Client	Saputo Dairy UK		
Site	Davidstow		
Emission Point	Boiler 3		
Date	22/10/2024		
Sample Number	108654/4		

Uncertainty	Estimated Value %	Measured Value %	sqr est	sqr meas
<b>Equipment Sources</b>				
Master System Velocity Measurements		1	0	1
Master System Air Density Measurement		0.15	0	0.0225
Tape Measure		2	0	4
Dual Incline Manometer		0.05	0	0.0025
Thermocouples		1	0	1
Sensitivity to Atmospheric Pressure	2		4	0
Sensitivity to Ambient Temperature	2		4	0
<b>Site Sources</b>				
Stack Internal Area		2.60014E-06	0	6.76073E-12
Uncertainty in Flow Measurement Device Calibration	1		1	0
Uncertainty in Differential Pressure Device Calibration	1		1	0
Time	0		0	0
S-Type Reference/Stagnation Check		0.29	0	0.08661249
Repeatability at single point			0	0
Swirl/Pitch Meter Position	2		4	0
Temperature on site			0	0
Pressure on Site			0	0
Humidity on Site	0		0	0
<b>Laboratory Sources</b>				
Uncertainty due to Calibration	2		4	0
Repeatability (hPa)		0.66	0	0.4356
Repeatability (m/s)		0.14		
Linearity		0.15	0	0.0225
Measurement of Duct Diameter		0.67	0	0.4489
Effect of Swirl Angle (Clockwise)		0.16	0	0.0256
Effect of Swirl Angle (Anti-clockwise)		1.82	0	3.3124
Sum of squares			28.356612	
		<b>Total Uncertainty</b>	<b>5.3</b>	

# APPENDIX 4

**(Instrumental analyser details)**

**(2 Pages)**

## Principle of Gas Conditioning

The sampling for oxygen, oxides of nitrogen, sulphur dioxide and carbon monoxide was carried out using a Horiba PG-350 combustion gas analyser fed via a heated sampling system comprising of a sampling probe, 20m sampling line (set at 120°C) and a PD100 permeation dryer gas conditioning system.

The sample gas enters a heated filter (approx. 100°C), separating all particles larger than 2µm. After filtration the sample gas proceeds to the permeation dryer, equipped with a temperature gradient. The installed permeation dryer is operated with dry purge gas, running in inverted direction flow. Due to the difference in partial pressure between sample and purge gas, humidity is driven out of the sample by equalization. The water is extracted from the sample gas through a semi permeable membrane and transported into an outer tube filled with the purge gas. This process does not have a distinguishable effect on the sample gas composition. The conditioned gas is then passed to the gas analyser for quantification.

Oxides of nitrogen are analysed using a standard technique called Chemiluminescence and during the sampling was set to cover the range 0-250 ppm.

Sulphur dioxide is analysed using a standard technique called Non-dispersive infra-red spectroscopy (N.D.I.R.) and was set to cover the range 0-200 ppm.

Carbon monoxide is analysed using a standard technique called Non-dispersive infra-red spectroscopy (N.D.I.R.) and was set to cover the range 0-2000ppm.

Performance Characteristic	Minimum performance characteristic			
	NOx	CO	O <sub>2</sub>	SO <sub>2</sub>
<b>Response Time (Required)</b>	≤200 s	≤200 s	≤200 s	≤200 s
Results	<50	<50	<40	<60
<b>Detection Limit</b>	≤± 2% Range	≤± 2% Range	≤± 0.2% relative of Range	≤± 2%
Results	<0.1	<0.2	<0.05	<0.15
<b>Lack of Fit (Linearity)</b>	≤± 2% Range	≤± 2% Range	≤± 0.3% volume	≤± 2%
Results	<2 (R <sup>2</sup> >0.9998)	<2 (R <sup>2</sup> >0.9999)	<2 (R <sup>2</sup> >0.9998)	<2 (R <sup>2</sup> >0.9997)
<b>Zero Drift</b>	≤± 2% Range/24 hours	≤± 2% Range/24 hours	≤± 0.2% Volume/24 hours	≤± 2%/24 hours
Results	0.04%	0.12%	0.02%	0.44%
<b>Span Drift</b>	≤± 2% Range/24 hours	≤± 2% Range/24 hours	≤± 0.2% Volume/24 hours	≤± 2%/24 hours
Results	0.08%	0.25%	0.01%	0.75%
<b>Sensitivity to Atmos Pressure</b>	≤± 3% Range/2 kPa	≤± 3% Range/2 kPa	≤± 3% of Range for 2 kPa	≤± 3%/2 kPa
Results	≤± 3% Range/2 kPa	≤± 3% Range/2 kPa	≤± 3% of Range for 2 kPa	≤± 3%/2 kPa
<b>Sensitivity to Sample Volume/pressure</b>	-	-	-	≤± 1%
Results	-	-	-	≤± 1%
<b>Sensitivity to ambient temperature</b>	≤± 3% Range/10 K	≤± 3% Range/10 K	≤± 0.3% Volume/10 K	≤± 3% Range/10 K
Results	≤± 3% Range/10 K	≤± 3% Range/10 K	≤± 0.3% Volume/10 K	≤± 3% Range/10 K
<b>Sensitivity to Electric Voltage</b>	≤± 2% Range/10 V	≤± 2% Range/10 V	≤± 0.1% Volume/10 V	≤± 2% Range/10 V
Results	≤± 2% Range/10 V	≤± 2% Range/10 V	≤± 0.1% Volume/10 V	≤± 2% Range/10 V
<b>Interferents</b>	Total ≤± 4% Range	Total ≤± 4% Range	Total ≤± 0.2% Volume	Total ≤± 4%
Results	-0.52%	-0.87%	0%	-1.82%
<b>Converter Efficiency</b>	≥95.0%			
Results	95.24%			
<b>Losses &amp; Leakage in Sampling Line and Conditioning System</b>	≤± 2% of measured value	≤± 2% of measured value	≤± 2.0% relative of the measured value	≤± 5%
Results	<2%	<2%	<2%	<5%
<b>Std Deviation of repeatability in Lab at zero</b>	≤± 1% Range	≤± 1% Range	≤± 0.20% relative of the range	≤± 1%
Results	0.03%	0.32%	0.07%	0.24%
<b>Std Deviation of repeatability in Lab at span level</b>	≤± 2% Range	≤± 2% Range	≤± 0.40% relative of the range	≤± 2%
Results	0.11%	0.22%	0.06%	0.46%

# APPENDIX 5

**(Annual calibration details & analysis data retained at permanent laboratory)**