


Power Logger Survey

Site - Vector Building 118


Current

Friday 03/01/2025 08:30:00 - Monday 13/01/2025 10:30:00



KWh

Friday 03/01/2025 08:30:00 - Monday 13/01/2025 10:30:00



Energy

Stats

From:	03/01/2025 08:00:00						
To:	13/01/2025 11:00:00						
Duration:	10 days 3 hours						
Interval:	30 minutes						
Data Points:	486						
Item:	Current 1 (amps)	Current 2 (amps)	Current 3 (amps)	Power Factor	Voltage (volts)	Energy (kWh)	Power (kW)
Mean Value:	21.1	22.6	21.5	-0.77	239.61	7.61	15.3
Median Value:	188.7	202.8	191.9	0.05	238.67	68.55	137.3
Maximum Value:	376.4	404.9	383.1	1.00	243.27	137.08	274.2
Time of Maximum:	06/01/2025 10:30:00	10/01/2025 11:00:00	06/01/2025 10:30:00	13/01/2025 06:00:00	11/01/2025 18:30:00	06/01/2025 10:30:00	06/01/2025 10:30:00
Minimum Value:	1.1	0.7	0.8	-0.90	234.07	0.01	0.5
Time of Minimum:	08/01/2025 17:30:00	09/01/2025 12:30:00	12/01/2025 16:00:00	09/01/2025 11:00:00	13/01/2025 08:30:00	03/01/2025 08:30:00	09/01/2025 11:00:00
Mean to Peak Ratio:	0.1	0.1	0.1	-0.78	0.98	0.06	0.1
Standard Deviation:	3.5	3.8	3.6	0.02	0.09	1.28	2.6
Overall Value:	21.1	22.6	21.5	1.00	239.61	3696.66	15.3

One company,
five specialist divisions



0845 6439 222
www.2teck.co.uk